

#### **SYSTEM OVERVIEW**

### Description:

-48 VDC @ up to 12000 Amperes Power System

The Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System is an integrated power system containing -48 VDC rectifiers, optional +24 VDC converters, optional -58 VDC converters, optional inverter system, intelligent control, metering, monitoring, and distribution.

This power system is designed to power a load while charging a positive grounded battery. This power system is capable of operating in a batteryless installation or off battery for maintenance purposes. The power system is designed for operation with the positive output grounded.

This system consists of the following components.

#### Distribution Cabinet

The system always includes a minimum of one distribution cabinet, which provides DC distribution through fuses and/or circuit breakers. The distribution cabinet is factory mounted in a relay rack, on shipping brackets, or in an enclosure as specified when ordered.

Four different sizes of configurable distribution cabinets are available to accept from one (1) to four (4) distribution panels. A variety of distribution panels are available that provide load distribution, battery distribution, and dual voltage load distribution for use with +24 VDC converters or -58 VDC converters. These distribution panels are configured to accept either bullet nose type circuit breakers and TPS/TLS fuseholders, TPH fuses, or GJ/218 circuit breakers. A bulk output panel is also available.

The distribution cabinet may be equipped with low voltage load disconnect (LVLD), low voltage battery disconnect (LVBD), and manual battery disconnect. Pre-configured systems are also available that incorporate specific options.

#### Controller

NCU: The controller provides power system control (including optional low voltage battery disconnect (LVBD) and low voltage load disconnect (LVLD) control), rectifier control (including a charge control function), converter control, inverter control, metering functions, monitoring functions, and local/remote alarm functions. The controller also supports rectifier temperature compensation if the system is equipped with a temperature probe(s). Temperature probe(s) may also be designated to monitor ambient temperature and/or battery temperature. The controller also provides data acquisition, system alarm management, and advanced battery and energy management. The controller contains a color LCD display and keypad for local access. The controller provides an Ethernet port and comes with comprehensive webpages for remote access. The controller has SNMP v3 capability for remote system management. The controller supports software upgrade via its USB port. Refer to the NCU Controller Instructions (UM1M830BNA) for more information.

### • Module Mounting Assembly (Spec. No. 588705300)

The system may contain one or more Spec. No. 588705300 module mounting assemblies, each of which houses 2000 watt rectifier modules, optional +24 VDC, 1500 watt DC-DC converter modules, and optional 1600W average (2000W peak) DC-DC converter modules.

### o Rectifier Modules (for use in Spec. No. 588705300)

The system contains 2000 watt rectifier modules; which provide load power, battery float current, and battery recharge current during normal operating conditions. Refer to the Rectifier Instructions (UM1R482000E3) for more information.

### Optional -48 VDC to +24 VDC Converter Modules (for use in Spec. No. 588705300)

Where +24 VDC load power is also required, 1500 watt DC-DC converter modules are available. Refer to the Converter Instructions (UM1C48241500) for more information.

#### Optional -48 VDC to -58 VDC Converter Modules (for use in Spec. No. 588705300)

Where -58 VDC load power is also required, converter modules are available. These converters operate from the main -48 VDC system bus to provide -58 VDC load power. Refer to the Converter Instructions (UM1C48582000P3) for more information.

#### Module Mounting Assembly (Spec. No. 588705400)

The system may contain one or more Spec. No. 588705400 module mounting assemblies, each of which houses up to six (6) 3500 watt rectifier modules.

#### o Rectifier Modules (for use in Spec. No. 588705400)

The system contains 3500 watt rectifier modules; which provide load power, battery float current, and battery recharge current during normal operating conditions. Refer to the Rectifier Instructions (UM1R483500E3) for more information.

#### Optional Inverter System

120 VAC @ up to 12 kVA Inverter System

The system contains one or more inverter module mounting shelves and AC distribution.

The inverter system can be set to operate in one of the three input power modes, AC Input Power Mode, DC Input Power Mode, and DC Input Only Power Mode:

- In the AC Input Power Mode, each inverter module operates with the commercial AC input to supply 120 VAC power to the loads. In the event commercial AC power fails or becomes abnormal, the inverter modules immediately transfer operation with the 48 VDC input to power to the inverters.
- In the DC Input Power Mode, each inverter module operates with the 48 VDC input to supply 120 VAC power to the loads. In the event DC power fails or becomes abnormal or an inverter module fails, the inverter module immediately transfers operation with the commercial 120 VAC input to power to the inverters.
- In the DC Input Only Power Mode, each inverter module operates with the 48 VDC input to supply 120 VAC power to the loads. In the event DC power fails or becomes abnormal or an inverter module fails, the inverter module shuts off.

The inverter system contains an EPO (Emergency Power Off) function. Connection points for a normally closed external EPO switch are provided on the customer interface board. If an external EPO switch is wired to the customer interface board, activating the switch to open the circuit activates the EPO function. The EPO function shuts down and locks out the inverters. When the EPO switch is returned to normal (closed loop), the inverters remain off. The inverters will restart when the AC and DC power inputs are removed and restored after 30 seconds or more (until the LEDs on the modules extinguish) (depending on the synchronizing time with the system). (Note that there is an EPO shorting link factory installed that can be replaced with a customer provided switch.)

**Note:** The power system's ESTOP function described in the power system Installation Manual (IM582137100) is factory wired into the inverter system's EPO function. If an EPO switch is not wired, the inverter system will still respond to the power system's ESTOP function.

This inverter system consists of the following components. Note that the inverter systems are preconfigured and do not have expansion shelves. Note the ratings are not only determined by the maximum number of inverters the system can be provided with, but also the rating of the AC distribution panel. The overall system rating cannot exceed the AC distribution panel rating.

### Inverter Module Mounting Shelf(s)


The inverter system consists of one or more inverter module mounting shelves, depending on power rating. The inverter module mounting shelves house the inverter modules.

#### Inverter Modules

The inverter system contains  $1 \, \text{kVA/1 kW}$  inverter modules ( $1 \, \text{kVA}$  at  $40 \, ^{\circ}\text{C}$  and  $0.5 \, \text{kVA}$  at  $65 \, ^{\circ}\text{C}$ ), supplying 120 VAC power from a commercial AC power source or from a  $48 \, \text{VDC}$  input. Refer to the Inverter Instructions (UMII1201000) for more information.


#### AC Load Distribution Shelf

The inverter system consists of one or more AC load distribution shelves, depending on power rating. A choice of a bulk output AC load distribution shelf or a NEMA output AC load distribution shelf is provided.



Main Bay Supplemental Bay

(E/W Spec. No. 588705300 or 588705400 Module Mounting Assemblies)



(Installed in an Enclosure)

#### **General Specifications**

See detailed specifications on page 240.

Family: NetSure™

System Spec. No.: 582127000

System Model: 7100

System AC Input Voltage: 582127000 List 40, 41: Nominal 208 VAC, 240 VAC, 277 VAC, single phase, 50 Hz /

60 Hz, with an operating range of 176 VAC to 305 VAC. Acceptable input

frequency range is 45 Hz to 65 Hz.

582127000 List 42: Nominal 208 VAC, 240 VAC, three-phase (3L+PE), 50 Hz / 60 Hz, with an operating range of 176 VAC to 275 VAC. Acceptable input frequency range is 45 Hz to 65 Hz.

582127000 List 43: Nominal 277/480 VAC, three-phase (3L+N+PE), 50 Hz / 60 Hz, with an operating range of 176/305 VAC to 305/528 VAC. Acceptable input frequency range is 45 Hz to 65 Hz. (For use with 588705000, 588705400, and

588705500 module mounting assemblies.)

582127000 List 100, 101, 102, 203, 500, 501, 502, 503: Nominal 208 VAC, 240 VAC, single phase,

50 Hz / 60 Hz, with an operating range of 176 VAC to 275 VAC. Acceptable input frequency range is 45 Hz to 65 Hz.

582127000 List 600, 601, 900, 901, 930, 931: Nominal 208 VAC, 240 VAC, 277 VAC, single phase, 50 Hz / 60 Hz, with an operating range of 176 VAC to 305 VAC.

Acceptable input frequency range is 45 Hz to 65 Hz.

System Output Capacity:

System: 12000 A maximum distribution and battery charge/discharge capacity, 12000 A

maximum rectifier capacity.

Bay: All List EXCEPT 100, 101, 102, 203, 500, 501, 502, 503, 600, 601, 900, 901, 930, 931:

2000 A maximum distribution and battery charge/discharge capacity, 2500 A

maximum rectifier capacity (when used with 588705400 shelves).

All List EXCEPT 100, 101, 102, 203, 500, 501, 502, 503, 600, 601, 900, 901, 930, 931: 1500 A @ -48 VDC and 520 A @ +24 VDC or 500 A @ -58 VDC, maximum (when used with 588705300).

582127000 List 100, 101, 102, 203: 1000 A @ -48 VDC and 500 A @ +24 VDC, maximum.

582127000 List 500, 501, 502, 503: 1000 A @ -48 VDC and 429 A @ -56VDC, maximum.

582127000 List 600, 601:

Maximum Output Power in Discharge Mode = 28,800 watts (600A at 48.0VDC to 496A at 58.0VDC) at 65°C operating ambient.

Maximum Output Power in Float Mode = 23040 watts (480A at 48.0VDC to 397A at 58.0VDC) at 65°C operating ambient.

Maximum Output Power in Charge Mode = 23040 watts (480A at 48.0VDC to 397A at 58.0VDC) +120A of current to charge batteries; at 65°C operating ambient.

582127000 List 900, 901:

Maximum Output Power in Discharge Mode = 43200 watts (900A at 48.0VDC to 745A at 58.0VDC) at 65°C operating ambient.

Maximum Output Power in Float Mode = 34560 watts (720A at 48.0VDC to 596A at 58.0VDC) at 65°C operating ambient.

Maximum Output Power in Charge Mode = 34560 watts (720A at 48.0VDC to 596A at 58.0VDC) +180A of current to charge batteries; at 65°C operating ambient.

582127000 List 930, 931:

-48VDC Output:

Maximum Output Power in Discharge Mode = 43200 watts (900A at 48.0VDC to 745A at 58.0VDC) at 65°C operating ambient.

Maximum Output Power in Float Mode = 34560 watts (720A at 48.0VDC to

System Application Guide

596A at 58.0VDC) at 65°C operating ambient.

Maximum Output Power in Charge Mode = 34560 watts (720A at 48.0VDC to 596A at 58.0VDC) +180A of current to charge batteries; at 65°C operating

ambient.

-58VDC Output:

600A peak, 500A average at -58VDC 65°C operating ambient.

Distribution Panel: Refer to the individual distribution panels list descriptions under "List Descriptions

(582127000)" starting on page 30.

 1R482000E3 Rectifier Rating:
 See UM1R482000E3.

 1R483500E Rectifier Rating:
 See UM1R483500E.

 1R483500E3 Rectifier Rating:
 See UM1R483500E3.

 1R484000E Rectifier Rating:
 See UM1R483500E.

 1C48241500 Converter Rating:
 See UM1C48241500.

 1C48582000P3 Converter Rating:
 See UM1C48582000P3.

 1C48583750P4 Converter Rating:
 See UM1C48583750P4.

System Agency Approval: UL 1801 Listed ("c UL"), NEBS (582127000 All Lists except List 600, 601, 900, 901,

930, 931)

UL 62368-1 (UL Subject 1801) Recognized ("c UR us"), NEBS (582127000 List 600,

601, 900, 901, 930, 931)

Relay Rack Mounted Option:

Framework Type: Relay Rack

Mounting Width: 23 Inches, nominal

Mounting Depth:

Distribution Cabinet: 20.09 Inches

Module

Mounting Assembly: 20.09 Inches
Battery Tray: 22.5 Inches
Enclosure P/N 563524 or 564881 Mounted Option:

Framework Type: Enclosure
Enclosure Width: 28 Inches
Enclosure Depth: 28 Inches
Enclosure Height: 84 Inches

Rack Mounted in an OSP Enclosure Option (582127000 List 600, 601, 900, 901, 930, 931)

Framework Type: Relay Rack

Mounting Width: 23 Inches, nominal (582127000 List 600, 601, 900, 901)

Mounting Width: 27 Inches, nominal (582127000 Lists 930, 931)

Mounting Depth: 20 Inches, nominal

Access: All Except 582127000 Lists 600, 601, 900, 901, 930, 931: Front for installation,

operation, and maintenance. Rear for supplemental bay expansion, rectifier shelf

expansion and battery tray installation.

582127000 Lists 600, 601, 900, 901, 930, 931: Front and rear for installation,

operation, and maintenance.

Supplemental Bay(s) Available: Five (5), dependent on configuration

Control: Microprocessor

Color: Enclosure: Textured Dark Gray (P/N 563524)

Distribution Cabinet, Relay Racks and Module Faceplates: Dark Gray Module Mounting Assembly and Module Bodies: Bright Zinc Plating

**Environment:** 

Relay Rack Mounted Option and Enclosure P/N 563524

## Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System

## System Application Guide

Mounted Option:  $-40 \,^{\circ}\text{C}$  to  $+40 \,^{\circ}\text{C}$  (-40  $^{\circ}\text{F}$  to  $+104 \,^{\circ}\text{F}$ )

Rack Mounted in an OSP Enclosure Option (582127000 List 600, 601,

900, 901, 930, 931): -40 °C to +65 °C (-40 °F to +149 °F)

Optional Inverter System:

AC Input Voltage: Nominal 120 VAC, single phase, 50 Hz or 60 Hz.

Operating range 96 VAC to 140 VAC.

Acceptable frequency range 47 Hz to 53 Hz or 57 Hz to 63 Hz.

DC Input Voltage: Nominal -48 VDC.

Operating range -42 VDC to -58 VDC.

AC Output Voltage: 120 VAC, 50 Hz or 60 Hz

AC Output Capacity: 582127000 List 50: 6 kVA, maximum

582127000 List 51: 6 kVA maximum (5.76 kVA per NEC breaker de-rating)

582127000 List 52: 12 kVA, maximum

582127000 List 53: 12 kVA maximum (11.5 kVA per NEC breaker de-rating)

1l1201000 Inverter Rating: See UM1l1201000

Environment:  $-40 \,^{\circ}\text{C} \text{ to } +65 \,^{\circ}\text{C} \, (-40 \,^{\circ}\text{F to } +149 \,^{\circ}\text{F})$ 

## **TABLE OF CONTENTS**

MAIN COMPONENTS ILLUSTRATIONS 582127000 (Relay Rack) 582127000 (Relay Rack) 582127000 List 50 58212700	SYSTEM OVERVIEW	1
S82127000 (Relay Rack)   15   S82127000 (List 50   17   S82127000 List 51   18   S82127000 List 52   18   S82127000 List 52   18   S82127000 List 52   18   S82127000 List 50   18   S82127000 List 50 (Relay Rack)   18   S82127000 List 100 (Relay Rack)   22   S82127000 List 500 (S8127000)   25   List 1. Main Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay For System Mounted in a Relay Rack on Shipping Ralis, or in an Enclosure   23   List 2. " "Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay For System Mounted in Relay Rack Only   23   List 2. " "Furbugh 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay For System Mounted in Relay Rack Only   23   List 2. " Through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay For System Mounted in Relay Rack on on Shippin	MAIN COMPONENTS ILLUSTRATIONS	15
S82127000 List 50   15   15   15   15   15   15   15		
S82127000 List 50. 17 582127000 List 51. 18 582127000 List 52. 18 582127000 List 101 (Relay Rack). 18 582127000 List 101 (Relay Rack). 18 582127000 List 102 (Relay Rack). 26 582127000 List 102 (Relay Rack). 26 582127000 List 102 (Relay Rack). 27 582127000 List 500 (Relay Rack). 27 582127000 List 500, 601 (rack mounted in an OSP enclosure). 27 582127000 List 500, 601 (rack mounted in an OSP enclosure). 27 582127000 List 500, 601 (rack mounted in an OSP enclosure). 27 582127000 List 500, 901 (rack mounted in an OSP enclosure). 28 582127000 List 500, 901 (rack mounted in an OSP enclosure). 28 582127000 List 500, 901 (rack mounted in an OSP enclosure). 28 582127000 List 500, 901 (rack mounted in an OSP enclosure). 30 List Numbers (582127000). 37 List Numbers (582127000). 37 List 1. Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure. 38 List 2. " Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 30 List 4. Distribution Only Bay Distribution Cabinet Bottom Rear Cover List 5. " Tri Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. Located Remote from Main Bay. Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. Common Equi		
582127000 List 50. 18 582127000 List 100 (Relay Rack). 18 582127000 List 100 (Relay Rack). 18 582127000 List 100 (Relay Rack). 20 582127000 List 100 (Relay Rack). 20 582127000 List 100 (Relay Rack). 20 582127000 List 500 (Relay Rack). 22 582127000 List 500, 801 (rack mounted in an OSP enclosure). 22 582127000 List 500, 801 (rack mounted in an OSP enclosure). 22 582127000 List 500, 801 (rack mounted in an OSP enclosure). 22 582127000 List 500, 801 (rack mounted in an OSP enclosure). 32 List Numbers (582127000). 33 List Numbers (582127000). 33 List 1: Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Ralls, or in an Enclosure . 33 List 2: "It Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. List 4: "Through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. List 4: Distribution on Main Bay. 20 List 1: "Through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover . 33 List 2: "Through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack on Shipping Ralls Only. List 8: 5: "If through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. List 8: 5: "If through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Optio		
582127000 List 103 (Relay Rack)	582127000 List 51	17
582127000 List 100 (Relay Rack). 22 582127000 List 102 (Relay Rack). 22 582127000 List 102 (Relay Rack). 22 582127000 List 500 (Relay Rack). 22 582127000 List 500 (Relay Rack). 22 582127000 List 500 (Relay Rack). 25 582127000 List 500 (Relay Rack). 26 582127000 List 500, 601 (rack mounted in an OSP enclosure). 27 582127000 List 500, 601 (rack mounted in an OSP enclosure). 27 582127000 List 900, 901 (rack mounted in an OSP enclosure). 28 582127000 List 930, 931 (rack mounted in an OSP enclosure). 26 582127000 List 930, 931 (rack mounted in an OSP enclosure). 30 List Numbers (682127000). 31 List Numbers (682127000). 33 List Numbers (682127000). 33 List Yama (1900). 34 List 2: "Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 34 List 2: "Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 34 List 4: "Is Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 34 List 4: "I Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. 35 List 5: "I through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. 35 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 36 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 36 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 36 List 3: Three-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails	582127000 List 52	18
582127000 List 107 (Relay Rack). 582127000 List 203 (Relay Rack). 582127000 List 500 (Relay Rack). 582127000 List 503 (Relay Rack). 582127000 List 500, 501 (rack mounted in an OSP enclosure). 582127000 List 600, 601 (rack mounted in an OSP enclosure). 582127000 List 600, 601 (rack mounted in an OSP enclosure). 582127000 List 930, 931 (rack mounted in an OSP enclosure). 582127000 List 930, 931 (rack mounted in an OSP enclosure). 582127000 List 930, 931 (rack mounted in an OSP enclosure). 582127000 List 930, 931 (rack mounted in an OSP enclosure). 532 List 1: Main Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 533 List 2: "* Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 534 List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover. 535 List 5: "† Through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay, Located In-Line with Main Bay, Enc System Mounted in a Relay Rack Only. 536 List 2: "To Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enc System Mounted in a Relay Rack Only. 536 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 537 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 538 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails, or in an Enclosure. 549 List 3: Module Mounting Assembly Interface Components (for Spec. No. 588705400). 540 List	582127000 List 53	18
582127000 List 500 (Relay Rack). 582127000 List 500 (Relay Rack). 582127000 List 500 (Relay Rack). 582127000 List 501 (Relay Rack). 582127000 List 501 (Relay Rack). 582127000 List 502 (Relay Rack). 582127000 List 502 (Relay Rack). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 582127000 List 500, 601 (rack mounted in an OSP enclosure). 301 List 1. Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure. 302 List 2. 1* Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 303 List 5. 1* In through 5* Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 303 List 5. 1* In through 5* Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. 304 List 4: 1* Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. 304 List 2: 1* One-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 305 List 2: 1* Three-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 306 List 2: 1* Three-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only. 307 List 3: Module Mounting Assembly Interface Components (for Spec. No. 5887053000), For System Mounted in a Relay Rack or on Shipping Rails Only. 308 List 3: Three-Row Distribution Cabinet,	582127000 List 100 (Relay Rack)	19
582127000 List 500 (Relay Rack)		
582127000 List 500 (Relay Rack). 22 582127000 List 501 (Relay Rack). 22 582127000 List 503 (Relay Rack). 25 582127000 List 503 (Relay Rack). 27 582127000 List 503 (Relay Rack). 27 582127000 List 503 (Relay Rack). 27 582127000 List 500, 601 (rack mounted in an OSP enclosure). 27 582127000 List 930, 931 (rack mounted in an OSP enclosure). 28 582127000 List 930, 931 (rack mounted in an OSP enclosure). 29 582127000 List 930, 931 (rack mounted in an OSP enclosure). 29 582127000 List 930, 931 (rack mounted in an OSP enclosure). 30 List Numbers (582127000). 33 List 1: Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure. 31 List 2: "Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 33 List 3: "If through 5" Supplemental Bays Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only. 34 List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover. 35 List 5: "If through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. 34 List 7: "Supplemental Bay Common Equipment (Power and Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. 35 List 7: "Supplemental Bay Common Equipment (Power and Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only. 35 List 7: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only 35 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only 36 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only 36 List 32: Trop Shield for Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only 36 List 32: Trop Shield for Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping R		
582127000 List 502 (Relay Rack)		
582127000 List 502 (Relay Rack)		
582127000 List 503 (Relay Rack) 582127000 (Enclosure)		
582127000 (Enclosure)		
582127000 List 900, 901 (rack mounted in an OSP enclosure)	,	
582127000 List 900, 901 (rack mounted in an OSP enclosure)		
LIST DESCRIPTIONS (582127000)		
List Numbers (582127000)		
List Numbers (582127000).  List 1: Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  Jist 2: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located Remote from Main Bay  List 5: 1st through 5st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located Remote from Main Bay.  List 7: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located Remote from Main Bay.  List 8: 2st Intrough 5st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located In-Line with Main Bay, Enclosure Mounted Option Only.  List 8: 2st Intrough 5st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located In-Line with Main Bay, Enclosure Mounted Option Only.  38  List 21: One-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only.  39  List 22: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails Only.  30  List 23: Three-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  40  List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  41  List 32: Module Mounting Assembly Interface Components (for Spec. No. 5887053000), For System Mounted in a Relay Rack or on Shipping Rails Only.  42  List 36: Module Mounting Assembly Field Expansion Kit (for Spec. No. 5887053000), For System Mounted in a Relay Rack or on Shipping Rails Only.  44  List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  45  List 49: Front Access AC I	58212/000 List 930, 931 (rack mounted in an OSP enclosure)	30
List Numbers (582127000).  List 1: Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  Jist 2: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  Located Remote from Main Bay  List 5: 1st through 5st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located Remote from Main Bay.  List 7: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located Remote from Main Bay.  List 8: 2st Intrough 5st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located In-Line with Main Bay, Enclosure Mounted Option Only.  Located In-Line with Main Bay, Enclosure Mounted Option Only.  Located In-Line with Main Bay, Enclosure Mounted Option Only.  38  List 2: One-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only.  39  List 22: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails Only.  30  List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  40  List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  41  List 32: Module Mounting Assembly Interface Components (for Spec. No. 5887053000), For System Mounted in a Relay Rack or on Shipping Rails Only.  42  List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  43  List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  44  List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  45  List 49: Front Access AC Input Termination Assemb	LIST DESCRIPTIONS (582127000)	31
Rails, or in an Enclosure List 2: 1" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  33 List 3: 2"d through 5" Supplemental Bays Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  34 List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover.  35 List 5: 1" through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. List 7: "I" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay. List 8: 2" through 5" Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only.  35 List 2: "I supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only.  36 List 2: "One Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only.  37 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only.  38 List 2: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  40 List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack Only.  41 List 32: Module Mounting Assembly Field Expansion Kit (for Spec. No. 5887053000), For System Mounted in a Relay Rack or on Shipping Rails Only.  42 List 33: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  44 List 36: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  45 List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  46 List 40: Front Access AC Input Termination Assembly (1 AC Feed per 1 Rectifiers, Single Phase).  47 List 40: Front Access AC Input Termination Assembly (1 AC Feed per 2 Rectifiers, 3-Phase).  48 List		
List 2: 1 <sup>st</sup> Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only	List 1: Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping	
with Main Bay, For System Mounted in a Relay Rack Only.  List 3: 2 <sup>nd</sup> through 5 <sup>th</sup> Supplemental Bays Common Equipment (Power and Distribution or Distribution Only),  Located In-Line with Main Bay, For System Mounted in a Relay Rack Only.  34  List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover.  35  List 5: 1 <sup>th</sup> through 5 <sup>th</sup> Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located Remote from Main Bay.  List 7: 1 <sup>th</sup> Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located In-Line with Main Bay, Enclosure Mounted Option Only.  List 8: 2 <sup>nd</sup> through 5 <sup>th</sup> Supplemental Bay Common Equipment (Power and Distribution or Distribution Only),  Located In-Line with Main Bay, Enclosure Mounted Option Only.  35  List 21: One-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only.  36  List 22: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only.  37  List 22: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  40  List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  40  List 29: Top Shield for Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure.  41  List 32: Module Mounting Assembly Interface Components (for Spec. No. 5887053000), For System Mounted in a Relay Rack or on Shipping Rails Only.  42  List 33: Module Mounting Assembly Field Expansion Kit (for Spec. No. 58870530003), For System Mounted in a Relay Rack or on Shipping Rails Only.  43  List 36: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  44  List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  45  List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400).  46  List 40: Front Access AC Input Termination Assembly (1 AC Feed per 1 Rectifiers, Single Phase).  47  List 43: Fron	Rails, or in an Enclosure	31
List 3: 2nd through 5th Supplemental Bays Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only	List 2: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line	
Located In-Line with Main Bay, For System Mounted in a Relay Rack Only	with Main Bay, For System Mounted in a Relay Rack Only	33
List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover		
List 5: 1st through 5th Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay	Located In-Line with Main Bay, For System Mounted in a Relay Rack OnlyOnly	34
Located Remote from Main Bay List 7: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only		35
List 7: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only		
with Main Bay, Enclosure Mounted Option Only		35
List 8: 2nd through 5th Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only		
Located In-Line with Main Bay, Enclosure Mounted Option Only		37
List 21: One-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only		0.0
List 22: Two-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only	Located In-Line with Main Bay, Enclosure Mounted Option Univ	36
List 23: Three-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure		
Enclosure		38
List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure		<i>/</i> .c
List 29: Top Shield for Distribution Cabinet, For System Mounted in a Relay Rack Only		
List 32: Module Mounting Assembly Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack or on Shipping Rails Only		
Relay Rack or on Shipping Rails Only		
List 33: Module Mounting Assembly Field Expansion Kit (for Spec. No. 58870530003), For System Mounted in a Relay Rack or on Shipping Rails Only		4
Relay Rack or on Shipping Rails Only	List 33: Module Mounting Assembly Field Expansion Kit (for Spec. No. 58870530003). For System Mounted in a	······
List 36: Module Mounting Assembly Interface Components (for Spec. No. 588705400)		42
List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400)		
List 37A: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400), For System Originally Configured with 588705000 or 588705500 Shelves		
Configured with 588705000 or 588705500 Shelves		
List 40: Front Access AC Input Termination Assembly (1 AC Feed per 1 Rectifier, Single Phase)		43
List 41: Front Access AC Input Termination Assembly (1 AC Feed per 2 Rectifiers, Single Phase)		
List 42: Front Access AC Input Termination Assembly (1 AC Feed per 3 Rectifiers, 3-Phase)		
List 43: Front Access AC Input Termination Assembly (1 AC Feed per 3 Rectifiers, 3-Phase)		
List 50: Inverter System, 23", up to 6kVA maximum, Bulk Output		
List 51: Inverter System, 23", up to 6kVA maximum (5.76kVA per NEC breaker de-rating), NEMA Outlet Output46 List 52: Inverter System, 23", up to 12kVA maximum, Bulk Output47	List 50: Inverter System, 23", up to 6kVA maximum, Bulk Output	46
List 52: Inverter System, 23", up to 12kVA maximum, Bulk Output47	List 51: Inverter System, 23", up to 6kVA maximum (5.76kVA per NEC breaker de-rating), NEMA Outlet Output	46
List 53: Inverter System, 23", up to 12kVA maximum (11.5kVA per NEC breaker de-rating), NEMA Outlet Output47	List 52: Inverter System, 23", up to 12kVA maximum, Bulk Output	47
	List 53: Inverter System, 23", up to 12kVA maximum (11.5kVA per NEC breaker de-rating), NEMA Outlet Output	47

# Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System

List 60: +24V Converter Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack	
or on Shipping Rails Only	48
List 62: -58V Converter Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack	
or on Shipping Rails Only	
List 90: Optional Battery Shunt, 800 A	
List 91: Optional Battery Shunt, 2000 A	
List 92: Optional Battery Shunt, 2500 A	49
List 93: Optional Battery Tray, Pre-Cabled, For System Mounted in a Relay Rack Only, 22.5" Deep	50
List 95: Optional Battery Tray, Pre-Cabled, For System Mounted in a Relay Rack Only, 24.79" Deep	
Batteries	
Optional Battery Tray Battery Disconnect Circuit Breaker and Housing KitsKitsKits	
Optional Battery Tray Front Battery Cover Kits	
Optional Battery Tray Anderson Battery Connector Kit	
List 100: Power and Distribution Bay (Fully Configured)	
List 101: Power and Distribution Bay (Fully Configured with One Battery Tray)	
List 102: Power and Distribution Bay (Fully Configured with Two Battery Trays)	
List 203: Power and Distribution Bay (Fully Configured with Three Battery Trays)	
List 500: Power and Distribution Bay (Fully Configured)	
List 501: Power and Distribution Bay (Fully Configured with One Battery Tray)	
List 502: Power and Distribution Bay (Fully Configured with Two Battery Trays)	
List 503: Power and Distribution Bay (Fully Configured with Two Battery Trays)	
List 600, 601: Power and Distribution Bay (Fully Configured)	
List 900, 901: Power and Distribution Bay (Fully Configured)	
List 930, 931: Power and Distribution Bay, Dual Voltage	
Single Voltage Distribution Panels	6
List AC: -48 VDC Distribution Panel (with Return Busbar) and List AD: -48 VDC Distribution Panel (without	
Return Busbar), (4) GJ/218 Circuit Breaker Positions	
List AF: -48 VDC Distribution Panel, (2) TPH Fuse Positions (with Shunts) (without Return Busbar)	
List AH: -48 VDC Distribution Panel, (4) TPH Fuse Positions (with Shunts) (without Return Busbar)	69
List AL: -48 VDC Distribution Panel (with Return Busbar) and List AN: -48 V Distribution Panel (without Return	
Busbar) (26) Bullet/TPS/TLS Circuit Breaker/Fuse Positions	70
List AM: -48 VDC Distribution Panel (with Return Busbar) and List AP: -48 VDC Distribution Panel (without	
Return Busbar) (12) GJ/218 Circuit Breaker Positions	
Dual Voltage Distribution Panels	72
List DE: -48 VDC / +24 VDC Distribution Panel, (22) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions	
(with Return Busbar) and (4) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	72
List DF: -48 VDC / +24 VDC Distribution Panel, (18) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions	
(with Return Busbar) and (8) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	73
List DG: -48 VDC / +24 VDC Distribution Panel, (14) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions	
(with Return Busbar) and (12) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	74
List DH: -48 VDC / +24 VDC Distribution Panel, (10) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions	
(with Return Busbar) and (16) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	75
List DJ: -48 VDC / +24 VDC Distribution Panel, (6) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	
Return Busbar) and (20) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	76
List DK: -48 VDC / +24 VDC Distribution Panel, (26) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions	
(with Return Busbar)	7
List FE: -48 VDC / -58 VDC Distribution Panel, (22) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	
Return Busbar) and (4) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	79
List FF: -48 VDC / -58 VDC Distribution Panel, (18) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	
Return Busbar) and (8) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	70
	/ 3
List FG: -48 VDC / -58 VDC Distribution Panel, (14) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	0.0
Return Busbar) and (12) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	ठ(
List FH: -48 VDC / -58 VDC Distribution Panel, (10) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	_
Return Busbar) and (16) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	8
List FJ: -48 VDC / -58 VDC Distribution Panel, (6) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	
Return Busbar) and (20) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)	82
List FK: -48 VDC / -58 VDC Distribution Panel, (26) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with	
Return Busbar)	
Battery Disconnect Distribution Panels	84

# Vertiv $^{\text{\tiny ™}}$ NetSure $^{\text{\tiny ™}}$ 7100 DC Power System

List BC: Battery Disconnect Distribution Panel (with Return Busbar) and List BD: Battery Disconnect Distribution	
Panel (without Return Busbar), (4) GJ/218 Circuit Breaker Battery Disconnect Positions	84
List BF: Battery Disconnect Distribution Panel, (2) TPH Fuse Battery Disconnect Positions (with Shunts) (without	
Return Busbar)	85
List BH: Battery Disconnect Distribution Panel, (4) TPH Fuse Battery Disconnect Positions (with Shunts)	0.0
(without Return Busbar)	
Return Bar Panel	
List GA: Return Bar Panel	
Bulk Output Panel	
List EA: Bulk Output Panel	
Battery Disconnect Contactors	
List CA: 600 A Battery Disconnect ContactorList CB: 1200 A Battery Disconnect Contactor	
List CC: 2000 A Battery Disconnect Contactor	
Low Voltage Disconnect Options	
List LB: Low Voltage Battery Disconnect (LVBD)	
List LL: Low Voltage Load Disconnect (LVLD)	
Manual Battery Disconnect Option	
List MB: Manual Battery Disconnect	
ACCESSORY DESCRIPTIONS	
Controller	
NCU Controller, P/N 1M830DNA or 1M830BNA	
NCU Controller 2nd Ethernet Port Kits	
NCU Controller 2nd Ethernet Port Add-On Kit, P/N 559252	
NCU Controller 2nd Ethernet Port Retrofit Kit, P/N 559251	
Optional Second IB2 (Controller Interface Board), P/N 555286 or MA4C5U31	
Optional EIB-1 and EIB-2 (Controller Extended Interface Board) (P/N 548120, MA455U41, and SXK2300238/1)	
Optional SM-DU+ Shunt Monitoring, P/N 548078	
In-Line Fuse and Resistor Pigtail Kits	
1 A In-Line Fuse Pigtail Kit, P/N 431300200	
1 A In-Line Fuse Pigtail Kit, P/N 431300300	
1 A In-Line Fuse Pigtail Kit, P/N 535135	
49.9 Ohm In-Line Resistor Pigtail Kit, P/N 424228000	
49.9 Ohm In-Line Resistor Pigtail Kit, P/N 424228100	
Optional Temperature Probes	
Optional SM-Temp Temperature Concentrator, P/N 547490	
SM-Temp Jumpers, P/N 552888	
Rectifiers	
Rectifier Module, P/N 1R483500E3	
Rectifier Module, P/N 1R482000E3	
Rectifier Module, P/N 1R483600E4	
Rectifier Module, P/N 1R483500E	
Rectifier Module, P/N 1R484000E	
Converters	
-48 VDC to +24 VDC Converter Module, P/N 1C48241500	
-48 VDC to -58 VDC Converter Module, P/N 1C48582000P3	
-48 VDC to -58 VDC Converter Module, P/N 1C48583750P4 (Lists 930 or 931)	
Inverters	
Inverter Module, P/N 111201000	
Module Mounting Position Blank Cover Panels	
Module Mounting Position Blank Cover Panel, P/N 21140440	
Module Mounting Position Blank Cover Panel, P/N SXA1100035/1	110
Optional +27 VDC Vertiv™ eSure™ Bullet Converter Kit, P/N 60147273	
Optional eSure™ Power Extend Converter	
Module Mounting Assembly	112
588705300 List 01: Module Mounting Assembly Configured with Rectifier and -48 VDC to +24 VDC or -48 VDC to	
-58 VDC Converter Module Mounting Positions, 208 VAC, 240 VAC Input, No Rear Covers, and Factory Input	
Wiring Only	112

## Vertiv $^{\mathsf{\tiny{M}}}$ NetSure $^{\mathsf{\tiny{M}}}$ 7100 DC Power System

588/05300 List 03: Module Mounting Assembly Configured with Rectifier and -48 VDC to +24 VDC or -48 VDC to	
-58 VDC Converter Module Mounting Positions, 208 VAC, 240 VAC Input, Single Phase, Rear Covers, and Rear	
Mount Molex Input Connectors	
588705300 List 61: Converter Module Mounting Assembly for Six (6) -48 VDC to -58 VDC Converter Positions	113
588705400 List 01: Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No Rear Covers,	
and Factory Input Wiring Only	114
588705400 List 02: Rectifier Module Mounting Assembly, 208 VAC, 240 VAC, 277 VAC Input, Single-Phase, Rear	44.
Covers, and Rear Mount Molex Input Connectors	114
588705400 List 03: Rectifier Module Mounting Assembly, 208 VAC, 240 VAC Input, Three-Phase, Rear Covers,	445
and Rear Mount Molex Input Connectors	115
588705400 List 04: Rectifier Module Mounting Assembly, 277/480 VAC Input, Three-Phase, Rear Covers, and	115
Rear Mount Molex Input Connectors	115
588705400 List 05: Controller/Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No	110
Rear Covers, and Factory Input Wiring Only588705400 List 11: Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No Rear Covers,	116
Factory Input Wiring Only, Solar Compatible	110
588705400 List 12: Rectifier Module Mounting Assembly, 208 VAC, 240 VAC, 277 VAC Input, Single-Phase, Rear	110
Covers, Rear Mount Molex Input Connectors, Solar Compatible	117
588705400 List 13: Rectifier Module Mounting Assembly, 208 VAC, 240 VAC Input, Three-Phase, Rear Covers,	117
Rear Mount Molex Input Connectors, Solar Compatible	117
588705400 List 14: Rectifier Module Mounting Assembly, 277/480 VAC Input, Three-Phase, Rear Covers, Rear	117
Mount Molex Input Connectors, Solar Compatible	110
588705400 List 15: Controller/Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No	110
Rear Covers, Factory Input Wiring Only, Solar Compatible	110
588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies	
Rectifier AC Input Cable Assembly, P/N 535232	
Rectifier AC Input Cable Assembly, P/N 547898	
Rectifier AC Input Cable Assembly, P/N 553202	
588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords	
Rectifier AC Input Line Cord, P/N 540946	
Rectifier AC Input Line Cord, P/N 545616	
Rectifier AC Input Line Cord, P/N 545252	
Rectifier AC Input Line Cord, P/N 562046	
Rectifier AC Input Line Cord, P/N 562045	
Converter Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack Only	
Relay Racks and Shipping Brackets	
Transition Plates to Mount Relay Rack on Top of GNB Absolyte IIP Batteries	124
Relay Rack Isolation Kit	
Replacement Rear Panel Cover	
Enclosure and Enclosure Options	
Crimp Lugs	
Standard Crimp Lug Tables	
Special Application Crimp Lug / Strap Combination Table	
Lug Adapters	
Busbar for 125 A, 150 A, and 200 A Bullet Nose Type Circuit Breaker, P/N 60016097	
Busbar for 125 A, 150 A, and 200 A Bullet Nose Type Circuit Breaker, P/N 522786 (all Lists except 600, 601, 900,	
901, 930, 931)	128
Lug Adapter Busbar Kit for 125 A, 150 A, and 200 A Bullet Nose Type Circuit Breaker, P/N 534449 (all Lists except	
600, 601, 900, 901, 930, 931)	128
Busbar for 225 A through 300 A Bullet Nose Type Circuit Breaker, P/N 545346DCP	
Lug Adapter Busbar Kit for 225 A through 300 A Bullet Nose Type Circuit Breaker, P/N 514714 (all Lists except	
600, 601, 900, 901, 930, 931	129
Lug Adapter Busbar Kit for 3-Pole GJ/218 Circuit Breaker Installed in a List AM and List AP Distribution Panel,	
P/N 562888	129
Lug Adapter Busbar Kit for 4-Pole, P/N 60159564 (used in Lists 600, 601, 900, 901, 930, 931)	129
Lug Adapters (Lists 600, 601, 900, 901, 930, 931)	130
Lug Hardware Kits	
1/4-20 Hardware Kit, P/N 541084	130
3/8-16 Hardware Kit, P/N 548184	
3/8-16 Hardware Kit, P/N 548185	130

## Vertiv $^{\text{\tiny ™}}$ NetSure $^{\text{\tiny ™}}$ 7100 DC Power System

Ba	ttery Busbar Extension Kit (P/N 562364)	13
	ttery Busbar Extension Kit (P/N 554541)	
Ba	ttery Landing Busbar Kit (P/N 553584), For System Mounted in a Relay Rack Only	13′
	ttery Landing Busbar Kit (P/N 555478), For System Mounted in a Relay Rack OnlyOnly	
Dis	stribution Devices	
	Bullet Nose Type Circuit Breakers and Bullet Nose Type Fuseholders e/w TPS/TLS Fuses	
	Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block, P/N 549017, (6) GMT Fuse Positions	
	Optional +27 VDC Bullet Nose 6-Position GMT Fuse Board Kit, P/N 10062803	
	Optional 6-Position 30A GMT Fuse Board Kit, P/N 60160806	
	Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block, P/N 60191012, (6) GMT Fuse Positions	
	GMT Type Load Distribution Fuses	
	GJ/218 Type Circuit Breakers	
l lo	TPH Type Fuseser Replaceable Alarm, Reference, and Control Fuses	
	er Replaceable Componentser Replaceable Components	
	placement Bay-to-Bay Interconnect Cable	
	ecial Application Rectifier Bus Landing Point Kit P/N 563686	
-	Generator Input Circuit Breaker Kit	
	P/N 564219	
	P/N 60141027	
DC	Cenerator Input Landing Kit P/N 10067484	147
DC	Generator Input Landing Kit P/N 60177224	148
DECOI	MMENDED WIRE SIZES, BRANCH CIRCUIT PROTECTION, CRIMP LUGS, AND WIRING ILLUSTRATIONS	1/.0
	lay Rack and Equipment Enclosure Frame Grounding Requirements	
	st 600, 601, 900, 901 Power System Shelf Frame Grounding Requirements	
	D (Surge Protection Device) (if equipped) Earth Ground Connection	
	eld Installed Module Mounting Assembly Shelf Frame Grounding Connection	
	Spec. No. 588705300 and 588705400	
Re	ctifier AC Input Connections	
	AC Input Branch Circuit Protection and Wire Size Selection for AC Input Termination Assembly List 40, 41, 42	
	when used with 588705300 Module Mounting Assemblies with Rectifiers	152
	AC Input Branch Circuit Protection and Wire Size Selection for AC Input Termination Assembly List 40, 41, 42, 43	
	when used with 588705400 Module Mounting Assemblies with Rectifiers	155
	AC Input Connections to AC Input Termination Assembly List 40 Illustration when Used with 588705300	
	(Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting	
	Assemblies with Rectifiers (1 Feed per 1 Rectifier, Single Phase)	159
	AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal	
	208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with	100
	Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Five (5) Shelves Installed	100
	208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with	
	Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Four (4) Shelves Installed	161
	AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal	10
	208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with	
	Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Three (3) Shelves Installed	162
	AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal	
	208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with	
	Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Two (2) Shelves Installed	163
	AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal	
	208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with	
	Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with One (1) Shelf Installed	164
	AC Input Connections to AC Input Termination Assembly List 42 Illustration when used with 588705300 or	
	588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC) (1 Feed per 3 Rectifiers,	40-
	Three Phase)	165
	AC Input Connections to AC Input Termination Assembly List 43 Illustration when used with 588705400 Module	100
	Mounting Assemblies with Rectifiers (Nominal 277/480 VAC) (1 Feed per 3 Rectifiers, Three Phase)AC Input Connections to AC Input Termination Assembly List 40 Illustration when used with 588705400 Module	100
	Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 1 Rectifier, Single Phase)	167
	mountaing / 1000 months with Noctifiers (Nothinial 200 V/10, 240 V/10, 277 V/10) (11 eeu pei 1 Nectifier, Single Filase)	107

## Vertiv $^{\mathsf{\tiny{M}}}$ NetSure $^{\mathsf{\tiny{M}}}$ 7100 DC Power System

AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Six (6) Shelves Installed	169
AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Five (5) Shelves Installed	
AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Four (4) Shelves Installed	
AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single	170
Phase) - with Three (3) Shelves Installed	171
AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single	170
Phase) - with Two (2) Shelves Installed	
Phase) - with One (1) Shelf Installed	
AC Input Connections to AC Input Termination Assembly List 43 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 277/480 VAC) (1 Feed per 3 Rectifiers, Three Phase)	
AC Input Branch Circuit Protection and Wire Size Selection (List 100, 101, 102, 203, 500, 501, 502, 503) (Nominal 208 VAC, 240 VAC)	
AC Input Connections to AC Input Termination Assembly in List 100, 101, 102, 203, 500, 501, 502, 503 Illustration (Nominal 208 VAC, 240 VAC)	
AC Input Branch Circuit Protection and Wire Size Selection (List 600, 601, 900, 901) (Nominal 208 VAC, 240 VAC, 277 VAC)	178
AC Input Connections to AC Input Termination Assembly in List 600, 601, 900, 901 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd on next page)	180
AC Input Connections to AC Input Termination Assembly in List 600, 601, 900, 901 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd from previous page)	181
AC Input Branch Circuit Protection and Wire Size Selection (List 930, 931) (Nominal 208 VAC, 240 VAC, 277 VAC).  AC Input Connections to AC Input Termination Assembly in List 930, 931 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd on next page)	
AC Input Connections to AC Input Termination Assembly in List 930, 931 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd from previous page)	
AC Input Connections to Field Installed Module Mounting Assemblies	
Spec. No. 588705300 List 03 (120 VAC / 208 VAC / 240 VAC Input, Single Phase)	
Spec. No. 588705400 List 02 (208 VAC, 240 VAC, 277 VAC Single Phase, 50 Hz / 60 Hz)	
Spec. No. 588705400 List 03 (208 VAC, 240 VAC Input, Three Phase, 50 Hz / 60 Hz)	
Spec. No. 588705400 List 04 (277/480 VAC Three Phase Input, 50 Hz / 60 Hz)	192
Optional Inverter System AC Input Connections (List 50, 51, 52, 53)	194
Inverter System AC Input Connections	194
Optional Inverter System AC Output Connections (List 50, 51, 52, 53)	
Inverter System AC Output Connections (List 50, 52)	
Inverter System AC Output Connections (List 51, 53)	199
External Alarm, Reference, Monitoring (All Lists except List 100, 101, 102, 203, 500, 501, 502, 503, 600, 601, 900, 901,	
930, 931)	
External Alarm, Reference, Monitoring, and Control Wire Sizes	
External Alarm, Reference, Monitoring, and Control Illustrations	
External Alarm, Reference, Monitoring (List 100, 101, 102, 203, 500, 501, 502, 503)	
External Alarm, Reference, Monitoring, and Control Wire Sizes	
External Alarm, Reference, Monitoring, and Control Illustrations	
External Alarm, Reference, Monitoring (List 600, 601, 900, 901)	
External Alarm, Reference, Monitoring, and Control Wire Sizes	
External Alarm, Reference, Monitoring, and Control Illustrations	
External Alarm, Reference, Monitoring (List 930, 931)	
External Alarm, Reference, Monitoring, and Control Wire SizesExternal Alarm, Reference, Monitoring, and Control Illustrations	
LALGINGI AIGINI, REICICHCE, MUNICUNINY, GIN CONCION MUSCIGNOS	∠ IC


# Vertiv $^{\text{\tiny ™}}$ NetSure $^{\text{\tiny ™}}$ 7100 DC Power System


Lo	oad Distribution	
	Load Distribution Wire Sizes and Lugs Selection	
	Load Distribution (Distribution Panels) Illustrations	
	Load Distribution Wiring (Optional Bullet Nose 6-Position 35 A GMT Fuse Block) Illustration	
	Load Distribution Wiring (Optional Bullet Nose 6-Position 30 A GMT Fuse Block) Illustration (List 930, 931 Only)	
В	attery Input	
	Battery Input Wire Sizes and Lugs Selection	
	Battery Input Illustrations	228
	/ire Size and Lug Selection Tables for Load and Battery Connections to TPS/TLS Fuses and Bullet Nose Type	000
	ircuit Breakers	236
	reakers or Battery Branch Circuitsericuits	220
	DIFICATIONS	
1.	System	
	1.1 Output Ratings	
	1.2 Input Ratings	
	1.3 Environmental Ratings	
	1.4 Compliance Information	
0	1.5 IB2 and EIB (Controller Interface Board) Ratings	
۷.	588705300 Module Mounting Assembly	
	2.1 Input and Output Ratings	
	2.3 Compliance Information	
2	. 588705400 Module Mounting Assembly	
٥.	3.1 Output Ratings	
	3.2 Input Ratings	
	3.3 Environmental Ratings	
	3.4 Compliance Information	
4.	Optional Inverter System	
	4.1 AC Input and DC Input Ratings	
	4.2 AC Output Ratings	
5.	. Rectifier	
6.	48 VDC to +24 VDC Converter	244
7.	-48 VDC to -58 VDC Converter	244
	. Inverter	
9.	. Controller	244
MECH	HANICAL SPECIFICATIONS	245
	verall Dimensions	
	Relay Racks	
	Enclosure, P/N 563524	
	List 21 (One-Row Distribution Cabinet)	
	List 22 (Two-Row Distribution Cabinet)	
	List 23 (Three-Row Distribution Cabinet)	247
	List 24 (Four-Row Distribution Cabinet)	247
	58212700050	248
	58212700051	248
	58212700052	
	58212700053	
	582127000100, 582127000500	
	582127000101, 582127000501	
	582127000102, 582127000502	
	582127000203, 582127000503	
	582127000600, 582127000601	
	582127000900, 582127000901	
	582127000930, 582127000931	
	List 93 (Battery Tray)List 95 (Battery Tray)	
	588705300 Module Mounting Assembly (List 01)	
	588705300 Module Mounting Assembly (List 01)	
	000700000 Module Modulting Assembly (List 007	200

## Vertiv $^{\text{\tiny ™}}$ NetSure $^{\text{\tiny ™}}$ 7100 DC Power System


588705300 Module Mounting Assembly (List 61)	
588705400 Module Mounting Assembly (List 01, 11, 15)588705400 Module Mounting Assembly (List 02, 03, 04, 12, 13, 14)	
Weights	
RELATED DOCUMENTATION	268
BATTERY MANUFACTURER INFORMATION	268

# MAIN COMPONENTS ILLUSTRATIONS 582127000 (Relay Rack)







## 582127000 List 50



## 582127000 List 51





## 582127000 List 52



Rear View

## 582127000 List 53





Rear View

582127000 List 100 (Relay Rack)


## Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). The SPD assemblies are mounted to the underside of the distribution cabinet top cover. **BATTERY DISCONNECT CONTACTOR DISTRIBUTION CABINET** (3-Row) **DISTRIBUTION PANELS** 582127000 List DJ FRONT ACCESS 582127000 List AL **AC TERMINATION ASSEMBLY** 582127000 List AL 1 AC Feed per 2 Rectifiers, Single Phase (both sides) **NCU Controller** 1M830DNA Module Mounting Assemblies: 58870530021 58870530001 58870530001 58870530001 Rectifier Module: 1R482000E3 **Other Features** Battery Shunt: 1500 A, 25 mV Optional DC-DC Manual Battery Disconnect Converter Module: System Interface Board 1C48241500 IB4 Board (second Ethernet port) **IB2 Board EIB Board** 10009902 Relay Rack

SPD (Surge Protection Device)

### 582127000 List 101 (Relay Rack)

SPD (Surge Protection Device)

Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). The SPD assemblies are mounted to the underside of the distribution cabinet top cover.




#### **Other Features**

Battery Shunt: 1500 A, 25 mV Manual Battery Disconnect System Interface Board IB4 Board (second Ethernet port) IB2 Board EIB Board

### 582127000 List 102 (Relay Rack)

SPD (Surge Protection Device)

Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). The SPD assemblies are mounted to the underside of the distribution cabinet top cover.




Battery Shunt: 1500 A, 25 mV Manual Battery Disconnect System Interface Board IB4 Board (second Ethernet port)


IB2 Board EIB Board

## 582127000 List 203 (Relay Rack) SPD (Surge Protection Device) Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). The SPD assemblies are mounted to the underside of the distribution cabinet top cover. **BATTERY DISCONNECT CONTACTOR DISTRIBUTION CABINET** (3-Row) **DISTRIBUTION PANELS** 582127000 List DJ FRONT ACCESS 582127000 List AL **AC TERMINATION ASSEMBLY** 582127000 List AL 1 AC Feed per 2 Rectifiers, Single Phase (both sides) **NCU Controller** 1M830DNA Module Mounting Assemblies: 58870530021 58870530001 58870530001 **Other Features** 58870530001 Battery Shunt: 1500 A, 25 mV Manual Battery Disconnect System Interface Board Rectifier Module: IB4 Board (second Ethernet port) 1R482000E3 **IB2 Board EIB Board** Optional DC-DC Converter Module: 1C48241500 **Battery Trays** (with 200 A Circuit Breakers) 10009902 Relay Rack

### 582127000 List 500 (Relay Rack)




### 582127000 List 501 (Relay Rack)



#### Other Features


Battery Shunt: 1500 A, 25 mV Manual Battery Disconnect System Interface Board IB4 Board (second Ethernet port) IB2 Board


### 582127000 List 502 (Relay Rack)




Battery Shunt: 1500 A, 25 mV Manual Battery Disconnect System Interface Board IB4 Board (second Ethernet port) IB2 Board

### 582127000 List 503 (Relay Rack)







## 582127000 List 600, 601 (rack mounted in an OSP enclosure)




## 582127000 List 900, 901 (rack mounted in an OSP enclosure)



### **582127000 List 930, 931 (rack mounted in an OSP enclosure)**





### LIST DESCRIPTIONS (582127000)

#### List Numbers (582127000)

List 1: Main Bay Common Equipment (Power and Distribution), For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure

#### **Features**

- Provides common equipment for one "power and distribution" bay rated for up to 2000 amperes of distribution. System components factory mounted in a relay rack, on shipping rails, or in an enclosure as specified when ordered.
- ♦ Accepts one (1) distribution cabinet (options are 1-row, 2-row, 3-row, or 4-row cabinet). 1-row and 2-row distribution cabinets are only available in the relay rack or shipping rails option.
- ♦ Accepts one (1) controller.
- Includes the IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).
- ◆ Accepts a second optional IB2 controller interface board. See Restrictions. See page 101.
- Accepts the optional EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two
   (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs). See page 102.
- ♦ Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.
- Accepts up to six (6) module mounting assemblies Spec. No. 588705400 (including expansion assemblies).
  - Accepts up to six (6) module mounting assemblies Spec. No. 588705300 (including expansion assemblies). Relay rack or shipping rails option only.

#### Restrictions

System components factory mounted in a relay rack, on shipping rails, or in an enclosure as specified when ordered.

Cannot put a system installed in an enclosure next to a system installed in a relay rack.

When the system is equipped with a List 40, 41, 42, or 43 front access input termination assembly, refer to the restrictions under these list descriptions.

The system can contain a maximum of three (3) Interface Boards, (1) IB2 and (2) EIB or (2) IB2 and (1) EIB.

Cannot include List 93 and List 95 battery tray option if it is to be used in conjunction with a List 2 adjacent supplemental bay.

#### **Ordering Notes**

- Order a relay rack or shipping brackets per "Relay Racks and Shipping Brackets" on page 123 if desired. If required, order relay rack transition plates per "Transition Plates to Mount Relay Rack on Top of GNB Absolyte IIP Batteries" on page 124. A relay rack, shipping rails, or enclosure must be specified when ordered. If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.
- 2) Order an enclosure per "Enclosure and Enclosure Options" on page 125 if desired. A relay rack, shipping rails, or enclosure must be specified when ordered.
- 3) Order one (1) List 21, 22, 23, or 24 distribution cabinet. List 21 and List 22 distribution cabinets are only available in the relay rack or shipping rails option.
  - a) Order up to four (4) (per the capacity of the distribution cabinet ordered) distribution panels, battery disconnect panels, return bar panel, and/or bulk output panel as required per "Single Voltage Distribution Panel", "Dual Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54. Dual voltage panels are not available in the enclosure option.
  - b) Order battery disconnect contactors and low voltage disconnect options as required per "<u>Battery Disconnect Contactors</u>" and "<u>Low Voltage Disconnect Options</u>" starting on page 89.
  - c) Order one (1) NCU controller (P/N 1M830DNA) with the desired configuration.
  - d) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
  - e) Order the optional EIB controller extended interface board as required (see page 102).
  - f) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
  - g) Order optional <u>temperature probes</u> for ambient and battery temperature monitoring, as required. The temperature probe(s) may also be used for the battery charge temperature compensation feature and BTRM (Battery Thermal Runaway Management). Refer to "Optional Temperature Probes" for additional information.
  - h) Order optional SM-Temp Temperature Concentrator (Supervisory Module for Temperature Probes) as desired (shipped loose) (see page 106).

- **Note:** A system can have up to (8) SM-Temp modules (each of which can accept up to eight temperature probes) that can be used in the power system for ambient and battery monitoring.
- i) Order optional <u>SM-DU+ Shunt Monitoring</u> (P/N 548078) for any fuse panel with shunts (Lists AF, AH, BF, or BH) or any GJ/218 panels (Lists AC, AD, BC, BD, AM, or AP) that are equipped with shunted breakers. (The SM-DU+ is factory-wired to the shunts.)
- j) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- k) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- D) Order a distribution cabinet top shield as required per List 29. Not available in the enclosure option.
- m) Order a battery shunt as required per List 90, 91, or 92.
- n) Refer to "In-Line Fuse and Resistor Pigtail Kits" on page 103 for in-line resistor pigtails for use with shunt inputs and in-line fuse pigtails for use with battery midpoint inputs connected to an IB2 or EIB.
- 4) <u>1R482000E3 Rectifier / 1C48241500 Converter Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705300 as required per List <u>32</u>. Order field expansion module mounting assembly(s) per List <u>33</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870530001, 58870530003). Not available in the enclosure option.
  - a) Order the front access AC Input Termination Assembly per List <u>40</u>, <u>41</u>, or <u>42</u> if module mounting assembly 58870530001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870530003. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R482000E3.
  - c) Order optional converter interface components per List 60.
  - d) Order optional DC-DC converter modules as required, P/N 1C48241500.
  - e) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 5) <u>1R482000E3 Rectifier / 1C48582000P3 Converter Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705300 as required per List <u>32</u>. Order field expansion module mounting assembly(s) per List <u>33</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870530001, 58870530003). Not available in the enclosure option.
  - a) Order the front access AC Input Termination Assembly per List 40, 41, or 42 if module mounting assembly 58870530001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870530003. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R482000E3.
  - c) Order optional converter interface components per List 62.
  - d) Order optional DC-DC converter modules as required, P/N 1C48582000P3.
  - e) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) 1R483500E3 Rectifier Option: Order interface components for module mounting assembly(s) Spec. No. 588705400 as required per List 36. Order field expansion module mounting assembly(s) per List 37. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004).
  - a) Order the front access AC Input Termination Assembly per List 40, 41, 42, or 43 if module mounting assembly 58870540001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870540002, 58870540003, 58870540004. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N <u>1R483500E3</u>.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 7) Order battery trays as required per List 93 or List 95. Not available in the shipping rails option.
  - a) Order batteries as required per "Batteries" on page 52.
  - b) Order "Optional Battery Tray Battery Disconnect Circuit Breaker and Housing Kits" as required.
  - c) Order "Optional Battery Tray Front Battery Cover Kits" as required.

# List 2: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only

#### **Features**

- Provides common equipment for one bussed "power and distribution or distribution only" bay rated for up to 2000 amperes of distribution. Includes interbay power busbars and communications cable. System components factory mounted in a relay rack as specified when ordered.
- ♦ Mounts to either left or right side of List 1 Main Bay.
- ♦ Accepts one (1) distribution cabinet (options are 3-row or 4-row cabinet).
- ♦ Includes SM-DU (provides bay interface to the system controller).
- Accepts up to six (6) module mounting assemblies Spec. No. 588705300 or 588705400 (including expansion assemblies).

#### Restrictions

System components factory mounted in a relay rack as specified when ordered. Not available with enclosure or shipping rails.

When the system is equipped with a List <u>40</u>, <u>41</u>, <u>42</u>, or <u>43</u> front access input termination assembly, refer to the restrictions under these list descriptions.

Will not accept List 21 and 22 distribution cabinet.

(List 21 and 22 are not provided with connection points for interbay busbars.)

Will not accept List 60 converter interface components.

Will not accept dual voltage distribution panels.

Will not accept List 93 and List 95 battery trays option.

Order maximum of one (1) List 2.

Rear access required for installation of inter-bay busbars.

If low voltage disconnect (List LL) is to be included, the Main Bay (List 1) of the system must also have low voltage disconnect (List LL or List LB).

#### **Ordering Notes**

- 1) Order a relay rack per "Relay Racks and Shipping Brackets" on page 123. If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.
- 2) Order one (1) List 23 or 24 distribution cabinet.
  - a) Order up to four (4) (per the capacity of the distribution cabinet ordered) distribution panels, battery disconnect panels, return bar panel, and/or bulk output panel as required per "Single Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
  - b) Order low voltage disconnect options as required per "Low Voltage Disconnect Options" starting on page 99.
  - c) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
  - d) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
  - e) Order a distribution cabinet top shield as required per List 29.
  - f) If distribution only, order a bottom rear distribution cabinet cover per List 4.
  - g) Order a battery shunt as required per List 90, 91, or 92.
- 3) 1R482000E3 Rectifier Option: Order interface components for module mounting assembly(s) Spec. No. 588705300 as required per List 32. Order field expansion module mounting assembly(s) per List 33. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870530001, 58870530003).
  - a) Order the front access AC Input Termination Assembly per List <u>40</u>, <u>41</u>, or <u>42</u> if module mounting assembly 58870530001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870530003. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R482000E3.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 4) <u>1R483500E3 Rectifier Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705400 as required per List <u>36</u>. Order field expansion module mounting assembly(s) per List <u>37</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004).

Revision CC. March 13, 2025

### System Application Guide

- a) Order the front access AC Input Termination Assembly per List 40, 41, 42, or 43 if module mounting assembly 58870540001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870540002, 58870540003, 58870540004. See "Module Mounting Assembly" starting on page 112).
- b) Order rectifier modules as required, P/N 1R483500E3.
- c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

# List 3: 2<sup>nd</sup> through 5<sup>th</sup> Supplemental Bays Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, For System Mounted in a Relay Rack Only

#### **Features**

- Provides common equipment for one bussed "power and distribution or distribution only" bay rated for up to 2000
  amperes of distribution. Includes interbay power busbars and communications cable. System components factory
  mounted in a relay rack as specified when ordered.
- ♦ Mounts to either left or right side of List 2 Supplemental Bay or another List 3 Supplementary bay.
- ♦ Accepts one (1) distribution cabinet (options are 3-row or 4-row cabinet).
- ♦ Includes SM-DU (provides bay interface to the system controller).
- Accepts up to six (6) module mounting assemblies Spec. No. 588705300 or 588705400 (including expansion assemblies).

#### Restrictions

System components factory mounted in a relay rack as specified when ordered. Not available with enclosure or shipping rails.

When the system is equipped with a List 40, 41, 42, or 43 front access input termination assembly, refer to the restrictions under these list descriptions.

Will not accept List 21 and 22 distribution cabinet.

(List 21 and 22 are not provided with connection points for interbay busbars.)

Will not accept List 60 converter interface components.

Will not accept dual voltage distribution panels.

Order maximum of four (4) List 3.

Will not accept List 93 and List 95 battery trays option.

Rear access required for installation of inter-bay busbars.

If low voltage disconnect (List LL) is to be included, the Main Bay (List 1) of the system must also have low voltage disconnect (List LL or List LB).

#### **Ordering Notes**

- 1) Order a relay rack per "Relay Racks and Shipping Brackets" on page 123. If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.
- 2) Order one (1) List 23 or 24 distribution cabinet.
  - a) Order up to four (4) (per the capacity of the distribution cabinet ordered) distribution panels, battery disconnect panels, return bar panel, and/or bulk output panel as required per "Single Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
  - b) Order low voltage disconnect options as required per "Low Voltage Disconnect Options" starting on page 99.
  - c) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
  - d) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
  - e) Order a distribution cabinet top shield as required per List 29.
  - f) If distribution only, order a bottom rear distribution cabinet cover per List 4.
  - g) Order a battery shunt as required per List 90, 91, or 92.
- 3) <u>1R482000E3 Rectifier Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705300 as required per List <u>32</u>. Order field expansion module mounting assembly(s) per List <u>33</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870530001, 58870530003).

### System Application Guide

- a) Order the front access AC Input Termination Assembly per List 40, 41, or 42 if module mounting assembly 58870530001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870530003. See "Module Mounting Assembly" starting on page 112).
- b) Order rectifier modules as required, P/N 1R482000E3.
- c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 4) 1R483500E3 Rectifier Option: Order interface components for module mounting assembly(s) Spec. No. 588705400 as required per List 36. Order field expansion module mounting assembly(s) per List 37. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004).
  - a) Order the front access AC Input Termination Assembly per List <u>40</u>, <u>41</u>, <u>42</u>, or <u>43</u> if module mounting assembly 58870540001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870540002, 58870540003, 58870540004. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R483500E3.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.


### List 4: Distribution Only Bay Distribution Cabinet Bottom Rear Cover

#### **Features**

 Bottom rear cover shield for use when a supplemental bay is configured for "distribution only" (no module mounting assembly).

#### **Pastrictions**

Module mounting assembly(s) cannot be mounted in a bay when List 4 is installed.



#### **Ordering Notes**

Order when a supplemental distribution bay is configured for "distribution only" (no module mounting assembly).

# List 5: 1st through 5th Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located Remote from Main Bay

### **Features**

- Provides common equipment for one remote "power and distribution or distribution only" bay rated for up to 2000 amperes of distribution. Includes interbay communications cabling. System components factory mounted in a relay rack, on shipping rails, or in an enclosure as specified when ordered.
- ♦ Accepts one (1) distribution cabinet (options are 1-row, 2-row, 3-row, or 4-row cabinet).
- Includes SM-DU (provides bay interface to the system controller).
- Accepts up to six (6) module mounting assemblies Spec. No. 588705300 or 588705400 (including expansion assemblies).

#### Restrictions

System components factory mounted in a relay rack, on shipping rails, or in an enclosure as specified when ordered.

When the system is equipped with a List 40, 41, 42, or 43 front access input termination assembly, refer to the restrictions under these list descriptions.

Will not accept List 60 converter interface components.

Will not accept dual voltage distribution panels.

Order maximum of five (5) List 5.

Interbay power cabling is not included, and must be separately provided per site requirements.

If low voltage disconnect (List LL) is to be included, the Main Bay (List 1) of the system must also have low voltage disconnect (List LL or List LB).

Optional battery shunt will not read battery current properly (due to cabling to bays tied to battery input termination bars) and should be disabled. Battery current can be calculated by controller.

#### **Ordering Notes**

- 1) Order a relay rack or shipping brackets per "Relay Racks and Shipping Brackets" on page 123. If required, order relay rack transition plates per "Transition Plates to Mount Relay Rack on Top of GNB Absolyte IIP Batteries" on page 124. A relay rack, shipping rails, or enclosure must specified when ordered. If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.
- 2) Order an enclosure per "Enclosure" on page 125 if desired. A relay rack, shipping rails, or enclosure must specified when ordered.
- 3) Order one (1) List 21, 22, 23, or 24 distribution cabinet.
  - a) Order up to four (4) (per the capacity of the distribution cabinet ordered) distribution panels, battery disconnect panels, return bar panel, and/or bulk output panel as required per "Single Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
  - b) Order low voltage disconnect options as required per "Low Voltage Disconnect Options" starting on page 99.
  - c) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
  - d) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
  - e) Order a distribution cabinet top shield as required per List 29.
  - f) If distribution only, order a bottom rear distribution cabinet cover per List 4.
  - g) Order a battery shunt as required per List 90, 91, or 92.
- 4) <u>1R482000E3 Rectifier Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705300 as required per List <u>32</u>. Order field expansion module mounting assembly(s) per List <u>33</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870530001, 58870530003).
  - a) Order the front access AC Input Termination Assembly per List 40, 41, or 42 if module mounting assembly 58870530001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870530003. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R482000E3.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 5) <u>1R483500E3 Rectifier Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705400 as required per List <u>36</u>. Order field expansion module mounting assembly(s) per List <u>37</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004).
  - a) Order the front access AC Input Termination Assembly per List <u>40</u>, <u>41</u>, <u>42</u>, or <u>43</u> if module mounting assembly 58870540001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870540002, 58870540003, 58870540004. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N <u>1R483500E3</u>.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- Order battery trays as required per List <u>93</u> or List <u>95</u>.
  - a) Order batteries as required per "Batteries" under ACCESSORY DESCRIPTIONS.
  - b) Order "Optional Battery Tray Battery Disconnect Circuit Breaker and Housing Kits" as required.
  - c) Order "Optional Battery Tray Front Battery Cover Kits" as required.

### System Application Guide

# List 7: 1st Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only

### **Features**

- Provides common equipment for one bussed "power and distribution or distribution only" bay rated for up to 2000 amperes of distribution. Includes interbay power busbars and communications cable. System components factory mounted in an enclosure as specified when ordered.
- Mounts to either left or right side of List 1 Main Bay.
- ♦ Accepts one (1) distribution cabinet (options are 3-row or 4-row cabinet).
- ♦ Includes SM-DU (provides bay interface to the system controller).
- ♦ Accepts up to six (6) module mounting assemblies Spec. No. 588705400 (including expansion assemblies).
- ♦ Includes enclosure joining kit P/N 563677.

### Restrictions

System components factory mounted in an enclosure as specified when ordered.

Cannot put List 7 system next to a system in a relay rack.

When the system is equipped with a List <u>40</u>, <u>41</u>, <u>42</u>, or <u>43</u> front access input termination assembly, refer to the restrictions under these list descriptions.

Will not accept List 21 and 22 distribution cabinet.

(List 21 and 22 are not provided with connection points for interbay busbars.)

Will not accept List 93 and List 95 battery trays option.

Order maximum of one (1) List 7.

Rear access required for installation of inter-bay busbars.

If low voltage disconnect (List LL) is to be included, the Main Bay (List 1) of the system must also have low voltage disconnect (List LL or List LB).

- Order an enclosure and enclosure options per "Enclosure" on page 125.
- Order one (1) List <u>23</u> or <u>24</u> distribution cabinet.
  - a) Order up to four (4) (per the capacity of the distribution cabinet ordered) distribution panels, battery disconnect panels, return bar panel, and/or bulk output panel as required per "Single Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
  - b) Order low voltage disconnect options as required per "Low Voltage Disconnect Options" starting on page 99.
  - c) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
  - d) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
  - e) Order a battery shunt as required per List 90, 91, or 92.
- 3) <u>1R483500E3 Rectifier Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705400 as required per List <u>36</u>. Order field expansion module mounting assembly(s) per List <u>37</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004).
  - a) Order the front access AC Input Termination Assembly per List <u>40</u>, <u>41</u>, <u>42</u>, or <u>43</u> if module mounting assembly 58870540001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870540002, 58870540003, 58870540004. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R483500E3.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

### System Application Guide

# <u>List 8: 2<sup>nd</sup> through 5<sup>th</sup> Supplemental Bay Common Equipment (Power and Distribution or Distribution Only), Located In-Line with Main Bay, Enclosure Mounted Option Only</u>

### **Features**

- Provides common equipment for one bussed "power and distribution or distribution only" bay rated for up to 2000
  amperes of distribution. Includes interbay power busbars and communications cable. System components factory
  mounted in an enclosure as specified when ordered.
- ♦ Mounts to either left or right side of List 2 Supplemental Bay.
- ♦ Accepts one (1) distribution cabinet (options are 3-row or 4-row cabinet).
- ♦ Includes SM-DU (provides bay interface to the system controller).
- Accepts up to six (6) module mounting assemblies Spec. No. 588705400 (including expansion assemblies).
- ♦ Includes enclosure joining kit P/N 563677.

### Restrictions

System components factory mounted in an enclosure as specified when ordered.

Cannot put List 8 system next to a system in a relay rack.

When the system is equipped with a List 40, 41, 42, or 43 front access input termination assembly, refer to the restrictions under these list descriptions.

Will not accept List 21 and 22 distribution cabinet.

(List 21 and 22 are not provided with connection points for interbay busbars.)

Will not accept List 93 and List 95 battery tray option.

Order maximum of four (4) List 8.

Rear access required for installation of inter-bay busbars.

If low voltage disconnect (List LL) is to be included, the Main Bay (List 1) of the system must also have low voltage disconnect (List LL or List LB).

- 1) Order an enclosure and enclosure options per "Enclosure" on page 125.
- 2) Order one (1) List 23 or 24 distribution cabinet.
  - a) Order up to four (4) (per the capacity of the distribution cabinet ordered) distribution panels, battery disconnect panels, return bar panel, and/or bulk output panel as required per "Single Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
  - b) Order battery disconnect contactors and low voltage disconnect options as required per "Battery Disconnect Contactors" and "Low Voltage Disconnect Options" starting on page 89.
  - c) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
  - d) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
  - e) Order a battery shunt as required per List 90, 91, or 92.
- 3) <u>1R483500E3 Rectifier Option:</u> Order interface components for module mounting assembly(s) Spec. No. 588705400 as required per List <u>36</u>. Order field expansion module mounting assembly(s) per List <u>37</u>. Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004).
  - a) Order the front access AC Input Termination Assembly per List 40, 41, 42, or 43 if module mounting assembly 58870540001 ordered (or order module mounting assemblies that accommodate AC input cable assemblies or line cords; 58870540002, 58870540003, 58870540004. See "Module Mounting Assembly" starting on page 112).
  - b) Order rectifier modules as required, P/N 1R483500E3.
  - c) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

### List 21: One-Row Distribution Cabinet, For System Mounted in a Relay Rack or on Shipping Rails Only

### **Features**

- ♦ Accepts one (1) distribution panel.
- Rated for up to 600 amperes of distribution.

#### Restrictions

System mounted in a relay rack or on shipping rails only.

For use in List 1 and List 5 bays.

Cannot be ordered with List 1 if it is to be used with a List 2.

Not available for <u>List 2</u> and <u>List 3</u> bays (no interbay busbar landings available).

Battery disconnect panels cannot be ordered for use in a List 21.

### **Ordering Notes**

- Order one (1) distribution panel as required per "Single Voltage Distribution Panel", "Dual Voltage Distribution Panel", and "Bulk Output Panel" starting on page 54.
- 2) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 4) Order battery contactor, battery shunt, and low voltage disconnect options as required.



### **Features**

- Accepts up to two (2) total distribution panels, battery disconnect distribution panels, and/or return bar panel.
- Rated for up to 1200 amperes of distribution.

### **Restrictions**

System mounted in a relay rack or on shipping rails only.


For use in List 1 and List 5 bays.

Cannot be ordered with List 1 if it is to be used with a List 2.

Not available for <u>List 2</u> and <u>List 3</u> bays (no interbay busbar landings available).

The List LL Low Voltage Load Disconnect (LVLD) option cannot be installed in the field for systems that are not equipped with any LVLD's from the factory. Field replacement of factory installed LVLD contactors is still available.

- 1) Order up to two (2) distribution panels as required per "Single Voltage Distribution Panel", "Dual Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
- 2) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- 3) Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 4) Order battery contactor, battery shunt, and low voltage disconnect options as required.



### List 23: Three-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure

### **Features**

- Accepts up to three (3) total distribution panels, battery disconnect distribution panels, and/or return bar panel.
- Rated for up to 1800 amperes of distribution.


### Restrictions

For use in List 1, List 2, List 3, List 5, List 7 and List 8.


The List LL Low Voltage Load Disconnect (LVLD) option cannot be installed in the field for systems that are not equipped with any LVLD's from the factory. Field replacement of factory installed LVLD contactors is still available.

### **Ordering Notes**

- Order up to three (3) distribution panels as required per "Single Voltage Distribution Panel", "Dual Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
- Order fuses and/or circuit breakers as required per "<u>Distribution Devices</u>" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 4) Order battery contactor, battery shunt, and low voltage disconnect options as required.



Relay Rack Installation



Cabinet Installation

# <u>List 24: Four-Row Distribution Cabinet, For System Mounted in a Relay Rack, on Shipping Rails, or in an Enclosure</u>

### Features


- Accepts up to four (4) total distribution panels, battery disconnect distribution panels, and/or return bar panel.
- Rated for up to 2000 amperes of distribution.

### Restrictions


For use in List 1, List 2, List 3, List 5, List 7 and List 8.

The List LL Low Voltage Load Disconnect (LVLD) option cannot be installed in the field for systems that are not equipped with any LVLD's from the factory. Field replacement of factory installed LVLD contactors is still available.

- Order up to four (4) distribution panels as required per "Single Voltage Distribution Panel", "Dual Voltage Distribution Panel", "Battery Disconnect Distribution Panel", "Return Bar Panel", and "Bulk Output Panel" starting on page 54.
- Order fuses and/or circuit breakers as required per "<u>Distribution Devices</u>" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 4) Order battery contactor, battery shunt, and low voltage disconnect options as required.



Relay Rack Installation



Cabinet Installation

### List 29: Top Shield for Distribution Cabinet, For System Mounted in a Relay Rack Only

### **Features**


 Plastic shield covers all wiring access openings in top of distribution cabinet. Individual cutouts can be removed for wiring as required for specific installation.

### Restrictions

Not for use with systems mounted in an enclosure.

### **Ordering Notes**

1) Where closed top cover is required, order one (1) List 29 for each List 21, 22, 23, and 24 ordered.



# List 32: Module Mounting Assembly Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack or on Shipping Rails Only

### **Features**

- Provides components to add one (1) to five (5) module mounting assembly(s) (Spec. No. 588705300) to a Main or Supplemental Bay.
- Refer to "Module Mounting Assembly" starting on page 112 for module mounting assembly information.

### **Restrictions**

Not for use with systems mounted in an enclosure.

Includes 'module mounting assembly-to-power system/distribution cabinet' interconnect components only. The module mounting assembly(s) must be ordered separately. Refer to <u>List 60</u> or <u>List 60</u> if converters are to be used in the module mounting assembly (main bay only).

Each bay (when used with a List 40, 41, or 42) can be equipped with a maximum of five (5) module mounting assemblies (see List 33 for expansion assemblies).

- Order one (1) List 32 per module mounting assembly(s) Spec. No. 588705300 to be installed in the bay with these
  interconnect components (one to five) and specify the number of rows in the distribution cabinet so correct busbars can
  be provided.
- 2) Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870530001, 58870530003). (58870530001 required when List 40, 41, or 42 ordered with the system.)
- 3) Order rectifier modules as required per P/N 1R482000E3.
- Order optional DC-DC converter modules as required, P/N <u>1C48241500</u> (Main Bay Only). Requires <u>List 60</u> to be installed in Main Bay.
- Order optional DC-DC converter modules as required, P/N <u>1C48582000P3</u> (Main Bay Only).
   Requires <u>List 62</u> to be installed in Main Bay.
- 6) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

# List 33: Module Mounting Assembly Field Expansion Kit (for Spec. No. 58870530003), For System Mounted in a Relay Rack or on Shipping Rails Only

### **Features**

 Provides a field expansion module mounting assembly Spec. No. 58870530003.

#### Restrictions

Not for use with systems mounted in an enclosure.

Maximum of two (2) List 33 per bay (total number of shelves in a bay cannot exceed six, maximum of ten shelves (60 total rectifiers plus converters) per multi-bay system).

AC inputs MUST be wired directly to the expansion assembly(s).

### **Ordering Notes**

- 1) Order List 33 for a module mounting assembly Spec. No. 58870530003 to be added in the field.
- Order rectifier modules as required per P/N <u>1R482000E3</u>.
- Order optional DC-DC converter modules as required, P/N <u>1C48241500</u> (Main Bay Only).
   Requires List 60 to be installed in Main Bay.
- Order optional DC-DC converter modules as required, P/N <u>1C48582000P3</u> (Main Bay Only). Requires <u>List 62</u> to be installed in Main Bay.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order Rectifier AC Input Cable Assemblies per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 or order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.

### List 36: Module Mounting Assembly Interface Components (for Spec. No. 588705400)

### **Features**

- Provides components to add one (1) to five (5) (relay rack mounted option) or one (1) to six (6) (enclosure mounted option) module mounting assembly(s) (Spec. No. 588705400) to a Main or Supplemental Bay.
- ♦ Refer to "Module Mounting Assembly" starting on page 112 for module mounting assembly information.

### **Restrictions**

Includes 'module mounting assembly-to-power system/distribution cabinet' interconnect components only. The module mounting assembly(s) must be ordered separately.

Relay Rack Mounted Option: Each bay (when used with a List 40, 41, 42 or 43) can be equipped with a maximum of five (5) module mounting assemblies (see List 37 for expansion assemblies).

Enclosure Mounted Option: Each bay (when used with a List 40, 41, 42 or 43) can be equipped with a maximum of six (6) module mounting assemblies (see List 37 for expansion assemblies).

- 1) Order one (1) List 36 per module mounting assembly(s) Spec. No. 588705400 to be installed in the bay with these interconnect components and specify the number of rows in the distribution cabinet so correct busbars can be provided.
- Order module mounting assembly(s) as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540001, 58870540002, 58870540003, 58870540004). (58870540001 required when List 40, 41, 42 or 43 ordered with the system.)
- 3) Order rectifier modules as required per P/N <u>1R483500E3</u>.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

### List 37: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400)

### **Features**

 Provides busbars and mounting hardware to tie the DC output busbars in a field installed module mounting assembly Spec. No. 588705400 to the system's DC busbars.

#### Restrictions

For use only for expansion shelf mounted directly beneath a 588705400 shelf

Maximum of two (2) List 37 per bay (total number of shelves in a bay cannot exceed six).

AC inputs MUST be wired directly to the expansion assembly(s).

Field expansion shelf is not available if the system is equipped with the inverter system.

### **Ordering Notes**

- Order List 37 for a module mounting assembly Spec. No. 588705400 to be added in the field beneath a 588705400 shelf.
- Order List 37A for the first module mounting assembly Spec. No. 588705400 to be added in a system with 588705000 or 588705500 shelves, if required.
- 3) Order List 37 for the second module mounting assembly Spec. No. 588705400 to be added in a system with 588705000 or 588705500 shelves, if required.
- 4) Order a module mounting assembly as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540002, 58870540003, 58870540004).
- 5) Order rectifier modules as required per P/N 1R483500E3.
- 6) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 7) Order Rectifier AC Input Cable Assemblies per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 or order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.

List 37A: Module Mounting Assembly Field Expansion Kit (for Spec. No. 588705400), For System Originally Configured with 588705000 or 588705500 Shelves

### Features

 Provides busbars and mounting hardware to tie the DC output busbars in a field installed module mounting assembly Spec. No. 588705400 to the module mounting assembly 588705000 or 588705500.


### **Restrictions**

System mounted with 588705000 or 588705500 only. One (1) List 37A per bay (total number of shelves in a bay cannot exceed six).

AC inputs MUST be wired directly to the expansion assembly(s).

Field expansion shelf is not available if the system is equipped with the inverter system.

- 1) Order List 37A for the first module mounting assembly Spec. No. 588705400 to be added in the field beneath a 588705000 or 588705500 shelf.
- 2) Order List 37 if an additional module mounting assembly Spec. No. 588705400 to be added.
- 3) Order a module mounting assembly as required. See "Module Mounting Assembly" starting on page 112 (choices are 58870540002, 58870540003, 58870540004).
- 4) Order rectifier modules as required per P/N <u>1R483500E3</u>.



### System Application Guide

- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order Rectifier AC Input Cable Assemblies per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 or order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.

### List 40: Front Access AC Input Termination Assembly (1 AC Feed per 1 Rectifier, Single Phase)

#### **Features**

Provides AC input terminal blocks for connection of single phase 208 VAC, 240 VAC, 277 VAC input feeds for all rectifier positions in the bay. One (1) AC input feed required per one (1) rectifier position. Refer to "AC Input Connections to AC Input Termination Assembly List 40 Illustration when Used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 1 Rectifier, Single Phase)" on page 159 for specific wiring details.

### **Restrictions**

For use with 58870530001 or 58870540001 module mounting assemblies only.

To be used with a maximum of five module mounting assemblies for relay rack, maximum of six module mounting assemblies for enclosure.

588705300 only rated for 208 VAC, 240 VAC.

Factory installed only.

For initial installation, only. Initial module mounting assemblies are factory wired to List 40. If a field expansion module mounting assembly is added to the system, AC inputs MUST be wired directly to the assembly.

### **Ordering Notes**

1) Order either List 40, 41, 42, or 43 for each bay (or order module mounting assemblies with AC input line cords, AC input cable assemblies, or AC input terminal blocks). See "Module Mounting Assembly" starting on page 112.

### List 41: Front Access AC Input Termination Assembly (1 AC Feed per 2 Rectifiers, Single Phase)

### **Features**

Provides AC input terminal blocks for connection of single phase 208 VAC, 240 VAC, 277 VAC input feeds for all rectifier positions in the bay. One (1) AC input feed required per two (2) rectifier positions. Refer to "AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Five (5) Shelves Installed" on page 160 for specific wiring details.

### Restrictions

For use with 58870530001 or 58870540001 module mounting assemblies only.

To be used with a maximum of five module mounting assemblies for relay rack, maximum of six module mounting assemblies for enclosure.

588705300 only rated for 208 VAC, 240 VAC.

Factory installed only.

For initial installation, only. Initial module mounting assemblies are factory wired to List 41. If a field expansion module mounting assembly is added to the system, AC inputs MUST be wired directly to the assembly.

### **Ordering Notes**

1) Order either List 40, 41, 42, or 43 for each bay (or order module mounting assemblies with AC input line cords, AC input cable assemblies, or AC input terminal blocks). See "Module Mounting Assembly" starting on page 112.

### List 42: Front Access AC Input Termination Assembly (1 AC Feed per 3 Rectifiers, 3-Phase)

### **Features**

Provides AC input terminal blocks for connection of three phase 208 VAC, 240 VAC input feeds for all rectifier positions in the bay. One (1) AC input feed required per three (3) rectifier positions. Refer to "AC Input Connections to AC Input Termination Assembly List 42 Illustration when used with 588705300 or 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC) (1 Feed per 3 Rectifiers, Three Phase)" on page 165 for specific wiring details.

**Note:** The three-phase input is internally distributed within the system to provide a single-phase line to line connection to each rectifier position, evenly distributed across the three phases.

### **Restrictions**

For use with 58870530001 or 58870540001 module mounting assemblies only.

To be used with a maximum of five module mounting assemblies for relay rack, maximum of six module mounting assemblies for enclosure.

Factory installed only.

For initial installation, only. Initial module mounting assemblies are factory wired to List 42. If a field expansion module mounting assembly is added to the system, AC inputs MUST be wired directly to the assembly.

### **Ordering Notes**

1) Order either List 40, 41, 42, or 43 for each bay (or order module mounting assemblies with AC input line cords, AC input cable assemblies, or AC input terminal blocks). See "Module Mounting Assembly" starting on page 112.

### List 43: Front Access AC Input Termination Assembly (1 AC Feed per 3 Rectifiers, 3-Phase)

### **Features**

Provides AC input terminal blocks for connection of three phase 277/480 VAC input feeds for all rectifier positions in the bay. One (1) AC input feed required per three (3) rectifier positions. Refer to "AC Input Connections to AC Input Termination Assembly List 43 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 277/480 VAC) (1 Feed per 3 Rectifiers, Three Phase)" on page 166 for specific wiring details.

**Note:** The three-phase input is internally distributed within the system to provide a single-phase line to neutral connection to each rectifier position, evenly distributed across the three phases.

### Restrictions

For use with 58870540001 module mounting assemblies only.

To be used with a maximum of five module mounting assemblies for relay rack, maximum of six module mounting assemblies for enclosure.

Factory installed only.

For initial installation, only. Initial module mounting assemblies are factory wired to List 43. If a field expansion module mounting assembly is added to the system, AC inputs MUST be wired directly to the assembly.

### **Ordering Notes**

1) Order either List 40, 41, 42, or 43 for each bay (or order module mounting assemblies with AC input line cords, AC input cable assemblies, or AC input terminal blocks). See "Module Mounting Assembly" starting on page 112.

### List 50: Inverter System, 23", up to 6kVA maximum, Bulk Output

### **Features**

- Provides a bulk output inverter system.
- ♦ One (1) 6-position inverter module mounting shelf.
- One (1) 1U bulk output AC distribution shelf (includes one 70 A circuit breaker).
- Includes the EPO (Emergency Power Off) board which provides the EPO function.

### **Restrictions**

Not a stand-alone system. Factory integrated into a Vertiv<sup>™</sup> Power System.

For use with 588705400 rectifier shelves only. Field rectifier expansion shelf is not available if the system is equipped with the inverter system.

Maximum system output power when equipped with one (1) 23-inch-wide inverter shelf is 6kVA at 40 °C and 3kVA at 65 °C.


### **Ordering Notes**

- 1) Order List 50 as required.
- The inverter system uses breaker positions in the power system distribution for its DC input.
  - Single feed option Six (6) 30A factory-installed breakers
  - Dual feed option Three (3) 60A factory-installed breakers
- 3) Order List AL for the bottom row to accommodate the DC input breakers for the inverter modules.

### List 51: Inverter System, 23", up to 6kVA maximum (5.76kVA per NEC breaker de-rating), NEMA Outlet Output

### **Features**

- Provides a NEMA output inverter system.
- One (1) 6-position inverter module mounting shelf.
- One (1) 1U NEMA output AC distribution shelf (includes four 15 A circuit breakers).
- Includes the EPO (Emergency Power Off) board which provides the EPO function.



### Restrictions

Not a stand-alone system. Factory integrated into a  $\mathsf{Vertiv}^\mathsf{TM}$  Power System.

For use with 588705400 rectifier shelves only. Field rectifier expansion shelf is not available if the system is equipped with the inverter system.

Maximum system output power when equipped with one (1) 23-inch-wide inverter shelf is 5.76kVA at 40 °C and 3kVA at 65 °C.

- 1) Order List 51 as required.
- 2) The inverter system uses breaker positions in the power system distribution for its DC input.
  - Single feed option Six (6) 30A factory-installed breakers
  - Dual feed option Three (3) 60A factory-installed breakers
- 3) Order List AL for the bottom row to accommodate the DC input breakers for the inverter modules.

### List 52: Inverter System, 23", up to 12kVA maximum, Bulk Output

### **Features**

- Provides a bulk output inverter system.
- ♦ Two (2) 6-position inverter module mounting shelves.
- One (1) 2U bulk output AC distribution shelf (includes two 70 A circuit breakers).
- Includes the EPO (Emergency Power Off) board which provides the EPO function.

### **Restrictions**

Not a stand-alone system. Factory integrated into a  $\mathsf{Vertiv}^\mathsf{TM}$  Power System.

For use with 588705400 rectifier shelves only. Field rectifier expansion shelf is not available if the system is equipped with the inverter system.

Maximum system output power when equipped with two (2) 23-inch-wide inverter shelf is 12kVA at 40 °C and 6kVA at 65 °C.

### **Ordering Notes**

- 1) Order List 52 as required.
- 2) The inverter system uses breaker positions in the power system distribution for its DC input.
  - Single feed option Twelve (12) 30A factory-installed breakers
  - Dual feed option Six (6) 60A factory-installed breakers
- 3) Order List AL for the bottom row to accommodate the DC input breakers for the inverter modules.

### List 53: Inverter System, 23", up to 12kVA maximum (11.5kVA per NEC breaker de-rating), NEMA Outlet Output

### **Features**

- Provides a NEMA output inverter system.
- ♦ Two (2) 6-position inverter module mounting shelves.
- One (1) 2U NEMA output AC distribution shelf (includes eight 15 A circuit breakers).
- Includes the EPO (Emergency Power Off) board which provides the EPO function.


### Restrictions

Not a stand-alone system. Factory integrated into a Vertiv  $^{\text{\tiny{TM}}}$  Power System.

For use with 588705400 rectifier shelves only. Field rectifier expansion shelf is not available if the system is equipped with the inverter system.

Maximum system output power when equipped with two (2) 23-inch-wide inverter shelf is 11.5kVA at 40 °C and 6kVA at 65 °C.

- Order List 53 as required.
- 2) The inverter system uses breaker positions in the power system distribution for its DC input.
  - Single feed option Twelve (12) 30A factory-installed breakers
  - Dual feed option Six (6) 60A factory-installed breakers
- 3) Order List AL for the bottom row to accommodate the DC input breakers for the inverter modules.



### System Application Guide

# <u>List 60: +24V Converter Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack or on Shipping Rails Only</u>

### **Features**

 Provides components to interface +24V converters in Spec. No. 588705300 module mounting assemblies to the distribution cabinet.

#### Restrictions

Not for use with systems mounted in an enclosure.

Must be used in systems equipped with Spec. No. 588705300 module mounting assemblies.

Must be installed in main bay only.

If the system does not include a dual voltage distribution panel, the converter power cabling will be provided as ship-loose material.

### **Ordering Notes**

- 1) Order List 60 as required. Quantity of List 60 must equal the quantity of module mounting assembly(s) Spec. No. 588705300 installed in the bay with a maximum of four (4) List 60. Note that if five (5) assemblies are in the bay, the quantity of List 60 is still four (4).
- 2) Specify the number of module mounting assembly(s) Spec. No. 588705300 installed in the bay (one to five) so correct busbars can be provided.
- 3) Order up to three (3) converter modules, P/N <u>1C48241500</u>, per module mounting assembly. Each List 60 allows the three right-most shelf positions (when viewed from the front) to accept either converter or rectifier modules.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

# List 62: -58V Converter Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack or on Shipping Rails Only

### **Features**

 Provides components to interface -58V converters in Spec. No. 588705300 module mounting assemblies to the distribution cabinet.

### **Restrictions**

Not for use with systems mounted in an enclosure.

Must be used in systems equipped with Spec. No. 588705300 module mounting assemblies.

Must be installed in main bay only.

If the system does not include a dual voltage distribution panel, the converter power cabling will be provided as ship-loose material.

- 1) Order List 62 as required. Quantity of List 62 must equal the quantity of module mounting assembly(s) Spec. No. 588705300 installed in the bay with a maximum of four (4) List 62. Note that if five (5) assemblies are in the bay, the quantity of List 62 is still four (4).
- 2) Specify the number of module mounting assembly(s) Spec. No. 588705300 installed in the bay (one to five) so correct busbars can be provided.
- 3) Order up to three (3) converter modules, P/N <u>1C48582000P3</u>, per module mounting assembly. Each List 62 allows the three right-most shelf positions (when viewed from the front) to accept either converter or rectifier modules.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

### System Application Guide

### List 90: Optional Battery Shunt, 800 A

### **Features**

♦ Provides an 800 A battery shunt.

### **Restrictions**

For use with List 21 only.

Cannot be used with low voltage load disconnect (LVLD) in a List 21.

### **Ordering Notes**

1) Order as required.

### List 91: Optional Battery Shunt, 2000 A

### **Features**

♦ Provides a 2000 A battery shunt.

### **Restrictions**

For use with List 22 only.

### **Ordering Notes**

1) Order as required.

### List 92: Optional Battery Shunt, 2500 A

### **Features**

♦ Provides a 2500 A battery shunt.

### **Restrictions**

For use with List 23 and 24 only. Not for use with List 5.


### **Ordering Notes**

1) Order as required.

### List 93: Optional Battery Tray, Pre-Cabled, For System Mounted in a Relay Rack Only, 22.5" Deep

### **Features**

- ♦ Each List 93 provides one (1) battery tray factory mounted in the 23" wide system relay rack specified when ordered. Each battery tray holds four (4) 12 V front terminal valve regulated lead acid (VRLA) batteries. Battery cabling is factory provided and connected to the system's main busbars. Batteries are configured as one (1) 48 VDC string per tray.
- Battery trays can be ordered with or without a battery disconnect circuit breaker.
   When a circuit breaker is ordered, it is provided in the -48 VDC lead of each battery string (1 circuit breaker per tray).
- Battery tray dimensions are 21.3" wide X 22.5" deep. Refer to "<u>List 93 (Battery Tray)</u>" under PHYSICAL SIZE INFORMATION for a typical battery tray arrangement.
- ♦ Battery spacers included.



### Restrictions

Designed to accommodate the batteries listed under "Batteries" in the ACCESSORY DESCRIPTIONS section.


A single battery tray must mount at bottom of relay rack. Multiple battery trays must mount starting at bottom of relay rack and working upward. Factory spaces battery trays 6RU, 7RU, or 8RU apart as determined by battery selected. If no battery selected, factory spaces battery trays 8RU apart. Spacing can be increased above that required for the battery selected up to a maximum of 8RU.

Cable size for each tray is 2 AWG for optional battery disconnect circuit breaker selected up to 150 A and 1/0 AWG for circuit breaker selected over 150 A or if circuit breaker is not selected.

Maximum number of List 93 per relay rack is four (4).

Not a stand-alone battery system. Must be used as part of a power system that includes a List 1 (or List 5) with a List 21, 22, 23, or 24.


- 1) Order up to four (4) battery trays per relay rack, as required.
- 2) Order battery tray mounting kit P/N 565004 for use with enclosure P/N 563524 and P/N 564881.
- 3) Order battery cable termination kit, one per bay. P/N 553584 for use with List 21, P/N 555478 for use with Lists 22, 23 and 24.
- Order batteries separately. See "<u>Batteries</u>" in the ACCESSORY DESCRIPTIONS section. Battery cables and lugs factory provided and connected.
- 5) If optional battery tray battery disconnect circuit breaker is desired, order per "Optional Battery Tray Battery Disconnect Circuit Breaker and Housing Kits" in the ACCESSORY DESCRIPTIONS section. You can order either optional battery tray battery disconnect circuit breaker or optional battery tray Anderson battery connector kit, not both.
- 6) If optional battery tray Anderson battery connector kit is desired, order per "Optional Battery Tray Anderson Battery Connector Kit" in the ACCESSORY DESCRIPTIONS section. You can order either optional battery tray battery disconnect circuit breaker or optional battery tray Anderson battery connector kit, not both.
- 7) If optional battery tray front battery cover is desired, order per "Optional Battery Tray Front Battery Cover Kits" in the ACCESSORY DESCRIPTIONS section.



### List 95: Optional Battery Tray, Pre-Cabled, For System Mounted in a Relay Rack Only, 24.79" Deep

### **Features**

- Each List 95 provides one (1) battery tray factory mounted in the 23" wide system relay rack specified when ordered. Each battery tray holds four (4) 12 V front terminal valve regulated lead acid (VRLA) batteries. Battery cabling is factory provided and connected to the system's main busbars. Batteries are configured as one (1) 48 VDC string per tray.
- Battery trays can be ordered with or without a battery disconnect circuit breaker. When a circuit breaker is ordered, it is provided in the -48 VDC lead of each battery string (1 circuit breaker per tray).
- Battery tray dimensions are 21.3" wide X 24.79" deep. Refer to "<u>List 95</u>
   (<u>Battery Tray</u>)" under *PHYSICAL SIZE INFORMATION* for a typical battery tray arrangement.
- ♦ Battery spacers included.



### Restrictions

Designed to accommodate the batteries listed under "Batteries" in the ACCESSORY DESCRIPTIONS section.


A single battery tray must mount at bottom of relay rack. Multiple battery trays must mount starting at bottom of relay rack and working upward. Factory spaces battery trays 6RU, 7RU, or 8RU apart as determined by battery selected. If no battery selected, factory spaces battery trays 8RU apart. Spacing can be increased above that required for the battery selected up to a maximum of 8RU.

Cable size for each tray is 2 AWG for optional battery disconnect circuit breaker selected up to 150 A and 1/0 AWG for circuit breaker selected over 150 A or if circuit breaker is not selected.

Maximum number of List 95 per relay rack is four (4).

Not a stand-alone battery system. Must be used as part of a power system that includes a List 1 (or List 5) with a List 21, 22, 23, or 24.

- 1) Order up to four (4) battery trays per relay rack, as required.
- 2) Order battery tray mounting kit P/N 565004 for use with enclosure P/N 563524 and P/N 564881.
- 3) Order battery cable termination kit, one per bay. P/N 553584 for use with List 21, P/N 555478 for use with Lists 22, 23 and 24.
- Order batteries separately. See "<u>Batteries</u>" in the ACCESSORY DESCRIPTIONS section. Battery cables and lugs factory provided and connected.
- 5) If optional battery tray battery disconnect circuit breaker is desired, order per "Optional Battery Tray Battery Disconnect Circuit Breaker and Housing Kits" in the ACCESSORY DESCRIPTIONS section. You can order either optional battery tray battery disconnect circuit breaker or optional battery tray Anderson battery connector kit, not both.
- 6) If optional battery tray Anderson battery connector kit is desired, order per "Optional Battery Tray Anderson Battery Connector Kit" in the ACCESSORY DESCRIPTIONS section. You can order either optional battery tray battery disconnect circuit breaker or optional battery tray Anderson battery connector kit, not both.
- 7) If optional battery tray front battery cover is desired, order per "Optional Battery Tray Front Battery Cover Kits" in the ACCESSORY DESCRIPTIONS section.



## Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System System Application Guide

### **Batteries**

### **Restrictions**

For use in List <u>93</u> and List <u>95</u> battery trays.

### **Ordering Notes**

1) Order batteries from Table 1 as required for List 93.

Manufacturer*	Manufacturer P/N	P/N (12 V Module)	Capacity (A-Hr)	Dimension W x L x H (Inches) (per 12 V Module)	Min Tray Spacing (RU)	Weight (lb) (per 12V Module)	Lug Kit 2 AWG	Lug Kit 1/0 AWG
C&D	TEL12-160F	140456	157	5.0 x 22.0 x 11.10	7	116.8	528236	528237
C&D	TEL12-180F		181	5.0 x 22.0 x 12.60	8	132.3	528236	528237
C&D	TEL12-210F	554579	202	5.0 x 22.0 x 12.60	8	132.3	528236	528237
Deka	12AVR-150ET	122018	150	4.90 x 22.00 x 11.75	8	115	528234	528235
Deka	12AVR-170ET	541381	170	4.90 x 22.0 x 12.60	8	120	528234	528235
Deka	HT170ET		164	4.93 x 22.17 x 12.58	8	118	528234	528235
Enersys	12V155FS	122010	155	4.90 x 22.10 x 11.10	7	106.9	528234	528235
Enersys	12V170FS		170	4.90 x 22.10 x 11.10	7	112	528234	528235
Enersys	SBS 170F		170	4.92 x 22.10 x 11.10	7	116	528234	528235
Enersys	SBS 190F	-	190	4.90 x 22.10 x 12.40	8	132	528234	528235
FIAMM	12FAT100		100	4.96 x 21.97 x 9.06	6	95	528234	528235
FIAMM	12FAT155		155	4.96 x 21.97 x 12.64	8	129	528234	528235
FIAMM	12FAT180		100	4.96 x 21.97 x 12.64	8	134	528234	528235
Northstar	NSB155FT RED		155	4.90 x 22.0 x 11.00	7	101	528234	528235
Northstar	NSB170FT RED	126111	170	4.90 x 22.00 x 12.60	8	116	528234	528235
Northstar	NSB190FT RED		190	4.90 x 22.00 x 12.60	8	123	528234	528235
Northstar	NSB155FT HT		154	4.90 x 22.00 x 11.0	7	117	528234	528235
Northstar	NSB170FT HT		174	4.90 x 22.00 x 12.60	8	121	528234	528235
Northstar	NSB190FT HT		190	4.90 x 22.00 x 12.60	8	132	528234	528235
GS Yuasa	PYL12V160FT		160	4.90 x 21.90 x 11.0	7	116.2	528234	528235
GS Yuasa	PYL12V185FT		185	4.90 x 21.90 x 12.50	8	133.8	528234	528235

<sup>\*</sup> See <u>Battery Manufacturer Information</u>

Table 1
Batteries and Battery Lug Kits for List 93

### 2) Order batteries from Table 2, as required for List <u>95.</u>

Manufacturer*	Manufacturer P/N	P/N (12 V Module)	Capacity (A-Hr)	Dimension W x L x H (Inches) (per 12 V Module)	Min Tray Spacing (RU)	Weight (lb) (per 12V Module)	Lug Kit 2 AWG	Lug Kit 1/0 AWG
Deka	12AVR-200ET		200	4.97 x 24.3 x 12.74	8	151	528234	528235
Deka	HT200ET		200	4.97 x 24.15 x 12.74	8	151	528234	528235

<sup>\*</sup> See <u>Battery Manufacturer Information</u>

Table 2 Batteries and Battery Lug Kits for List <u>95</u>

### Optional Battery Tray Battery Disconnect Circuit Breaker and Housing Kits

### **Features**

 Provides a battery disconnect circuit breaker housing factory mounted on the left or right side of the List <u>93</u> and List <u>95</u> battery trays. Selected circuit breaker factory installed and wired.


### Restrictions

For use in List 93 and List 95 battery trays.

Factory wires battery trays with 2 AWG cables for battery disconnect circuit breaker selected up to 150 A and 1/0 AWG cables for circuit breaker selected over 150 A.

### **Ordering Notes**

- For each battery tray, order one (1) circuit breaker from Table 3.
- For each double-pole circuit breaker ordered, order an optional circuit breaker guard P/N 548014, if desired, to block front access to circuit breaker handle.
- For each battery tray ordered, order one (1) battery circuit breaker housing kit from Table 4.



Ampere Rating	P/N Electrical/Mechanical Trip <sup>1</sup> (Black Handle)	No. of Poles
50	256694300	
60	256694700	
70	256695100	1-Pole
75	256695500	
100	256695900	
125	100762	
150	100763	2-Pole
200	121810	

Circuit Breaker Alarm Operation:

Table 3
Battery Tray Battery Disconnect Circuit Breakers

Part Number	Description
559813	Single Pole, Right Side Mounted
559814	Single Pole, Left Side Mounted
559815	Double Pole, Right Side Mounted
559816	Double Pole, Left Side Mounted

Table 4
Battery Tray Battery Disconnect Circuit Breaker Housing Kits

<sup>&</sup>lt;sup>1</sup>Provides an alarm during an electrical or manual trip condition.

### **Optional Battery Tray Front Battery Cover Kits**

### **Features**

 Provides a front battery cover to the List <u>93</u> and List <u>95</u> battery trays.

### **Restrictions**


For use in List 93 and List 95 battery trays.

### **Ordering Notes**

1) Order one (1) kit per tray from Table 5, as required.

Part Number	Height		
562128	8U		
562053	7U		
562145	6U		

Table 5



### **Optional Battery Tray Anderson Battery Connector Kit**

### **Features**


 Provides an Anderson battery connector (SB 120) factory mounted on the left or right side of the List <u>93</u> and List <u>95</u> battery trays.

### Restrictions

For use in List 93 and List 95 battery trays.

### **Ordering Notes**

 For each battery tray, order one (1) Anderson battery tray connector kit P/N 563297.



### List 100: Power and Distribution Bay (Fully Configured)

### **Features**

- ♦ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ +24 VDC, maximum.
- ♦ This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 100 (Relay Rack)" on page 17.

All system components mounted in a 7' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List DJ distribution panel in the top row.

Includes two (2) List AL distribution panels in the lower two rows.

Includes the NCU controller (with custom configuration).

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Includes one (1) EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs).

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

Includes three (3) 556155 temperature probes.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

### System Application Guide

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 - 48 VDC Bus). Also includes a 75 A circuit breaker factory installed in Row 2 distribution panel position #26 (connected to the SPD Assemblies).

This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48241500.
- Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 7) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 8) For a field installed battery tray, order P/N 563206.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502 and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 101: Power and Distribution Bay (Fully Configured with One Battery Tray)

- Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ +24 VDC, maximum.
- This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 101 (Relay Rack)" on page 20.

All system components mounted in a 5' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List DJ distribution panel in the top row.

Includes two (2) List AL distribution panels in the lower two rows.

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes the NCU controller with custom configuration.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Includes one (1) EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs).

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

Includes three (3) 556155 temperature probes.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

### System Application Guide

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes one (1) battery tray with 200 A disconnect circuit breakers.

Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). Also includes a 75 A circuit breaker factory installed in Row 2 distribution panel position #26 (connected to the SPD Assemblies).

♦ This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- 1) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48241500.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order batteries as required per "Batteries" on page 52. Three (3) P/N 562674 battery trays provided.
- 7) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 8) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 102: Power and Distribution Bay (Fully Configured with Two Battery Trays)

### **Features**

- ◆ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ +24 VDC, maximum.
- ♦ This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 102 (Relay Rack)" on page 21.

All system components mounted in a 6' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List DJ distribution panel in the top row.

Includes two (2) List AL distribution panels in the lower two rows.

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes the NCU controller with custom configuration.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Includes one (1) EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs).

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

### System Application Guide

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes two (2) battery trays with 200 A disconnect circuit breakers.

Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). Also includes a 75 A circuit breaker factory installed in Row 2 distribution panel position #26 (connected to the SPD Assemblies).

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- 1) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48241500.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order batteries as required per "Batteries" on page 52. Three (3) P/N 562674 battery trays provided.
- 7) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 8) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 203: Power and Distribution Bay (Fully Configured with Three Battery Trays)

### **Features**

- ♦ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ +24 VDC, maximum.
- ♦ This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 203 (Relay Rack)" on page 22.

All system components mounted in a 7' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List DJ distribution panel in the top row.

Includes two (2) List AL distribution panels in the lower two rows.

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes the NCU controller with custom configuration.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Includes one (1) EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs).

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

### System Application Guide

Includes three (3) 556155 temperature probes.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes three (3) battery trays with 200 A disconnect circuit breakers.

Includes factory installed and wired SPD (Surge Protection Device) Assemblies (Row 2 -48 VDC Bus). Also includes a 75 A circuit breaker factory installed in Row 2 distribution panel position #26 (connected to the SPD Assemblies).

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- 1) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48241500.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order batteries as required per "Batteries" on page 52. Three (3) P/N 562674 battery trays provided.
- 7) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 8) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 500: Power and Distribution Bay (Fully Configured)

### **Features**

- ◆ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 414 A @ -58 VDC, maximum.
- ♦ This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 500 (Relay Rack)" on page 23.

All system components mounted in a 7' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List FK distribution panel in the top row.

Includes one (1) List FG distribution panel in the middle row.

Includes one (1) List AL distribution panel in the bottom row.

Includes the NCU controller (with custom configuration).

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

### System Application Guide

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

Includes three (3) 556155 temperature probes.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48582000P3.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 7) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 8) For a field installed battery tray, order P/N 563206.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 501: Power and Distribution Bay (Fully Configured with One Battery Tray)

### **Features**

- ♦ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ -58 VDC, maximum.
- ♦ This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 501 (Relay Rack)" on page 24.

All system components mounted in a 5' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List FK distribution panel in the top row.

Includes one (1) List FG distribution panel in the middle row.

Includes one (1) List AL distribution panel in the bottom row.

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes the NCU controller with custom configuration.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

### System Application Guide

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes one (1) battery tray with 200 A disconnect circuit breakers.

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- 1) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48582000P3.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order batteries as required per "Batteries" on page 52. Three (3) P/N 562674 battery trays provided.
- 7) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 8) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 502: Power and Distribution Bay (Fully Configured with Two Battery Trays)

### **Features**

- ♦ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ -58 VDC, maximum.
- ♦ This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 502 (Relay Rack)" on page 25.

All system components mounted in a 6' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List FK distribution panel in the top row.

Includes one (1) List FG distribution panel in the middle row.

Includes one (1) List AL distribution panel in the bottom row.

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes the NCU controller with custom configuration.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

### System Application Guide

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes two (2) battery trays with 200 A disconnect circuit breakers.

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- 1) Order fuses and/or circuit breakers as required per "Distribution Devices" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48582000P3.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order batteries as required per "Batteries" on page 52. Three (3) P/N 562674 battery trays provided.
- 7) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 8) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 503: Power and Distribution Bay (Fully Configured with Three Battery Trays)

### **Features**

- ♦ Provides a "power and distribution" bay rated for 1000 A @ -48 VDC and 500 A @ -58 VDC, maximum.
- This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 503 (Relay Rack)" on page 2622.

All system components mounted in a 7' x 23" seismic Zone-4 rated relay rack.

Includes a 3-row distribution cabinet.

Includes one (1) List FK distribution panel in the top row.

Includes one (1) List FG distribution panel in the middle row.

Includes one (1) List AL distribution panel in the bottom row.

Includes a battery disconnect contactor providing low voltage and manual battery disconnect.

Includes the NCU controller with custom configuration.

Includes a system interface board which provides manual battery disconnect, system voltage test points, two (2) temperature inputs, two (2) battery CB/Fuse alarm inputs, and a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts a second optional IB2 controller interface board. See page 101.

Accepts a second optional EIB controller extended interface board. See Restrictions. See page 102.

### System Application Guide

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) rectifier only shelf (six positions accept rectifiers only).

Includes three (3) rectifier/converter shelves (three positions accept rectifiers only, three positions accept rectifiers or converters).

Includes front access AC input termination assemblies with two rectifiers per AC feed, single phase.

Includes three (3) battery trays with 200 A disconnect circuit breakers.

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000100 and UM582127000100.

### **Ordering Notes**

- Order fuses and/or circuit breakers as required per "<u>Distribution Devices</u>" starting on page 132.
- Order input and load distribution lugs, lug adapters, and lug hardware kits as required per "Recommended Wire Sizes, Branch Circuit Protection, Crimp Lugs, and Wiring Illustrations" starting on page 149.
- 3) Order rectifier modules as required, P/N 1R482000E3.
- 4) Order optional DC-DC converter modules as required, P/N 1C48582000P3.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 6) Order batteries as required per "Batteries" on page 52. Three (3) P/N 562674 battery trays provided.
- 7) Order optional second IB2 controller interface board as required. See Restrictions. See page 101.
- 8) Order optional second EIB controller interface board as required. See Restrictions. See page 102.
- 9) Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables. Refer to "Special Application Rectifier Bus Landing Point Kit P/N 563686" on page 144.
- 10) A DC generator input circuit breaker kit P/N 564219 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system.
- 11) If required, order Relay Rack Isolation Kit as applicable per "Relay Rack Isolation Kit" on page 124.

### List 600, 601: Power and Distribution Bay (Fully Configured)

### **Features**

- Provides a "power and distribution" bay rated for 600 A @ -48 VDC, maximum.
- This is a preconfigured power system which is orderable by specifying one List number. This power system is
  preconfigured as follows. See also "582127000 List 600, 601 (rack mounted in an OSP enclosure)" on page 28.

Includes a 2-row distribution cabinet equipped with two (2) single voltage distribution panels (26-distribution positions each). Visible on the front door is a critical alarm indicator which illuminates if the NCU controller issues a critical alarm.

List 600 Only: Includes a battery disconnect contactor providing low voltage battery disconnect (LVBD).

Includes a system interface board which provides a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts the optional EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs). See page 102.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) controller/rectifier shelf (positions for 1 controller and 5 rectifiers).

Includes one (1) rectifier shelf (positions for 6 rectifiers).

Includes a rear access AC input termination assembly configurable for either one rectifier per AC feed or two rectifiers per AC feed, single phase.

### System Application Guide

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000900 and UM582127000900.

- 1) Order one (1) NCU controller (P/N 1M830BNA) with the desired configuration.
- 2) Order the optional EIB controller extended interface board as required (see page 102).
- 3) Order optional <u>temperature probes</u> for ambient and battery temperature monitoring, as required. The temperature probe(s) may also be used for the battery charge temperature compensation feature and BTRM (Battery Thermal Runaway Management). Refer to "Optional Temperature Probes" for additional information.
- 4) Order optional SM-Temp Temperature Concentrator (Supervisory Module for Temperature Probes) as desired (shipped loose) (see page 106).
  - **Note:** A system can have up to (8) SM-Temp modules (each of which can accept up to eight temperature probes) that can be used in the power system for ambient and battery monitoring.
- 5) Order fuses and/or circuit breakers as required per "Bullet Nose Type Circuit Breakers and Bullet Nose Type Fuseholders e/w TPS/TLS Fuses" on page 132.
- 6) Order 6-position GMT fuse block P/N 549017 and fuses as required per "Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block, P/N 549017, (6) GMT Fuse Positions" on page 136.
- 7) Order output lugs as required per "Crimp Lugs" starting on page 126. Order output lug hardware kit P/N 548185 as required per "Lug Hardware Kits" starting on page 130.
- 8) Order load distribution lugs as required per "Crimp Lugs" starting on page 126. Order load distribution lug adapters P/N 559805 for 3-pole devices, P/N 559804 for 2-pole devices, and P/N 559803 for 1-pole devices as required per "Lug Adapters" starting on page 128. Order load distribution lug hardware kit P/N 541084 as required per "Lug Hardware Kits" starting on page 130.
- 9) Order rectifier modules as required, P/N 1R483500E3.
- 10) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 11) Order power extend converters and other material as required per "Optional eSure™ Power Extend Converter" on page 112.
- 12) A DC generator input circuit breaker kit P/N 60141027 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system. This kit includes an EIB kit for shunt monitoring.
- 13) A DC generator input landing kit P/N 10067484 is available. This kit provides DC generator input landing points on the rectifier output bus of the power system. This allows for connection of an external DC generator input provided through an external 600 A DC generator output breaker. This kit includes an EIB kit for shunt monitoring.

### List 900, 901: Power and Distribution Bay (Fully Configured)

### **Features**

- ♦ Provides a "power and distribution" bay rated for 900 A @ -48 VDC, maximum.
- This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 900, 901 (rack mounted in an OSP enclosure)" on page 29.

Includes a 2-row distribution cabinet equipped with two (2) single voltage distribution panels (26-distribution positions each). Visible on the front door is a critical alarm indicator which illuminates if the NCU controller issues a critical alarm.

List 900 Only: Includes a battery disconnect contactor providing low voltage battery disconnect (LVBD).

Includes a system interface board which provides a CAN interface connector.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts the optional EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs. and eight (8) battery midpoint inputs). See page 102.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) controller/rectifier shelf (positions for 1 controller and 5 rectifiers).

Includes two (2) rectifier shelves (positions for 6 rectifiers each).

Includes a rear access AC input termination assembly configurable for either one rectifier per AC feed or two rectifiers per AC feed, single phase.

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000900 and UM582127000900.

- 1) Order one (1) NCU controller (P/N 1M830BNA) with the desired configuration.
- 2) Order the optional EIB controller extended interface board as required (see page 102).
- 3) Order optional temperature probes for ambient and battery temperature monitoring, as required. The temperature probe(s) may also be used for the battery charge temperature compensation feature and BTRM (Battery Thermal Runaway Management). Refer to "Optional Temperature Probes" for additional information.
- 4) Order optional SM-Temp Temperature Concentrator (Supervisory Module for Temperature Probes) as desired (shipped loose) (see page 106).
  - **Note:** A system can have up to (8) SM-Temp modules (each of which can accept up to eight temperature probes) that can be used in the power system for ambient and battery monitoring.
- Order fuses and/or circuit breakers as required per "Bullet Nose Type Circuit Breakers and Bullet Nose Type Fuseholders e/w TPS/TLS Fuses" on page 132.
- 6) Order 6-position GMT fuse block P/N 549017 and fuses as required per "Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block, P/N 549017, (6) GMT Fuse Positions" on page 136.
- 7) Order output lugs as required per "Crimp Lugs" starting on page 126. Order output lug hardware kit P/N 548185 as required per "Lug Hardware Kits" starting on page 130.
- 8) Order load distribution lugs as required per "Crimp Lugs" starting on page 126. Order load distribution lug adapters P/N 559805 for 3-pole devices, P/N 559804 for 2-pole devices, and P/N 559803 for 1-pole devices as required per "Lug Adapters" starting on page 128. Order load distribution lug hardware kit P/N 541084 as required per "Lug Hardware Kits" starting on page 130.
- 9) Order rectifier modules as required, P/N 1R483500E3.
- 10) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 11) Order power extend converters and other material as required per "Optional eSure™ Power Extend Converter" on page 112.
- 12) A DC generator input circuit breaker kit P/N 60141027 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system. This kit includes an EIB kit for shunt monitoring.

13) A DC generator input landing kit P/N 10067484 is available. This kit provides DC generator input landing points on the rectifier output bus of the power system. This allows for connection of an external DC generator input provided through an external 600 A DC generator output breaker. This kit includes an EIB kit for shunt monitoring.

### List 930, 931: Power and Distribution Bay, Dual Voltage

### **Features**

- Provides a "power and distribution" bay rated for 900 A @ -48 VDC 600 A peak @ -58 VDC, maximum.
- This is a preconfigured power system which is orderable by specifying one List number. This power system is preconfigured as follows. See also "582127000 List 930, 931 (rack mounted in an OSP enclosure)" on page 30.

Includes a 2-row distribution cabinet equipped with two (2) dual voltage distribution panels (30-distribution positions each). Visible on the front door is a critical alarm indicator which illuminates if the NCU controller issues a critical alarm.

List 930 Only: Includes a battery disconnect contactor.

Includes a system interface board which provides a CAN interface connector and a manual disconnect switch.

Includes one (1) IB2 controller interface board (provides eight (8) programmable form C- relay outputs, eight (8) programmable binary inputs, and two (2) temperature inputs).

Accepts one (1) optional IB2 controller interface board.

Accepts an optional EIB controller extended interface board (provides five (5) programmable form-C relay outputs, two (2) temperature inputs, three (3) shunt inputs, and eight (8) battery midpoint inputs). See page 102.

Includes the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

Includes one (1) controller/rectifier shelf (positions for one (1) controller and 5 rectifiers).

Includes two (2) rectifier shelves (positions for six (6) rectifiers each).

Includes two (2) DC-DC converter shelves (positions for six (6) converters each).

Includes a rear access AC input termination assembly configurable for either one rectifier per AC feed or two rectifiers per AC feed, single phase.

 This system includes separate installation and user manuals specific to its configuration. Refer to IM582127000900 and UM582127000900.

### **Ordering Notes**

- 1) Order one (1) NCU controller (P/N 1M830BNA) with the desired configuration.
- 2) Order the optional EIB controller extended interface board as required (see page 102).
- 3) Order the optional second IB2 controller interface board as required (see page 101).
- 4) Order optional <u>temperature probes</u> for ambient and battery temperature monitoring, as required. The temperature probe(s) may also be used for the battery charge temperature compensation feature and BTRM (Battery Thermal Runaway Management). Refer to "Optional Temperature Probes" for additional information.
- 5) Order optional SM-Temp Temperature Concentrator (Supervisory Module for Temperature Probes) as desired (shipped loose) (see page 106).

**Note:** A system can have up to (8) SM-Temp modules (each of which can accept up to eight temperature probes) that can be used in the power system for ambient and battery monitoring.

- 6) Order fuses and/or circuit breakers as required per "Bullet Nose Type Circuit Breakers and Bullet Nose Type Fuseholders e/w TPS/TLS Fuses" on page 132.
- 7) Order optional 6-position GMT fuse block kit P/N 60160608 and/or fuses as required per "Optional 6-Position 30A GMT Fuse Board Kit, P/N 60160806" on page 138.
- 8) Order output lugs as required per "Crimp Lugs" starting on page 126. Order output lug hardware kit P/N 548185 as required per "Lug Hardware Kits" starting on page 130.
- 9) Order load distribution lugs as required per "Crimp Lugs" starting on page 126. Order load distribution lug adapters P/N 559805 for 3-pole devices, P/N 559804 for 2-pole devices, and P/N 559803 for 1-pole devices as required per "Lug Adapters" starting on page 128. Order load distribution lug hardware kit P/N 541084 as required per "Lug Hardware Kits" starting on page 130.
- 10) Order rectifier modules as required, P/N 1R483500E3.
- 11) Order rectifier modules as required, P/N <u>1R483600E4</u>.
- 12) Order converter modules as required, P/N 1C48583750P4.

## System Application Guide

- 13) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.
- 14) A DC generator input circuit breaker kit P/N 60141027 is available. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies generator input power to the system. This kit includes an EIB kit for shunt monitoring.
- 15) A DC generator input landing kit P/N 60177224 is available. This kit provides DC generator input landing points on the rectifier output bus of the power system. This allows for connection of an external DC generator input provided through an external 600 A DC generator output breaker. This kit includes an EIB kit for shunt monitoring.

### System Application Guide

### **Single Voltage Distribution Panels**

List AC: -48 VDC Distribution Panel (with Return Busbar) and List AD: -48 VDC Distribution Panel (without Return Busbar), (4) GJ/218 Circuit Breaker Positions

### **Features**

- (4) -48 VDC Load Distribution Circuit Breaker Mounting Positions: 100 A to 800 A GJ/218 Type Circuit Breakers.
- ♦ List AC includes a return busbar; List AD does not include a return busbar.
- ♦ 600 A Maximum Capacity at 40°C ambient. 700 A Maximum Capacity at 30°C ambient. Maximum current rating of each landing point is 360 A.


### Restrictions

Can be installed in any bus row 1-4 of a 1-, 2-, 3-, or 4-row distribution cabinet.

Maximum lug width, 1.375 inches.

For an 800 A circuit breaker, continuous load must not exceed 600 A at 40°C ambient, 700 A at 30°C ambient.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL per panel as required.
- 3) List AD: To terminate load returns within the distribution cabinet, order List GA as required.
- 4) Order circuit breakers and associated jumper kits as required per Table 27.
- 5) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 6) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 7) Order return and load bus bar assemblies per Table 6 for List AC or Table 7 for List AD.



### List AF: -48 VDC Distribution Panel,

### (2) TPH Fuse Positions (with Shunts) (without Return Busbar)

#### **Features**


- (2) -48 VDC Distribution Fuse Mounting Positions:
   70 A to 600 A TPH Type Fuses.
- Includes shunts, 800 A / 25 mV. Each shunt is equipped with 10' jumpers for connection to monitoring device. If the
  system is equipped with an SM-DU+, the leads are trimmed and connected to the SM-DU+ (internal to the distribution
  cabinet).
- ♦ Does NOT include a return busbar.
- ♦ 600 A Maximum Capacity.

### **Restrictions**

Can be installed in any row 1-4 of a 1-, 2-, 3-, or 4-row distribution cabinet.

Maximum lug width, 1.88 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL per panel as required.
- 3) To terminate load returns within the distribution cabinet, order List GA as required.
- 4) Order fuses as required per Table 28. Order replacement alarm fuses (1/4 A) per Table 29.
- 5) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 6) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 7) Order return and load bus bar assemblies per Table 7.



### List AH: -48 VDC Distribution Panel,

### (4) TPH Fuse Positions (with Shunts) (without Return Busbar)

#### **Features**


- (4) -48 VDC Distribution Fuse Mounting Positions: 70 A to 400 A TPH Type Fuses.
- Includes shunts, 600 A / 25 mV. Each shunt is equipped with 10' jumpers for connection to monitoring device. If the system is equipped with an SM-DU+, the leads are trimmed and connected to the SM-DU+ (internal to the distribution cabinet).
- ♦ Does NOT include a return busbar.
- ♦ 600 A Maximum Capacity.

### **Restrictions**

Cannot be installed in row 1 (bottom row) of a system with a List 2, 3, 5, or 6 (supplemental bay).

Maximum lug width, 1.75 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL per panel as required.
- 3) To terminate load returns within the distribution cabinet, order List GA as required.
- 4) Order fuses as required per Table 28. Order replacement alarm fuses (1/4 A) per Table 29.
- 5) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 6) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 7) Order return and load bus bar assemblies per Table 7.



List AL: -48 VDC Distribution Panel (with Return Busbar) and List AN: -48 V Distribution Panel (without Return Busbar) (26) Bullet/TPS/TLS Circuit Breaker/Fuse Positions

### **Features**

- (26) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers, or accepts
   "Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block (P/N 549017)".
- ♦ List AL includes a return busbar; List AN does not include a return busbar.
- 600 A Maximum Capacity.

### Restrictions

Can be installed in any row 1-4 of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL per panel as required.
- 3) List AN: To terminate load returns within the distribution cabinet, order List GA as required.
- 4) Order circuit breakers as required per Table 23 or Table 24.
- 5) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 6) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 7) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 8) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 9) Order return and load bus bar assemblies per Table 8 for List AL or Table 9 for List AN.



<u>List AM: -48 VDC Distribution Panel (with Return Busbar) and List AP: -48 VDC Distribution Panel (without Return Busbar)</u>
(12) GJ/218 Circuit Breaker Positions

### **Features**

- (12) -48 VDC Load Distribution Circuit Breaker Mounting Positions:
   100 A to 800 A GJ/218 Type Circuit Breakers.
- ♦ Includes a return busbar
- 1600 A Maximum Capacity.
   Maximum current rating of each landing point is 360 A.

### Restrictions

Unless otherwise specified circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


Can be installed in any two adjacent bus rows 1-2, 2-3, or 3-4 of a 2-, 3-, or 4-row distribution cabinet.

List LL is not available in any row if the system is equipped with one or more List EA, List AM, or List AP.

Maximum lug width, 1.375 inches.

For an 800 A circuit breaker, continuous load must not exceed 600 A at 40°C ambient, 700 A at 30°C ambient.

- 1) Specify rows for panel location(s) (each List AM and AP requires two rows).
- 2) Order circuit breakers and associated jumper kits as required per Table 27.
- 3) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 4) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 5) Order return and load bus bar assemblies per Table 10 for List AM or Table 11 for List AP.



### System Application Guide

**Dual Voltage Distribution Panels** 

List DE: -48 VDC / +24 VDC Distribution Panel,

(22) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and

(4) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (22) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (4) +24 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum +24 VDC Distribution Capacity.

### **Restrictions**

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

Caution: 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



# List DF: -48 VDC / +24 VDC Distribution Panel,

(18) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and (8) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (18) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (8) +24 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum +24 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



# List DG: -48 VDC / +24 VDC Distribution Panel,

(14) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and (12) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (14) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (12) +24 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum +24 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



# List DH: -48 VDC / +24 VDC Distribution Panel,

(10) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and

# (16) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (10) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (16) +24 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum +24 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



# List DJ: -48 VDC / +24 VDC Distribution Panel,

(6) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and (20) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (6) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (20) +24 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum +24 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet with the following exception: cannot be installed in row 1 when an LVD contactor is installed in row 1.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



#### List DK: -48 VDC / +24 VDC Distribution Panel,

# (26) +24 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (26) +24 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- Includes a return busbar.
- 500 A Maximum +24 V Distribution Capacity.
   If reconfigured in the field; 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum +24 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 2-, 3-, or 4-row distribution cabinet. Not for use in List 21.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- 2) Order circuit breakers as required per Table 23 or Table 24.
- Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 4) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 5) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 6) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 7) Order return and load bus bar assemblies per Table 12.



# List FE: -48 VDC / -58 VDC Distribution Panel,

(22) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and (4) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (22) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (4) -58 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum -58 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- 1) Specify row for panel location(s).
- Order low voltage load disconnect List LL (for 48 V positions) as required.
- Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



#### List FF: -48 VDC / -58 VDC Distribution Panel,

(18) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and (8) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (18) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (8) -58 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum -58 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



#### List FG: -48 VDC / -58 VDC Distribution Panel,

(14) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and

(12) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (14) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (12) -58 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum -58 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- 1) Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



#### List FH: -48 VDC / -58 VDC Distribution Panel,

(10) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and

(16) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (10) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (16) -58 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum -58 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- 1) Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



#### List FJ: -48 VDC / -58 VDC Distribution Panel,

(6) -48 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar) and (20) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (6) -48 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   (20) -58 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- Includes a return busbar.
- 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum -58 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 1-, 2-, 3-, or 4-row distribution cabinet with the following exception: cannot be installed in row 1 when an LVD contactor is installed in row 1.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- 1) Specify row for panel location(s).
- 2) Order low voltage load disconnect List LL (for 48 V positions) as required.
- 3) Order circuit breakers as required per Table 23 or Table 24.
- 4) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 5) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 6) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 7) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 8) Order return and load bus bar assemblies per Table 8.



#### List FK: -48 VDC / -58 VDC Distribution Panel,

# (26) -58 VDC Bullet/TPS/TLS Circuit Breaker/Fuse Positions (with Return Busbar)

#### **Features**

- (26) -58 VDC Load Distribution Fuse / Circuit Breaker Mounting Positions:
   3 A to 100 A TPS/TLS Type Fuses,
   1 A to 300 A Bullet Nose Type Circuit Breakers.
- ♦ Includes a return busbar.
- 500 A Maximum -58 V Distribution Capacity.
   If reconfigured in the field; 600 A Maximum Total Capacity:
   600 A Maximum -48 VDC Distribution Capacity.
   500 A Maximum -58 VDC Distribution Capacity.

#### Restrictions

Cannot be used in a supplemental bay.

Limit two (2) dual voltage distribution panels per power system. If two dual voltage distribution panels are ordered, they must be mounted in adjacent rows. Maximum subsystem current capacity of the second panel is 255 A based on the cables that are provided to connect it to the first panel.

Can be installed in any row of a 2-, 3-, or 4-row distribution cabinet. Not for use in List 21.

Unless otherwise specified fuses and/or circuit breakers are mounted from left to right, starting with the highest capacity and working to the lowest capacity.


125 A, 150 A, 175 A, and 200 A circuit breakers occupy two mounting positions.

225 A, 250 A, and 300 A circuit breakers occupy three mounting positions.

<u>Caution:</u> 100 A circuit breakers and fuses can be used without a space provided the continuous operating current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker shall have an empty mounting position between it and any other overcurrent protective device.

Maximum lug width, 0.625 inches.

- 1) Specify row for panel location(s).
- 2) Order circuit breakers as required per Table 23 or Table 24.
- 3) Order fuses as required per Table 25. Also order one (1) P/N 117201 bullet nose type fuseholder per fuse ordered. Order replacement alarm fuses (18/100 A) per Table 29.
- 4) Order 6-position GMT fuse block P/N 549017 and fuses per Table 26 as required.
- 5) Order load lugs (two hole, 1/4" bolt clearance hole, 5/8" centers) as required for each distribution position per Table 52.
- 6) Order lug hardware kit (P/N 541084) as required. Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware (nuts, flat washers, and lock washers), enough for sixteen (16) lug landing points.
- 7) Order return and load bus bar assemblies per Table 12.



# **Battery Disconnect Distribution Panels**

<u>List BC: Battery Disconnect Distribution Panel (with Return Busbar) and List BD: Battery Disconnect Distribution Panel (without Return Busbar), (4) GJ/218 Circuit Breaker Battery Disconnect Positions</u>

#### **Features**

- (4) -48 VDC Battery Disconnect Circuit Breaker Mounting Positions: 100 A to 800 A GJ/218 Type Circuit Breakers.
- ♦ List BC Includes a return busbar; List BD does not include a return busbar.
- ♦ 600 A Maximum Capacity at 40°C ambient. 700 A Maximum Capacity at 30°C ambient. Maximum current rating of each landing point is 360 A.

#### Restrictions


Cannot be used with List 21.

Must be installed in top row only (limit one battery disconnect panel per distribution cabinet).

Maximum lug width, 1.375 inches.

For an 800 A circuit breaker, load must not exceed 600 A at 40°C ambient, 700 A at 30°C ambient.

- 1) Order circuit breakers and associated jumper kits as required per Table 27.
- 2) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 3) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 4) Order return and load bus bar assemblies per Table 13 for List BC. No return or load bus bars required for List BD.



# List BF: Battery Disconnect Distribution Panel,

# (2) TPH Fuse Battery Disconnect Positions (with Shunts) (without Return Busbar)

#### **Features**

- (2) -48 VDC Battery Disconnect Fuse Mounting Positions: 70 A to 600 A TPH Type Fuses.
- Includes shunts, 800 A / 25 mV. Each shunt is equipped with 10' jumpers for connection to monitoring device. If the
  system is equipped with an SM-DU+, the leads are trimmed and connected to the SM-DU+ (internal to the distribution
  cabinet).
- ♦ Does NOT include a return busbar.
- ♦ 1200 A Maximum Capacity.


# **Restrictions**

Cannot be used with List 21.

Must be installed in top row only (limit one battery disconnect panel per distribution cabinet).

Maximum lug width, 1.88 inches.

- 1) Order fuses as required per Table 28. Order replacement alarm fuses (1/4 A) per Table 29.
- 2) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 3) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 4) No return or load bus bars required.



# List BH: Battery Disconnect Distribution Panel,

# (4) TPH Fuse Battery Disconnect Positions (with Shunts) (without Return Busbar)

#### **Features**

- (4) -48 VDC Battery Disconnect Fuse Mounting Positions: 70 A to 400 A TPH Type Fuses.
- Includes shunts, 600 A / 25 mV. Each shunt is equipped with 10' jumpers for connection to monitoring device. If the system is equipped with an SM-DU+, the leads are trimmed and connected to the SM-DU+ (internal to the distribution cabinet).
- ♦ Does NOT include a return busbar.
- ♦ 1200 A Maximum Capacity.


# **Restrictions**

Cannot be used with List 21.

Must be installed in top row only (limit one battery disconnect panel per distribution cabinet).

Maximum lug width, 1.75 inches.

- 1) Order fuses as required per Table 28. Order replacement alarm fuses (1/4 A) per Table 29.
- 2) Order load lugs (two hole, 3/8" bolt clearance hole, 1" centers) as required for each distribution position per Table 53.
- 3) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 4) No return or load bus bars required.



# **Return Bar Panel**

# **List GA: Return Bar Panel**

# **Features**

- Return bar panel for use with distribution panels when internal load returns are required.
- ♦ 1200 A Maximum Capacity.


#### Restrictions

Cannot be used in a 1- row distribution cabinet.

Can be installed in any row 1-4 of a 2-, 3-, or 4-row distribution cabinet.

Maximum lug width, 1.38 inches.

- 1) Specify row for panel location(s).
- 2) To terminate load and/or battery returns within the distribution cabinet, order List GA as required.
- 3) Order lug hardware kit (P/N 548184) as required. Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware (bolts, flat washers, and lock washers), enough for eight (8) lug landing points.
- 4) Order return and load bus bar assemblies per Table 14.



# System Application Guide

# List EA: Bulk Output Panel

**Bulk Output Panel** 

# **Features**

- Provides a bulk output panel with five (5) landing points per polarity.
- ♦ 1600 A Maximum Capacity.


# Restrictions

Not available with List 21 (1-row cabinet).

 $List \ LL \ is \ not \ available \ in \ any \ row \ if \ the \ system \ is \ equipped \ with \ one \ or \ more \ List \ EA, \ List \ AM, \ or \ List \ AP.$ 

Maximum lug width, 2.0 inches.

- 1) Order as required.
- 2) Specify row for panel location(s).
- 3) Order return and load bus bar assemblies per Table 15.



	DI.	Panel		Load	Bar
DU Panel List	DU Cabinet Size	Installed in Row	Return Bar	W/O LVD	W/LVD
	1 Row	1	60022287 ASS'Y (548271 Busbar)	Included in DU Cabinet	Included in DU Cabinet
		2	60022299 ASS'Y (548273 Busbar)	60022304 ASS'Y (561773 Busbar)	60022462 ASS'Y (561988 Busbar)
	2 Row	1	60022287 ASS'Y (548271 Busbar)	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		3	60022300 ASS'Y (548274 Busbar)	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
	3 Row	2	60022288 ASS'Y (548272 Busbar)	60022303 ASS'Y (561881 Busbar)	60022461 ASS'Y (561878 Busbar)
AC		1	60022287 ASS'Y (548271 Busbar)	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		4	60022300 ASS'Y (548274 Busbar)	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
		3	60022299 ASS'Y (548273 Busbar)	60022304 ASS'Y (561773 Busbar)	60022463 ASS'Y (561509 Busbar)
	4 Row	2	60022288 ASS'Y (548272 Busbar)	60022302 ASS'Y (561772 Busbar)	60022460 ASS'Y (561508 Busbar)
		1	60022287 ASS'Y (548271 Busbar)	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)

Table 6

	DU	Panel		Load	d Bar
DU Panel List	Cabinet Size	Installed in Row	Return Bar	W/O LVD	W/LVD
	1 Row	1	No connection. No Busbar Req'd.	Included in DU Cabinet	Included in DU Cabinet
	0.5	2	No connection. No Busbar Req'd.	60022304 ASS'Y (561773 Busbar)	60022462 ASS'Y (561988 Busbar)
	2 Row	1	No connection. No Busbar Req'd.	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		3	No connection. No Busbar Req'd.	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
AD AE AU	3 Row	2	No connection. No Busbar Req'd.	60022303 ASS'Y (561881 Busbar)	60022461 ASS'Y (561878 Busbar)
AD, AF, AH		1	No connection. No Busbar Req'd.	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		4	No connection. No Busbar Req'd.	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
	/ D	3	No connection. No Busbar Req'd.	60022304 ASS'Y (561773 Busbar)	60022463 ASS'Y (561509 Busbar)
	4 Row	2	No connection. No Busbar Req'd.	60022302 ASS'Y (561772 Busbar)	60022460 ASS'Y (561508 Busbar)
		1	No connection. No Busbar Req'd.	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)

Table 7

		Panel		Load B	Bar
DU Panel List	DU Cabinet Size	Installed in Row	Return Bar	W/O LVD	W/LVD
	1 Row	1	548271 Busbar	Included in DU Cabinet	Included in DU Cabinet
	2.5	2	562507 ASS'Y (562501 Busbar)	60022304 ASS'Y (561773 Busbar)	60022462 ASS'Y (561988 Busbar)
	2 Row	1	562434 ASS'Y (561804 Busbar)	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
	3 Row	3	562432 ASS'Y (561802 Busbar)	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
AL, DE, DF, DG,		2	10142184 Busbar	60022303 ASS'Y (561881 Busbar)	60022461 ASS'Y (561878 Busbar)
DH, DJ, FE, FF, FG, FH, FJ		1	562434 ASS'Y (561804 Busbar)	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		4	562432 ASS'Y (561802 Busbar)	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
	4 Row	3	562435 ASS'Y (562352 Busbar)	60022304 ASS'Y (561773 Busbar)	60022463 ASS'Y (561509 Busbar)
	4 ROW	2	562433 ASS'Y (561803 Busbar)	60022302 ASS'Y (561772 Busbar)	60022460 ASS'Y (561508 Busbar)
		1	562434 ASS'Y (561804 Busbar)	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)

Table 8

		Panel		Loa	d Bar
DU Panel List	DU Cabinet Size	Installed in Row	Return Bar	W/O LVD	W/LVD
	1 Row	1	No connection. No Busbar Req'd.	Included in DU Cabinet	Included in DU Cabinet
	2 Row	2	No connection. No Busbar Req'd.	60022304 ASS'Y (561773 Busbar)	60022462 ASS'Y (561988 Busbar)
		1	No connection. No Busbar Req'd.	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		3	No connection. No Busbar Req'd.	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
	3 Row	2	No connection. No Busbar Req'd.	60022303 ASS'Y (561881 Busbar)	60022461 ASS'Y (561878 Busbar)
AN		1	No connection. No Busbar Reg'd.	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)
		4	No connection. No Busbar Req'd.	60022306 ASS'Y (561774 Busbar)	60022464 ASS'Y (561510 Busbar)
		3	No connection. No Busbar Req'd.	60022304 ASS'Y (561773 Busbar)	60022463 ASS'Y (561509 Busbar)
	4 Row	2	No connection. No Busbar Req'd.	60022302 ASS'Y (561772 Busbar)	60022460 ASS'Y (561508 Busbar)
		1	No connection. No Busbar Req'd.	60022301 ASS'Y (562822 Busbar)	60022459 ASS'Y (548351 Busbar)

Table 9

		Panel		Load Bar		
DU Panel List	DU Cabinet Size	Installed in Rows	Return Bar	W/O LVD	W/LVD	
	2 Row	1 and 2	562449 ASS'Y (562406 Busbar)	562443 ASS'Y (562400 Busbar)	Not Available	
	3 Row	2 and 3	562448 ASS'Y (562405 Busbar)	562447 ASS'Y (562404 Busbar)	Not Available	
		1 and 2	10032382 ASS'Y (10032379 Busbar)	10032384 ASS'Y (10032383 Busbar)	Not Available	
АМ	4 Row	3 and 4	562444 ASS'Y (562401 Busbar)	562441 ASS'Y (562398 Busbar)	Not Available	
		2 and 3	562445 ASS'Y (562402 Busbar)	562442 ASS'Y (562399 Busbar)	Not Available	
		1 and 2	562446 ASS'Y (562403 Busbar)	562443 ASS'Y (562400 Busbar)	Not Available	

Table 10

DU Panel	DU Cabinet	Panel	Return Bar	Load Bar		
List	Size	Installed in	Return Bar	W/O LVD	W/LVD	
	2 Row	1 and 2	No connection. No Busbar Req'd.	562443 ASS'Y (562400 Busbar)	Not Available	
		2 and 3	No connection. No Busbar Req'd.	562447 ASS'Y (562404 Busbar)	Not Available	
4.5	3 Row	1 and 2	No connection. No Busbar Req'd.	10032384 ASS'Y (10032383 Busbar)	Not Available	
AP		3 and 4	No connection. No Busbar Req'd.	562441 ASS'Y (562398 Busbar)	Not Available	
	4 Row	2 and 3	No connection. No Busbar Req'd.	562442 ASS'Y (562399 Busbar)	Not Available	
		1 and 2	No connection. No Busbar Req'd.	562443 ASS'Y (562400 Busbar)	Not Available	

Table 11

DII Donal I !	DII Cabinat Ci-	Panel	Deturn Ber	Load E	Bar
DU Panei List	DU Cabinet Size	Installed in	Return Bar	W/O LVD	W/LVD
			562507 ASS'Y	No connection.	No connection.
	2 Row	2	(562501 Busbar)	No Busbar Req'd.	No Busbar Req'd.
			562434 ASS'Y	No connection.	No connection.
		1	(561804Busbar)	No Busbar Req'd.	No Busbar Req'd.
			562432 ASS'Y	No connection.	No connection.
		3	(561802 Busbar)	No Busbar Req'd.	No Busbar Req'd.
	3 Row	2	562433 ASS'Y	No connection.	No connection.
			(561803 Busbar)	No Busbar Req'd.	No Busbar Req'd.
517 517		1	562434 ASS'Y	No connection.	No connection.
DK, FK			(561804 Busbar)	No Busbar Req'd.	No Busbar Req'd.
			562432 ASS'Y	No connection.	No connection.
		4	(561802 Busbar)	No Busbar Req'd.	No Busbar Req'd.
			562435 ASS'Y	No connection.	No connection.
	<b>4.</b> D.	3	(562352 Busbar)	No Busbar Req'd.	No Busbar Req'd.
	4 Row		562433 ASS'Y	No connection.	No connection.
		2	(561803 Busbar)	No Busbar Req'd.	No Busbar Req'd.
		1	562434 ASS'Y (561804 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.

Table 12

DII Damal I iat	DU Cabinet	Panel	Return Bar	Load Bar		
DU Panel List	Size	Installed in		W/O LVD	W/LVD	
			60022299 ASS'Y	No connection.	No connection.	
	2 Row	2	(548273 Busbar)	No Busbar Req'd.	No Busbar Req'd.	
		1		Not Available		
		3	60022300 ASS'Y	No connection.	No connection.	
	0.5		(548274 Busbar)	No Busbar Req'd.	No Busbar Req'd.	
ВС	3 Row	2		Not Available		
		1	Not Available			
			60022300 ASS'Y	No connection.	No connection.	
		4	(548274 Busbar)	No Busbar Req'd.	No Busbar Req'd.	
	4 Row	3		Not Available		
		2		Not Available		
		1		Not Available		

Table 13

DU Panel	DU Cabinet	Panel	D.J D	Load	l Bar
List Size	Installed in	Return Bar	W/O LVD	W/LVD	
	2 Row 3 Row 4 Row	2	60022299 ASS'Y (548273 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		1	60022287 ASS'Y (548271 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		3	60022300 ASS'Y (548274 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		2	60022288 ASS'Y (548272 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
GA		1	60022287 ASS'Y (548271 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		4	60022300 ASS'Y (548274 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		3	60022299 ASS'Y (548273 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		2	60022288 ASS'Y (548272 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.
		1	60022287 ASS'Y (548271 Busbar)	No connection. No Busbar Req'd.	No connection. No Busbar Req'd.

Table 14

DU Panel	DU Panel DU Cabinet	Panel	D.1 D	Load	d Bar
List Size	Installed in	Return Bar	W/O LVD	W/LVD	
		2	562470 ASS'Y (562454 Busbar)	562474 ASS'Y (562458 Busbar)	Not Available
	2 Row	1	562472 ASS'Y (562456 Busbar)	562476 ASS'Y (562460 Busbar)	Not Available
		3	562469 ASS'Y (562453 Busbar)	562473 ASS'Y (562457 Busbar)	Not Available
3 Row	2	562477 ASS'Y (562468 Busbar)	562452 ASS'Y (562864 Busbar)	Not Available	
	1	562472 ASS'Y (562456 Busbar)	562476 ASS'Y (562460 Busbar)	Not Available	
		4	562469 ASS'Y (562453 Busbar)	562473 ASS'Y (562457 Busbar)	Not Available
4 Row	3	562470 ASS'Y (562454 Busbar)	562474 ASS'Y (562458 Busbar)	Not Available	
	2	562471 ASS'Y (562455 Busbar)	562475 ASS'Y (562459 Busbar)	Not Available	
		1	562472 ASS'Y (562456 Busbar)	562476 ASS'Y (562460 Busbar)	Not Available

Table 15

# **Battery Disconnect Contactors**

# **List CA: 600 A Battery Disconnect Contactor**

#### **Features**

Provides a battery disconnect contactor which is mounted within the main bay distribution cabinet.

# **Restrictions**

Main bay only.

Must be used with List LB, MB, or both.

For use with List 21 only.

Can only use LVLD or LVBD on List 21, not both.

# **Ordering Notes**

1) Order as required.

# List CB: 1200 A Battery Disconnect Contactor

# **Features**

• Provides a battery disconnect contactor which is mounted within the main bay distribution cabinet.

# **Restrictions**

Main bay only.

Must be used with List LB, MB, or both.

For use with List 22, 23, or 24 only.

If used in List 23 or 24, system capacity is reduced to 1200 A.

# **Ordering Notes**

1) Order as required.

# List CC: 2000 A Battery Disconnect Contactor

# **Features**

• Provides a battery disconnect contactor which is mounted within the main bay distribution cabinet.

# **Restrictions**

Main bay only.

Must be used with List LB, MB, or both.

For use with List 22, 23, or 24 only.

# **Ordering Notes**

1) Order as required.

# **Low Voltage Disconnect Options**

# List LB: Low Voltage Battery Disconnect (LVBD)

#### **Features**

- Adds Low Voltage Battery Disconnect (LVBD) to the system.
- Adds LVD Driver circuit card P/N 563696 or LVD Driver Lite circuit card P/N 547873 to the main bay distribution cabinet.

#### Restrictions

Must be used with List CA, CB, or CC.

Installed in main bay only.

# **Ordering Notes**

- 1) Order if low voltage battery disconnect (LVBD) is required.
- 2) Can be combined with manual battery disconnect (List MB) if required.

# List LL: Low Voltage Load Disconnect (LVLD)

#### **Features**

- Adds low voltage load disconnect (LVLD) to a distribution panel.
- Adds LVD Driver circuit card P/N 563696 (main bay) / 563718 (supplemental bay) or LVD Driver Lite circuit card P/N 547873 (main bay) / 547874 (supplemental bay) to a distribution cabinet, one per distribution cabinet.

# **Restrictions**

Must be used with List AC through AL, AN, DE through DJ. Not available with Lists AM, AP, DK or EA.

In a List 22, List 23, List 24; the List LL Low Voltage Load Disconnect (LVLD) option cannot be installed in the field for systems that are not equipped with any LVLD's from the factory. Field replacement of factory installed LVLD contactors is still available.

Cannot use List LL in row 1 if row 1 is equipped with List DJ.

Capacity is reduced to 500 amps for any row equipped with List LL.

# **Ordering Notes**

1) Order low voltage load disconnect (LVLD) per load distribution panel (one per row) as required. Specify by row.

# **Manual Battery Disconnect Option**

# **List MB: Manual Battery Disconnect**

# **Features**

- Adds manual battery disconnect to the system.
- Adds manual disconnect circuit card P/N 540973 to the system.


# **Restrictions**

Must be used with List CA, CB, or CC.

Installed in main bay only.

If this option is to be used as a Maintenance Battery Disconnect only, at least one rectifier requires to be active and providing voltage to the system for proper operation.

- 1) Order if manual battery disconnect is required.
- 2) Can be combined with low voltage battery disconnect (List LB) if required.



# **ACCESSORY DESCRIPTIONS**

# Controller

# NCU Controller, P/N 1M830DNA or 1M830BNA

#### **Features**

- Provides the system controller.
- Factory programmed with the configuration file required for the system configuration ordered.

Note: For custom NCU configurations, contact Vertiv.

# **Restrictions**

Only one (1) controller per power system is required.

Mounts in the main bay (List 1) distribution cabinet or module mounting shelf (List 600, 601, 900, 901).

Cannot be installed in a List 2, List 3, List 5, List 7, or List 8 supplemental bay.


# **Ordering Notes**

- Order one (1) controller (P/N 1M830DNA) with the desired configuration for use with List 1.
- Order one (1) NCU controller (P/N 1M830BNA) with the desired configuration for use with Lists 600, 601, 900, and 901.
- Ordering an NCU for replacing an NCU or as a spare NCU.

If the NCU is to be used as a replacement in a specific system, it should be ordered with the same configuration file as the original NCU controller. This is identified by a six-digit number. If the controller part number ends with a six-digit number, for example, 1M830BNA559242, the configuration file number is the last six characters. If the part number does not have these characters, the configuration file number can be found on the controller nameplate – "Programmed with Configuration File ######". The controller may also have a Unique Identification Number (UIN). This number indicates that certain parameters were set at the factory to match the controller to the options selected with the power plant (such as low voltage disconnect, load and battery shunt ratings, etc.). If the controller has a UIN, the plant will have shipped with a USB drive labelled with the UIN. The UIN label may also be located near the controller slot in the system. If the controller has a UIN, provide this UIN number, along with the configuration number, when ordering so that the new controller will match that of the original controller shipped with the system. The user manual provided with the controller provides instructions for replacing and programming the controller. It is important to follow these instructions carefully. The user manual also provides instructions for saving certain controller files that are created when changes are made to the system after leaving the factory. These files can be programmed into the replacement controller so it can match the latest saved state of the original controller.

If the NCU is being ordered as a spare part for any of a group of power plants, the same procedure can be followed. If the replacement controller's configuration does not match that of the original controller, the original files can be retrieved from the USB drive shipped with the plant, if available. If the USB drive is not available, contact the factory or technical assistance center to obtain a copy of the original configuration file (all package) so it can be programmed into the new controller.

The NCU programming files are unique to the NCU. Files from an SCU+ or ACU+ are not compatible with the NCU and MUST NOT BE loaded into an NCU.





# **NCU Controller 2nd Ethernet Port Kits**

#### NCU Controller 2nd Ethernet Port Add-On Kit, P/N 559252

# **Features**

• Provides the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

#### Restrictions

For use only with NCU controller, not the ACU+ controller. Factory installed in a main bay if initially ordered with the power system. Field installable only into a main bay if initially ordered with the NCU controller.

Not for use in List 100, 101, 102, 203, 500, 501, 502, 503, 600, 601, 900, 901 (2nd Ethernet port is factory provided).

# **Ordering Notes**

 If a second Ethernet port is required, order kit P/N 559252. For field upgrade of systems originally configured with the ACU+ controller, order kit P/N 559251. The field upgrade must also include the NCU controller replacing the ACU+ controller.

#### NCU Controller 2nd Ethernet Port Retrofit Kit, P/N 559251

#### **Features**

- ♦ Provides a complete control module assembly that allows an IB4 board to be connected to the NCU in an older main bay.
- Provides the IB4 board with a second Ethernet port. The Ethernet port located on the NCU Controller's front panel can be used to connect a computer directly to the NCU. The Ethernet port located on the IB4 board can be used to connect the NCU to your Local Area Network (LAN).

#### Restrictions

Field installable only into a main bay if initially ordered with the ACU+ controller. The field upgrade must also include the NCU controller replacing the ACU+ controller.

Not for use in List 100, 101, 102, 203, 500, 501, 502, 503, 600, 601, 900, 901 (2nd Ethernet port is factory provided).

# **Ordering Notes**

1) For field upgrade of systems originally configured with the ACU+ controller, order kit P/N 559251. The field upgrade must also include the NCU controller replacing the ACU+ controller.

# Optional Second IB2 (Controller Interface Board), P/N 555286 or MA4C5U31

# **Features**

- Provides connections for up to two (2) temperature probes.
- Provides connections for the eight (8) programmable form C- relay outputs located on the board.
- Provides connections for the eight (8) programmable binary digital inputs located on the board.

Note: An IB2 (Controller Interface Board) is factory provided with the system. The IB2 provides eight (8) programmable form C- relay outputs, eight (8) programmable binary digital inputs and two (2) temperature inputs.


#### Restrictions

A second IB2 or EIB controller interface board requires an NCU not an ACU+. The system can contain only three (3) interface boards, (1) IB2 and (2) EIB or (2) IB2 and (1) EIB.

Must be installed in the main bay.

Not available for List 600, 601, 900, 901.

- 1) Order a second optional IB2 Interface Board Assembly (P/N 555286 for List 1 or MA4C5U31 for Lists 100, 101, 102, 203, 500, 501, 502, and 503) per system as required. Also, order up to two (2) additional temperature probes, as desired.
- 2) Refer to "In-Line Fuse and Resistor Pigtail Kits" on page 103 for in-line resistor pigtails for use with shunt inputs and inline fuse for sure with battery midpoint inputs.



# Optional EIB-1 and EIB-2 (Controller Extended Interface Board) (P/N 548120, MA455U41, and SXK2300238/1)

# **Features**

- ♦ Provides connections for up to two (2) temperature probes.
- Provides connections for the five (5) programmable form C- relay outputs located on the board.
- Provides connections for the three (3) shunt inputs located on the board. Shunts must be installed in the hot (-48V) bus.
- Provides connections for the eight (8) battery midpoint inputs located on the board.

#### **Restrictions**

A List 1, 100, 101, 102, 203, 500, 501, 502, 503 system can contain only three (3) interface boards, (1) IB2 and (2) EIB or (2) IB2 and (1) EIB.

**Note:** A second IB2 or EIB controller interface board requires an NCU not an ACU+. The optional second EIB must be installed in the main bay.

A second EIB cannot be installed in a List 600, 601, 900, 901 system.

# **Ordering Notes**


- List 1: Order a second and/or first optional EIB Extended Interface Board Assembly. Order by P/N 548120 as required.
- List 100, 101, 102, 203, 500, 501, 502, 503: Order a second optional EIB Extended Interface Board Assembly. Order by P/N MA455U41 as required.
- 3) List 600, 601, 900, 901: Order a second and/or first optional EIB Extended Interface Board Assembly. Order by P/N SXK2300238/1 as required.
- 4) Also order up to two (2) additional temperature probes, as desired. See "Optional Temperature Probes".
- 5) Refer to "In-Line Fuse and Resistor Pigtail Kits" on page 103 for in-line resistor pigtails for use with shunt inputs and inline fuse pigtails for use with battery midpoint inputs.


# Optional SM-DU+ Shunt Monitoring, P/N 548078

#### **Features**

♦ Provides twenty-five (25) shunt monitoring inputs. Shunts must be installed in the hot (-48V) bus.

- Order optional SM-DU+ Shunt Monitoring for any fuse panel with shunts (Lists AF, AH, BF, or BH) or any GJ/218 panels (Lists AC, AD, BC, BD, AM, or AP) that are equipped with shunted breakers. (The SM-DU+ is factory-wired to the shunts.) Order by P/N 548078 as required.
- Refer to "In-Line Fuse and Resistor Pigtail Kits" on page 103 for inline resistor pigtails for use with shunt inputs and in-line fuse pigtails for use with battery midpoint inputs.





# In-Line Fuse and Resistor Pigtail Kits

In-line fuse kits should be used for connecting to battery or bus potentials for use with the digital inputs on the IB2 Interface Board and the battery midpoint/block voltage inputs on the EIB Extended Interface Board. In-line resistor kits should be used for connecting to shunts for use with the EIB Extended Interface Board and SMDU+ Shunt Interface Board.

# 1 A In-Line Fuse Pigtail Kit, P/N 431300200

# **Features**

♦ In-line fuse pigtail kit with 3/8" ring lug.

# **Ordering Notes**

1) Order Kit P/N 431300200, as required.

# 1 A In-Line Fuse Pigtail Kit, P/N 431300300

# **Features**

♦ In-line fuse pigtail kit with 5/16" ring lug.

# **Ordering Notes**

1) Order Kit P/N 431300300, as required.

# 1 A In-Line Fuse Pigtail Kit, P/N 535135

#### **Features**

♦ In-line fuse pigtail kit with a splice connector, 3/8" ring lug, and 1/4" ring lug.

# **Ordering Notes**

1) Order Kit P/N 535135, as required.

# 49.9 Ohm In-Line Resistor Pigtail Kit, P/N 424227900

# **Features**

♦ In-line resistor pigtail kit with 3/8" ring lug.

# **Ordering Notes**

1) Order Kit P/N 424227900, as required.

# 49.9 Ohm In-Line Resistor Pigtail Kit, P/N 424228000

# **Features**

♦ In-line resistor pigtail kit with a splice connector.

# **Ordering Notes**

1) Order Kit P/N 424228000, as required.

# 49.9 Ohm In-Line Resistor Pigtail Kit, P/N 424228100

#### **Features**

♦ In-line resistor pigtail kit with 3/16" (#10) ring lug.

# **Ordering Notes**

1) Order Kit P/N 424228100, as required.

# **Optional Temperature Probes**


# **Features**

- ♦ Up to two (2) temperature probes can be connected to each IB2 (Controller Interface Board). Up to two (2) temperature probes can be connected to each EIB (Controller Extended Interface Board). Up to two (2) temperature probes can be connected to the System Interface Board (List 100, 101, 102, 203, 500, 501, 502, 503 only). Any combination of the temperature probes can be programmed to monitor ambient temperature and/or battery temperature. A temperature probe set to monitor battery temperature can also be used for the rectifier battery charge temperature compensation feature, or the battery charge temperature compensation feature can be programmed to use the average or highest value of all battery temperature probes. The battery charge temperature compensation feature allows the controller to automatically increase or decrease the output voltage of the system to maintain battery float current as battery temperature decreases or increases, respectively. Battery life can be extended when an optimum charge voltage to the battery with respect to temperature is maintained. A temperature probe set to monitor battery temperature can also be used for the BTRM (Battery Thermal Runaway Management) feature. The BTRM feature lowers output voltage when a high temperature condition exists to control against battery thermal runaway.
- ♦ The temperature sensor end of the probe contains a tab with a 5/16" clearance hole for mounting.
- ◆ Temperature probes can also be used with the optional <u>SM-Temp Temperature Concentrator</u>.

#### Restrictions

A temperature probe programmed to monitor battery temperature should be mounted on the negative post of a battery cell to sense battery temperature. A temperature probe used for battery charge temperature compensation or BTRM (Battery Thermal Runaway Management) should also be mounted on the negative post of a battery cell. A temperature probe programmed to monitor ambient temperature should be mounted in a convenient location, away from direct sources of heat or cold.

- 1) Order temperature probes as required. Note that each temperature probe consists of two or three pieces which plug together to make a complete probe (see the following illustration). For a complete temperature probe, order one (1) P/N 552992 (10.3 meters) or one (1) P/N 556155 (3.3 meters). If additional length is required, order temperature probe extension cable P/N 04119122 (10 meters).
- 2) If more probes are desired, order one or more SM-Temp Temperature Concentrator, P/N 547490. See SM-Temp Temperature Concentrator.



# Optional SM-Temp Temperature Concentrator, P/N 547490

#### **Features**

- Allows for multiple temperature probes to be used for ambient temperature monitoring, battery temperature monitoring, temperature compensation, and/or BTRM (Battery Thermal Runaway Management).
- Provides (8) temperature probe inputs per SM-Temp unit.
- Can cascade up to (8) SM-Temp units, connecting up to sixty-four (64) temperature probes.
- ◆ The SM-Temp Concentrator is connected at the end of the Controller's CAN Bus. Via the CAN Bus, the controller reads each temperature probe from each SM-Temp Concentrator.
- Refer to the SM-Temp Temperature Concentrator Instructions (UM547490) for more information.



Requires ACU+ version 3.02 or later when SM-Temp is connected into the ACU+ CAN Bus.

# **Ordering Notes**

- 1) Order SM-Temp Temperature Concentrator, P/N 547490, as required.
- 2) Order up to (8) temperature probes for each concentrator. See "Optional Temperature Probe" above.
- 3) Order one (1) SM-Temp CAN Bus Interface Cable, P/N 562868, to connect the SM-Temp into the controller's CAN bus.
- 4) Order SM-Temp jumpers (P/N 552888) to interconnect SM-Temp units, as required. See "SM-Temp Jumpers, P/N 552888" on page 106.


# SM-Temp Jumpers, P/N 552888

# **Features**

 Provides 20' of 18 AWG solid red / black twisted pair cable and three (3) wire splices for connecting the CAN bus of multiple SM-Temp modules together.

# **Ordering Notes**

1) Order P/N 552888 as required.



# **Rectifiers**

# Rectifier Module, P/N 1R483500E3

# **Features**

- Provides one (1) Model R48-3500E3, Spec. No. 1R483500E3, 3500 watt / -48 volt rectifier module.
- Refer to the Rectifier Instructions (UM1R483500E3) for more information.

#### Restrictions

For use in Spec. No. 588705400 module mounting assembly.

#### **Ordering Notes**

1) Order by P/N 1R483500E3 as required. Each Spec. No. 588705400 module mounting assembly holds up to six (6) rectifier modules (except the first shelf in a List 600, 601, 900, 901 which holds up to five (5) rectifier modules).

# Rectifier Module, P/N 1R482000E3

#### **Features**

- Provides one (1) Model R48-2000E3, Spec. No. 1R482000E3, 2000 watt / -48 volt rectifier module.
- Refer to the Rectifier Instructions (UM1R482000E3) for more information.

# **Restrictions**

For use in Spec. No. 588705300 module mounting assembly.

# **Ordering Notes**

 Order by P/N 1R482000E3 as required. Each Spec. No. 588705300 module mounting assembly holds up to six (6) rectifier modules.

# Rectifier Module, P/N 1R483600E4

# **Features**


- Provides one (1) Model R48-3600E4, Spec. No. 1R483600E4, 3650 watt / -48 volt rectifier module.
- Refer to the Rectifier Instructions (UM1R483600E4) for more information.

# Restrictions

For use in Spec. No. 588705400 module mounting assembly.

# **Ordering Notes**

 Order by P/N 1R483600E4 as required. Each Spec. No. 588705400 module mounting assembly holds up to six (6) rectifier modules.



# Rectifier Module, P/N 1R483500E

# **Features**


- Provides one (1) Model R48-3500E, Spec. No. 1R483500E, 3500 watt / -48 volt rectifier module.
- ♦ Refer to the Rectifier Instructions (UM1R483500E) for more information.

# **Restrictions**

For use in Spec. No. 588705000 module mounting assembly Lists 21, 22, 31, 32, 33.

#### **Ordering Notes**

 Order by P/N 1R483500E as required. Each Spec. No. 588705000 module mounting assembly holds up to six (6) rectifier modules.



# Rectifier Module, P/N 1R484000E

# **Features**


- Provides one (1) Model R48-4000E, Spec. No. 1R484000E, 4000 watt / -48 volt rectifier module.
- Refer to the Rectifier Instructions (UM1R483500E) for more information.

# Restrictions

For use in Spec. No. 588705500 module mounting assembly Lists 01, 02, 03, 04, 05.

# **Ordering Notes**

1) Order by P/N 1R484000E as required. Each Spec. No. 588705500 module mounting assembly holds up to six (6) rectifier modules.



# Converters

## -48 VDC to +24 VDC Converter Module, P/N 1C48241500

#### **Features**

- Provides one (1) Model C48/24-1500, Spec. No. 1C48241500, 1500 watt / -48 V to +24 V converter module.
- ♦ Refer to the Converter Instructions (UM1C48241500) for more information.

#### Restrictions

For use in Spec. No. 588705300 module mounting assembly.

Converters can be installed in main bay only.

Use with List 60, List 100, List 101, List 102, or List 203.

#### **Ordering Notes**

1) Order by P/N 1C48241500 as required. Each Spec. No. 588705300 module mounting assembly holds up to three (3) converter modules (far right three mounting positions as viewed from the front).

#### -48 VDC to -58 VDC Converter Module, P/N 1C48582000P3

#### **Features**

- Provides one (1) Model C48/58-2000P3, Spec. No. 1C48582000P3, 2000 watt peak, 1600 watt average / -48 V to -58 V converter module.
- ♦ Refer to the Converter Instructions (UM1C48582000P3) for more information.



For use in Spec. No. 588705300 module mounting assembly and List 930 or List 931 configurations.

Converters can be installed in main bay only.

Use with List 62, List 500, List 501, List 502, List 503, List 930, or List 931.

## **Ordering Notes**

1) Order by P/N 1C48582000P3 as required. Each Spec. No. 588705300 module mounting assembly holds up to three (3) converter modules (far right three mounting positions as viewed from the front). Each converter shelf in Lists 930 and 931 configurations holds up to six (6) converter modules.

#### -48 VDC to -58 VDC Converter Module, P/N 1C48583750P4 (Lists 930 or 931)

## **Features**

- Provides one (1) Model C48/58-3750P4, Spec. No. 1C48583750P4, 3750 watt peak, 3000 watt average / -48 V to -58 V converter module.
- Refer to the Converter Instructions (UM1C48583750P4) for more information.

## **Restrictions**


For use in Spec. No. 588705300 module mounting assembly and List 930 and 931 configurations.


Converters can be installed in main bay only.

Use with List 930 or List 931.

## Ordering Notes

1) Order by P/N 1C48583750P4 as required. Each Spec. No. 588705300 module mounting assembly holds up to three (3) converter modules (far right three mounting positions as viewed from the front). Each converter shelf in Lists 930 and 931 configurations holds up to six (6) converter modules.





#### **Inverters**


## Inverter Module, P/N 1l1201000

#### **Features**

- Model I120-1000, Spec. No. 111201000,
   120 VAC, 1kVA/1kW at 40 °C and 120 VAC / 0.5 kVA at 65 °C inverter module.
- Refer to the Inverter Instructions (UM1I1201000) for more information.

#### **Ordering Notes**

1) Order by P/N 1l1201000 as required.



## **Module Mounting Position Blank Cover Panels**

## Module Mounting Position Blank Cover Panel, P/N 21140440

#### **Features**

♦ Covers one (1) unused module mounting position.

#### Restrictions

For use in Spec. No. 588705000 and 588705500 module mounting assembly.

## **Ordering Notes**

1) Order by P/N 21140440 as required. Order a module mounting position blank cover panel for each empty module mounting position in the system, as desired.



## Module Mounting Position Blank Cover Panel, P/N SXA1100035/1

#### **Features**


♦ Covers one (1) unused module mounting position.

## **Restrictions**

For use in Spec. No. 588705300 and 588705400 module mounting assemblies and in optional inverter system.

## **Ordering Notes**

1) Order by P/N SXA1100035/1 as required. Order a module mounting position blank cover panel for each empty module mounting position in the system, as desired.



## Optional +27 VDC Vertiv™ eSure™ Bullet Converter Kit, P/N 60147273

#### **Features**

The +27 VDC Vertiv™ eSure™ Bullet Converter (Model C48/27-375B, Spec. No. 1C4827375B) is a compact DC/DC converter unit which offers efficient power conversion. It operates from a nominal -48 VDC source to provide up to 375 W at 40 °C and 300 W at 65 °C, regulated +27 VDC to the load for continuous operation to end of battery discharge. Refer to UM60147273, and IM565939 for further information.

#### **Restrictions**

Only install the power extend converter into a -48 VDC distribution position. Non-repairable damage will occur if the power extend converter is plugged into a +24 VDC distribution position.

It is recommended to install the +27 VDC Vertiv™ eSure™ Bullet Converter in the right side of the distribution panel on the side of the panel opposite from where the larger breakers are recommended to be installed to minimize heat concentration.

Up to three (3) converters can be paralleled together for a total output power of 750 W at 40 °C and 600 W at 65 °C. Requires a Power Extend Converter Mounting kit.

- To add a +27 VDC Vertiv™ eSure™ Bullet Converter to a bullet distribution panel order up to three (3) 60147273 converter kits, a 60016097 two-pole, 545346DCP three-pole, 10078650 four-pole or 10078651 five-pole paralleling busbar, an optional 10062803 +27 VDC Bullet Nose 6-Position GMT Fuse Board Kit and the appropriate Power Extend Converter Mounting Kit. Refer to the UM60147273 bullet converter user manual to determine the appropriate mounting kit.
- 2) If one or more +27V bullet converters are to be used, order one (1) mounting kit P/N 60171745 per system.

## Optional eSure™ Power Extend Converter

#### **Features**

The eSure Power Extend Converter (Model C48/58-1000B, Spec. No. 1C48581000B) is a compact DC/DC converter unit which offers efficient power conversion. It operates from a nominal -48 VDC source to provide regulated -58 VDC to the load for continuous operation to end of battery discharge. Refer to UM565050 and IM565391 for further information.

#### **Restrictions**

Only install the power extend converter into a -48 VDC distribution position. Non-repairable damage will occur if the power extend converter is plugged into a +24 VDC distribution position.

## **Ordering Notes**

1) To add an eSure Power Extend Converter to a List AA (24-position bullet) distribution panel or List DA, DB, DC, DD (21-position bullet dual voltage) distribution panel or 582127000 List DE, DF, DG, DH, DJ, DK, FE, FG, FH, FJ, FK (26-position bullet dual voltage) distribution panel; refer to the material list in the eSure Power Extend Converter Calculator (link provided below).

Ø

0

- 2) To add an eSure Power Extend Converter to a List AL (26-position bullet) distribution panel; refer to the material list in the eSure Power Extend Converter Calculator (link provided below).
- 3) To add an eSure Power Extend Converter to a 582127000600, 582127000601, 582127000900, 582127000901 (26-position bullet) distribution panel; refer to the material list in the eSure Power Extend Converter Calculator (link provided below)

 $\frac{https://www.vertiv.com/en-us/products-catalog/critical-power/dc-power-systems/esure-power-extend-converter-c4858-1000/\#/downloads}{1000/\#/downloads}$ 

## **Module Mounting Assembly**

## 588705300 List 01:

Module Mounting Assembly Configured with Rectifier and -48 VDC to +24 VDC or -48 VDC to -58 VDC Converter Module Mounting Positions, 208 VAC, 240 VAC Input, No Rear Covers, and Factory Input Wiring Only

## **Features**

- Provides one (1) Model PSS48/250-23C, Spec. No. 58870530001 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- No output busbar cover assembly and input cover assembly provided. Rear covers will be provided as part of the factory configured system.

#### Restrictions

Module mounting assembly inputs MUST be factory wired into power system. For use with Lists 40, 41, and 42 front access AC input termination assemblies.

- Order as required.
- 2) Order rectifier modules as required, P/N 1R482000E3.
- 3) Order converter modules as required, P/N 1C48241500.
- 4) Order converter modules as required, P/N 1C48582000P3.
- 5) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

System Application Guide

#### 588705300 List 03:

Module Mounting Assembly Configured with Rectifier and -48 VDC to +24 VDC or -48 VDC to -58 VDC Converter Module Mounting Positions, 208 VAC, 240 VAC Input, Single Phase, Rear Covers, and Rear Mount Molex Input Connectors

#### **Features**

- Provides one (1) Model PSS48/250-23C, Spec. No. 58870530003 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

**Note:** Three (3) rectifier input Molex connectors furnished and factory wired to provide three (3) rectifier input feeds to the assembly. First rectifier input feeds rectifier mounting positions #1 and #2. Second rectifier input feeds rectifier mounting positions #3 and #4. Third rectifier input feeds rectifier mounting positions #5 and #6.

#### **Restrictions**

AC inputs MUST be wired directly to the shelf.

## **Ordering Notes**

- 1) Order as required.
- 2) Order rectifier modules as required, P/N 1R482000E3.
- 3) Order converter modules as required, P/N 1C48241500.
- 4) Order converter modules as required, P/N 1C48582000P3.
- 5) Order rectifier AC input cable assemblies per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 or order rectifier AC input line cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 6) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

#### 588705300 List 61:

## Converter Module Mounting Assembly for Six (6) -48 VDC to -58 VDC Converter Positions

## **Features**

- Provides one (1) Model PSS48/5852-1/23, Spec. No. 58870530061 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) DC-DC converter modules.
- No input busbar, output busbar and rear cover assembly provided. These are provided as part of the factory configured system.

#### **Restrictions**

Module mounting assembly inputs and outputs MUST be factory assembled busbars. For use with List 930 or List 931.

- Provided as part of List 930, 931.
- 2) Order converter modules as required, P/N 1C485820000P3 and P/N 1C48583750P4.
- 3) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

System Application Guide

#### 588705400 List 01:

## Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No Rear Covers, and Factory Input Wiring Only

#### **Features**

- Provides one (1) Model PSS4850-1/23, Spec. No. 58870540001 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- No output busbar cover assembly and input cover assembly provided. Rear covers will be provided as part of the factory configured system.

#### **Restrictions**

Module mounting assembly inputs MUST be factory wired into power system. For use with Lists 40, 41, 42 and 43 front access AC input termination assemblies. For use with List 600, 601, 900, 901.

## **Ordering Notes**

- 1) Order as required. Provided as part of a List 600, 601, 900, 901.
- 2) Order rectifier modules as required, P/N 1R483500E3.
- 3) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

#### 588705400 List 02:

# Rectifier Module Mounting Assembly, 208 VAC, 240 VAC, 277 VAC Input, Single-Phase, Rear Covers, and Rear Mount Molex Input Connectors

#### **Features**

- ♦ Provides one (1) Model PSS4850-1/23, Spec. No. 58870540002 module mounting assembly.
- This module mounting assembly holds up to six (6) modules.
- ♦ This module mounting assembly is equipped with individual rectifier module single-phase AC input feeds (one AC input branch circuit per rectifier module, six AC input branch circuits per module mounting assembly).
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

#### **Restrictions**

AC inputs MUST be wired directly to the shelf.

- 1) Order as required.
- 2) Order rectifier modules as required, P/N 1R483500E3.
- 3) Order Rectifier AC Input Cable Assemblies per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 or order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

## System Application Guide

#### 588705400 List 03:

# Rectifier Module Mounting Assembly, 208 VAC, 240 VAC Input, Three-Phase, Rear Covers, and Rear Mount Molex Input Connectors

#### **Features**

- Provides one (1) Model PSS4850-1/23, Spec. No. 58870540003 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- This module mounting assembly is equipped with two (2) three-phase AC input circuits. Each input circuit powers three (3) single-phase rectifier modules, each connected from line to line, evenly distributed across the phases.
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

#### **Restrictions**

AC inputs MUST be wired directly to the shelf.

To maintain phase balance, rectifier modules should be installed in groups of three (all three on left and/or all three on right).

#### **Ordering Notes**

- 1) Order as required.
- Order rectifier modules as required, P/N <u>1R483500E3</u>.
- Order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

#### 588705400 List 04:

# Rectifier Module Mounting Assembly, 277/480 VAC Input, Three-Phase, Rear Covers, and Rear Mount Molex Input Connectors

#### **Features**

- Provides one (1) Model PSS4850-1/23, Spec. No. 58870540004 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- This module mounting assembly is equipped with two (2) three-phase AC input circuits. Each input circuit powers three (3) single-phase rectifier modules, each connected from line to neutral, evenly distributed across the phases.
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

#### **Restrictions**

AC inputs MUST be wired directly to the shelf.

To maintain phase balance, rectifier modules should be installed in groups of three (all three on left and/or all three on right).

- Order as required.
- 2) Order rectifier modules as required, P/N 1R483500E3.
- 3) Order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

System Application Guide

#### 588705400 List 05:

# Controller/Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No Rear Covers, and Factory Input Wiring Only

#### **Features**

- Provides one (1) Model PSS4850-1/23, Spec. No. 58870540005 module mounting assembly.
- ♦ This module mounting assembly holds up to one (1) controller and five (5) rectifier modules.
- No output busbar cover assembly and input cover assembly provided. Rear covers will be provided as part of the factory configured system.

#### Restrictions

For use with List 600, 601, 900, 901.

Module mounting assembly inputs MUST be factory wired into power system.

## **Ordering Notes**

- 1) Provided as part of a List 600, 601, 900, 901.
- 2) Order one (1) NCU controller (P/N 1M830BNA) with the desired configuration.
- 3) Order rectifier modules as required, P/N 1R483500E3.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty rectifier module mounting position in the system, as desired.

#### 588705400 List 11:

# Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No Rear Covers, Factory Input Wiring Only, Solar Compatible

#### **Features**

- Provides one (1) Model PSS4875-2/23, Spec. No. 58870540011 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- No output busbar cover assembly and input cover assembly provided. Rear covers will be provided as part of the factory configured system.

#### Restrictions

Module mounting assembly inputs MUST be factory wired into power system. For use with Lists 930, 931.

- 1) Order as required. Provided as part of a List 930, 931.
- 2) Order rectifier modules as required, P/N 1R483600E4.
- 3) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

System Application Guide

#### 588705400 List 12:

Rectifier Module Mounting Assembly, 208 VAC, 240 VAC, 277 VAC Input, Single-Phase, Rear Covers, Rear Mount Molex Input Connectors, Solar Compatible

#### **Features**

- Provides one (1) Model PSS4875-2/23, Spec. No. 58870540012 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- This module mounting assembly is equipped with individual rectifier module single-phase AC input feeds (one AC input branch circuit per rectifier module, six AC input branch circuits per module mounting assembly).
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

#### **Restrictions**

AC inputs MUST be wired directly to the shelf.

#### **Ordering Notes**

- 1) Order as required.
- 2) Order rectifier modules as required, P/N 1R483600E4.
- 3) Order Rectifier AC Input Cable Assemblies per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 or order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

#### 588705400 List 13:

Rectifier Module Mounting Assembly, 208 VAC, 240 VAC Input, Three-Phase, Rear Covers, Rear Mount Molex Input Connectors, Solar Compatible

#### **Features**

- Provides one (1) Model PSS4875-2/23, Spec. No. 58870540013 module mounting assembly.
- This module mounting assembly holds up to six (6) modules.
- This module mounting assembly is equipped with two (2) three-phase AC input circuits. Each input circuit powers three (3) single-phase rectifier modules, each connected from line to line, evenly distributed across the phases.
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

## Restrictions

AC inputs MUST be wired directly to the shelf.

To maintain phase balance, rectifier modules should be installed in groups of three (all three on left and/or all three on right).

- Order as required.
- Order rectifier modules as required, P/N 1R483600E4.
- 3) Order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

System Application Guide

#### 588705400 List 14:

Rectifier Module Mounting Assembly, 277/480 VAC Input, Three-Phase, Rear Covers, Rear Mount Molex Input Connectors, Solar Compatible

#### **Features**

- ♦ Provides one (1) Model PSS4875-2/23, Spec. No. 58870540014 module mounting assembly.
- ♦ This module mounting assembly holds up to six (6) modules.
- This module mounting assembly is equipped with two (2) three-phase AC input circuits. Each input circuit powers three (3) single-phase rectifier modules, each connected from line to neutral, evenly distributed across the phases.
- Output busbar and input cover assemblies provided. Input cover assembly is provided with rear input Molex connectors factory wired to the rectifier mounting positions.

#### **Restrictions**

AC inputs MUST be wired directly to the shelf.

To maintain phase balance, rectifier modules should be installed in groups of three (all three on left and/or all three on right).

## **Ordering Notes**

- 1) Order as required.
- Order rectifier modules as required, P/N 1R483600E4.
- Order Rectifier AC Input Line Cords per "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

#### 588705400 List 15:

Controller/Rectifier Module Mounting Assembly, 208 VAC / 240 VAC / 277 VAC Input, No Rear Covers, Factory Input Wiring Only, Solar Compatible

#### **Features**

- Provides one (1) Model PSS4875-2/23, Spec. No. 58870540015 module mounting assembly.
- ♦ This module mounting assembly holds up to one (1) controller and five (5) rectifier modules.
- ♦ No output busbar cover assembly and input cover assembly provided. Rear covers will be provided as part of the factory configured system.

## **Restrictions**

For use with List 930 or List 931.

Module mounting assembly inputs MUST be factory wired into power system.

- 1) Provided as part of a List 930, 931.
- 2) Order one (1) NCU controller (P/N 1M830BNA) with the desired configuration.
- Order rectifier modules as required, P/N 1R483600E4.
- 4) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty rectifier module mounting position in the system, as desired.

## System Application Guide

## 588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies

## Rectifier AC Input Cable Assembly, P/N 535232

#### **Features**

 One (1) 30" long, 8 AWG (2L+PE), input cable assembly that is terminated on one end with a Molex plug which mates with the input receptacle on a module mounting assembly, and not terminated on the remaining end.


#### Restrictions

For use with 588705300 List 03 and 588705400 List 02.

Rated for 30 A.

#### **Ordering Notes**

1) Order input cable assemblies as required.



## Rectifier AC Input Cable Assembly, P/N 547898

#### **Features**

One (1) 6' long, 8 AWG (2L+PE), input cable assembly that is terminated on one end
with a Molex plug which mates with the input receptacle on a module mounting
assembly, and not terminated on the remaining end.


#### Restrictions

For use with 588705300 List 03 and 588705400 List 02.

Rated for 30 A.

## **Ordering Notes**

Order input cable assemblies as required.



## Rectifier AC Input Cable Assembly, P/N 553202

### **Features**

 One (1) 12' long, 8 AWG (2L+PE), AC input cable assembly that is terminated on one end with a Molex plug which mates with the input receptacle on a module mounting assembly, and not terminated on the remaining end.


## **Restrictions**

For use with 588705300 List 03 and 588705400 List 02.

Rated for 30 A.

## **Ordering Notes**

1) Order input cable assemblies as required.



# 588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords

## Rectifier AC Input Line Cord, P/N 540946

#### **Features**

 One (1) 14' long, 8 AWG (2L+PE), AC input line cord that is terminated on one end with a Molex plug which mates with the AC input receptacle on a module mounting assembly, and terminated on the remaining end with a NEMA L6-30P twist-lock plug.

#### Restrictions

For use with 588705300 List 03 and 588705400 List 02.

For 208 VAC / 240 VAC only (rated for 30 A at 208 VAC / 240 VAC). (Size external overcurrent protection per plug rating. Refer to American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). For operation in countries where the NEC is not recognized, follow applicable codes.

## **Ordering Notes**

1) Order AC input line cords as required.

## Rectifier AC Input Line Cord, P/N 545616

#### **Features**

 One (1) 6' long, 8 AWG (2L+PE), AC input line cord that is terminated on one end with a Molex plug which mates with the AC input receptacle on a module mounting assembly, and terminated on the remaining end with a NEMA L6-30P twist-lock plug.

## **Restrictions**

For use with 588705300 List 03 and 588705400 List 02.

For 208 VAC / 240 VAC only (rated for 30 A at 208 VAC / 240 VAC). (Size external overcurrent protection per plug rating. Refer to American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). For operation in countries where the NEC is not recognized, follow applicable codes.

## **Ordering Notes**

1) Order AC input line cords as required.

## Rectifier AC Input Line Cord, P/N 545252

#### **Features**

One (1) 14' long, 8 AWG (L+N+PE), AC input line cord that is terminated on one end with a Molex plug which mates with the AC input receptacle on a module mounting assembly, and terminated on the remaining end with a NEMA L5-30P twist-lock plug.


#### **Restrictions**


For use with 588705300 List 03.


For 120 VAC only (rated for 30 A at 120 VAC). (Size external overcurrent protection per plug rating. Refer to American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). For operation in countries where the NEC is not recognized, follow applicable codes.

## **Ordering Notes**

1) Order AC input line cords as required.







#### Rectifier AC Input Line Cord, P/N 562046

#### **Features**

 One (1) 13' long, 8 AWG (3L+PE), AC input line cord that is terminated on one end with a Molex plug which mates with the AC input receptacle on a module mounting assembly, and terminated on the remaining end with a NEMA 15-50P plug.

#### Restrictions

For use with 588705400 List 03.

For 208 VAC / 240 VAC only (rated for 50 A at 208 VAC / 240 VAC). (Size external overcurrent protection per plug rating. Refer to American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). For operation in countries where the NEC is not recognized, follow applicable codes.

## **Ordering Notes**

1) Order AC input line cords as required.



#### **Features**

 One (1) 13' long, 12 AWG (3L+N+PE), AC input line cord that is terminated on one end with a Molex plug which mates with the AC input receptacle on a module mounting assembly, and terminated on the remaining end with a NEMA L22-20P twist-lock plug.


#### Restrictions


For use with 588705400 List 04.

For 277/480 VAC (3L+N+PE) only (rated for 20 A at 277/480 VAC). (Size external overcurrent protection per plug rating. Refer to American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). For operation in countries where the NEC is not recognized, follow applicable codes.

#### **Ordering Notes**

1) Order AC input line cords as required.





## Converter Interface Components (for Spec. No. 588705300), For System Mounted in a Relay Rack Only

#### **Features**

 Provides components to interface converters in Spec. No. 588705300 module mounting assemblies to the distribution cabinet.

## Restrictions

Not for use with systems mounted in an enclosure.

Must be used in systems equipped with Spec. No. 588705300 module mounting assemblies.

Must be installed in main bay only.

Must be used in conjunction with a dual voltage bus distribution panel.

## **Ordering Notes**

- 1) Order the components listed in Table 16 to add converter capability to a system in the field that was not originally ordered with the List 60 or List 62 Converter Option.
- 2) Order up to three (3) converter modules, P/N 1C48241500 or 1C48582000P3, per module mounting assembly.
- 3) Order a module mounting position blank cover panel, P/N SXA1100035/1, for each empty module mounting position in the system, as desired.

For Use w/ (5)

Component	Part Number	Quantity	
Converter Jumper	556228	Order one (1) per rectifier/converter assembly in the system, up to a maximum of four (4).	
	555264 when there are five (5) rectifier/converter assemblies in the system.		
	555730 when there are four (4) rectifier/converter assemblies in the system.		
+24V Busbar	555733 when there are three (3) rectifier/converter assemblies in the system.	Order one (1) from the part numbers listed.	
	555736 when there are two (2) rectifier/converter assemblies in the system.		
	555739 when there are one (1) rectifier/converter assemblies in the system.		
1/4-20 x 3/4" Bolt	227640400	Order two (2) per converter jumper ordered.	
1/4-20 x 1" Bolt	227640600	Order two (2) per converter jumper ordered.	
1/4" Flat Washer	214110100	Order six (6) per converter jumper ordered.	
1/4" Lock Washer	215111100	Order four (4) per converter jumper ordered.	
1/4-20 Nut	228557100	Order two (2) per converter jumper ordered.	

Table 16

For Use w/ (1) Rectifier/Converter Shelf

For Use w/ (2

Rectifier/Converter Shelves

For Use w/ (3)

For Use w/ (4) Rectifier/Converter She

## **Relay Racks and Shipping Brackets**

**Note:** System components are factory mounted in a relay rack, on shipping rails, or in an enclosure as specified when ordered.

#### **Features**

- ♦ The system can be factory mounted to a relay rack or on shipping brackets as specified when ordered.
- Relay racks (except P/N 562353 and P/N 10009902) are 23" standard mounting with 3" deep uprights.
   P/N 562353 and P/N 10009902 are 23" standard mounting with 6" deep upright.
- ♦ When ordered with shipping brackets, the system is mounted on shipping brackets bolted to a shipping skid. The shipping brackets can mount a system up to 22U high.

## **Ordering Notes**

1) Order from relay racks and shipping brackets listed in Table 17.

Part Number	Size	Available Mounting Positions (1RU = 1-3/4")	Notes
509638 509639	Shipping Brackets	22RU	
562360	43.156"H x 24.376"W x 15"D	23RU	Seismic (Note 1)
559817	51.906"H x 24.376"W x 15"D	28RU	Welded
564169	60.000"H x 25.800"W x 18"D	31RU	Seismic (Note 1)
559818	72.000"H x 24.375"W x 15"D	38RU	Welded
564127	72.000"H x 25.800"W x 18"D	38RU	Seismic (Note 1)
559820	84.000"H x 24.375"W x 15"D	45RU	Welded
562353	84.000"H x 25.800"W x 18"D	45RU	Seismic (Note 1)
10009902	84.000"H x 25.800"W x 18"D	45RU	Seismic (Note 2)
562355	85.750"H x 24.375"W x 15"D	46RU	Welded
559821	90.000"H x 24.375"W x 15"D	48RU	Welded
559822	96.000"H x 24.375"W x 15"D	51RU	Welded

*Note 1:* Complies with Bellcore Seismic Zone 4 requirements.

Note 2: Complies with Bellcore Seismic Zone 4 requirements, per FEA Analysis.

Table 17
Available Relay Racks and Shipping Brackets

## Transition Plates to Mount Relay Rack on Top of GNB Absolyte IIP Batteries

#### **Features**


- Transition Plate Kits can be ordered to mount relay rack P/Ns 562360 or 559817 on top of GNB Absolyte IIP batteries.
- ♦ Each kit consists of two transition plates with three hole patterns and hardware (3/8") to mount the plates to the above listed relay racks. Customer must supply hardware to mount the transition plates to the battery.

#### Restrictions

Used with relay rack P/Ns 562360 or 559817 only.

## **Ordering Notes**

- Order P/N 509819 for a Transition Plate Kit to mount relay rack on top of a GNB 3-100A19, GNB 3-100A27, or GNB 3-100A33 battery.
- Order P/N 514596 for a Transition Plate Kit to mount relay rack on top of a GNB 6-90A09 battery.
- 3) Order P/N 514880 for a Transition Plate Kit to mount relay rack on top of a GNB 3-100A21, GNB 3-100A25, or GNB 3-100A31 battery.




## **Relay Rack Isolation Kit**

#### **Features**

Provides electrical isolation of the relay rack from the concrete floor. Includes an insulating pad, four (4) insulating bushings, and four (4) flat washers to be used with the anchors used to mount the relay rack to the floor.

### **Ordering Notes**

1) Order P/N 10019125 for a Relay Rack Isolation Kit to be used with 23" seismic relay racks P/N 562353, PN 10009902, P/N 564127, and P/N 564169.




## **Replacement Rear Panel Cover**

### **Features**

Provides a rear panel cover to replace a breakaway section of the original rear panel. The breakaway sections are provided to allow for installing the rearinter-bay bus or for gaining access through the rear of the system, if needed.

## **Ordering Notes**

 Order P/N 537497 for one rear panel cover, quantity as needed. The number of breakaways varies by cabinet size (two for List 22 and 23, three for List 24). Each cover is secured with two (2) 6-32 x 1/4" L pan head machine screws (not provided).




## **Enclosure and Enclosure Options**

#### **Features**

- The system can be factory mounted in an enclosure as specified when ordered.
- Refer to "Enclosure, P/N 563524" on page 245 for dimensions.
- Reversible door. Default mounting is right handed.

#### **Ordering Notes**

- 1) Order from available enclosures listed in Table 18.
- 2) Order enclosure side panels as required. P/N 563666 (dark gray) provides one (1) side panel. Side panels are factory installed when ordered.
- 3) Order an enclosure mounted LED kit as required P/N 563678. Provides a factory installed LED located at the top of the enclosure visible from the front with the door closed. Illuminates red if a major or critical alarm activates.
- 4) If List 40 AC input assembly is ordered with six (6) rectifier shelves, two (2) P/N 563877 conduit plates will be provided. Each provides five (5) 3/4" conduit openings. Note that each enclosure is factory equipped with two (2) conduit plates that provide four (4) 1" conduit openings.
- 5) If desired, order lockable door handle P/N 10014497. This item will ship loose with the system for field replacement.





*Note 1:* Complies with Bellcore Seismic Zone 4 requirements.

Table 18 Available Enclosures (Note 1)

# **Crimp Lugs**

## **Standard Crimp Lug Tables**

Lead Size	Part Number
14 AWG to 10 AWG	245342300
8 AWG	245390200
6 AWG	245346700
4 AWG	245346800
2 AWG	245346900

Lugs should be crimped per lug manufacturer's specifications.

Table 19 Crimp Lug Two-Hole, 1/4" Bolt Clearance Hole, 5/8" Centers

Lead Size	Part Number	
6 AWG	245349900	
4 AWG	245350000	
2 AWG	245348200	
1/0 AWG	245347100	
2/0 AWG	245347200	
3/0 AWG	245347300	
4/0 AWG	245347400	
250 kcmil	245347500	
300 kcmil	245347600	
350 kcmil	245347700	
400 kcmil	245347800	
500 kcmil	245347900	
600 kcmil	245348000	
750 kcmil	245348100	

Lugs should be crimped per lug manufacturer's specifications.

Table 20 Crimp Lug Two-Hole, 3/8" Bolt Clearance Hole, 1" Centers

## **Special Application Crimp Lug / Strap Combination Table**

#### **Features**

♦ Straps two fuseholder/circuit breaker wiring positions together, and provides a crimp-type lug which allows distribution wiring up to 350 kcmil size (maximum size of wire to be connected to a single position is 2 AWG). Designed for use with 125 A and larger bullet nose-type circuit breakers or TPS/TLS-type fuses, which require at least two mounting positions.

#### Restrictions

If used with bullet nose-type circuit breakers or TPS/TLS-type fuses smaller than 125 A, an empty mounting position is required adjacent to the distribution device.

## **Ordering Notes**

1) Specify part number from Table 21 for desired lead size.

Lead Size	Part Number	
1/0 AWG	245393500	
2/0 AWG	245393600	
3/0 AWG	245393700	
4/0 AWG	245393800	
250 kcmil	514872	
350 kcmil	514873	

Lugs should be crimped per lug manufacturer's specifications.

Table 21
Special Application Crimp Lug / Strap Combination
(Two-Hole Lug, 1/4" Bolt Clearance Hole, 5/8" Centers)

## **Lug Adapters**


## Busbar for 125 A, 150 A, and 200 A Bullet Nose Type Circuit Breaker, P/N 60016097

#### **Features**

 Provides a busbar that mounts on the two lug landing positions of a 125 A, 150 A, or 200 A bullet nose circuit breaker, and allows for use of one standard two-hole lug having 1/4" bolt clearance holes on 5/8" centers.

## **Ordering Notes**

 Order one (1) Part No. 60016097 per 125 A, 150 A, and 200 A bullet nose circuit breaker ordered, as desired. See also P/Ns <u>522786</u> and <u>534449</u> in this section.




# Busbar for 125 A, 150 A, and 200 A Bullet Nose Type Circuit Breaker, P/N 522786 (all Lists except 600, 601, 900, 901, 930, 931)

#### **Features**

Provides a busbar that mounts on the two lug landing positions of a 125 A, 150 A, or 200 A bullet nose circuit breaker, and provides a landing for one standard two-hole lug having 3/8" bolt clearance holes on 1" centers.

## **Ordering Notes**

 Order one (1) Part No. 522786 per 125 A, 150 A, and 200 A bullet nose circuit breaker ordered, as desired. See also P/Ns 520989 and 534449 in this section.




# Lug Adapter Busbar Kit for 125 A, 150 A, and 200 A Bullet Nose Type Circuit Breaker, P/N 534449 (all Lists except 600, 601, 900, 901, 930, 931)

#### **Features**

Includes one (1) busbar that mounts on the two lug landing positions of a 125 A, 150 A, or 200 A bullet nose circuit breaker, and provides a landing for one standard two-hole lug having 3/8" bolt clearance holes on 1" centers. Also includes one (1) busbar that mounts on two landings of the associated ground return bar (if furnished), and provides one landing for a standard two-hole lug having 3/8" bolt clearance holes on 1" centers. All busbar and lug mounting hardware is included.



 Order one (1) Part No. 534449 per 125 A, 150 A, and 200 A bullet nose circuit breaker ordered, as desired. See also P/Ns 520989 and 522786 in this section.




## Busbar for 225 A through 300 A Bullet Nose Type Circuit Breaker, P/N 545346DCP

## **Features**

Provides a busbar that mounts on the three lug landing positions of a 225 A through 300
 A bullet nose circuit breaker, and allows for use of a <u>Special Application Crimp Lug / Strap Combination</u> lug listed in Table 21.

## **Ordering Notes**

 Order one (1) P/N 514717 per 225 A through 300 A bullet nose circuit breaker ordered, as desired (see also <u>Lug Adapter Busbar Kit for 225 A through 300 A Bullet Nose Type</u> <u>Circuit Breaker, P/N 514714</u> for another option).




# Lug Adapter Busbar Kit for 225 A through 300 A Bullet Nose Type Circuit Breaker, P/N 514714 (all Lists except 600, 601, 900, 901, 930, 931

#### **Features**

♦ Includes one (1) busbar that mounts on the three lug landing positions of a 225 A through 300 A bullet nose circuit breaker, and provides one landing for a standard two-hole lug having 3/8" bolt clearance holes on 1" centers. Also includes one (1) busbar that mounts on three landings of the associated ground return bar (if furnished), and provides one landing for a standard two-hole lug having 3/8" bolt clearance Holes on 1" centers. All busbar and lug mounting hardware is included.

## **Ordering Notes**

 Order one (1) Part No. 514714 per 225 A through 300 A bullet nose circuit breaker ordered, as desired (see also <u>Busbar for 225 A through 300 A Bullet Nose Type Circuit Breaker, P/N 514717</u> for another option).



# Lug Adapter Busbar Kit for 3-Pole GJ/218 Circuit Breaker Installed in a List AM and List AP Distribution Panel, P/N 562888

#### **Features**

• Includes one (1) busbar that mounts on the three lug landing positions of a three-pole circuit breaker installed in a List AM or List AP distribution panel and one (1) busbar that mounts on the three landings of the associated ground return bar. These busbars provide two (2) landings for standard two-hole lugs having 3/8" bolt clearance holes on 1" centers.



Maximum lug width, 2.0 inches.


## **Ordering Notes**

 Order one (1) Part No. 562888 per three-pole GJ/218 circuit breaker ordered for a List AM or List AP Distribution Panel, as desired.

## Lug Adapter Busbar Kit for 4-Pole, P/N 60159564 (used in Lists 600, 601, 900, 901, 930, 931)

## **Features**

◆ Includes two (2) busbars that each mount on two of the four lug landing positions of a 400 A bullet nose circuit breaker, with each providing one landing for a standard twohole lug having 3/8" bolt clearance holes on 1" centers. Also includes two (2) busbars that each mount on two landings of the associated ground return bar (if furnished), with each providing one landing for a standard two-hole lug having 3/8" bolt clearance holes on 1" centers. All busbar and lug mounting hardware is included.



## Restrictions

Maximum lug width 1.25 inches.

For use with 4-pole bullet nose breaker assembled to distribution panel.

For use only with Lists 600, 601, 900, 901, 930, and 931.

#### **Ordering Notes**

1) Order one (1) Lug Adapter Busbar Kit (P/N 60159564) per four-pole bullet breaker ordered. (See restrictions above.)

## Lug Adapters (Lists 600, 601, 900, 901, 930, 931)

See the table below.

Part Number	Description		
559803	Busbar Lug Adapter Kit: Converts one (1) load position (1/4-20 on 5/8" centers) to one (1) load landing (1/4-20 on 5/8" centers), right angle.		
559804	Busbar Lug Adapter Kit: Converts two (2) load positions (1/4-20 on 5/8" centers) to one (1) landing (3/8-16 on 1" centers). Right angle load busbar and straight return busbar for rear wiring egress.	88	
559805	Busbar Lug Adapter Kit: Converts three (3) load positions (1/4-20 on 5/8" centers) to one (1) landing (3/8-16 on 1" centers). Right angle load busbar and straight return busbar for rear wiring egress.	333	

Busbar lug adapter kits include hardware shown.

Unless otherwise specified, busbar lug adapter kits are factory installed when ordered with system.

Table 22 Busbar Lug Adapter Kits

## **Lug Hardware Kits**

## 1/4-20 Hardware Kit, P/N 541084

#### **Features**

Lug hardware kit provides thirty-two (32) sets of 1/4-20 hardware for bullet nose distribution panels. Kit includes (32) 1/4-20 Nuts, (32) 1/4" Flat Washers, and (32) 1/4" Lock Washers.

## **Ordering Notes**

1) Order Kit P/N 541084, as required.

## 3/8-16 Hardware Kit, P/N 548184

#### **Features**

♦ Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware for GJ/218 distribution panels, TPH distribution panels, return bar panels, and battery busbars. Kit includes (16) 3/8-16 x 1-1/4" Bolts, (16) 3/8" Flat Washers, and (16) 3/8" Lock Washers.

## **Ordering Notes**

1) Order Kit P/N 548184, as required.

## 3/8-16 Hardware Kit, P/N 548185

## **Features**

◆ Lug hardware kit provides sixteen (16) sets of 3/8-16 hardware for Lists 600, 601, 900, 901 battery busbars. Kit includes (16) 3/8-16 Nuts, (16) 3/8" Flat Washers, and (16) 3/8" Lock Washers.


## **Ordering Notes**

1) Order Kit P/N 548185, as required.

## Battery Busbar Extension Kit (P/N 562364)

#### **Features**

Provides busbar extension plates and mounting hardware for extending battery busbars through the top of a List 23 and List 24 distribution cabinet. The hot side busbar extension plate (P/N 562363) provides five (5) pairs of clearance holes for 3/8" hardware on 1" centers, and the return side busbar extension plate (P/N 562362) provides four (4) pairs of clearance holes for 3/8" hardware on 1" centers. The hot side allows back-to-back lug landing for up to ten lugs and the return side allows back-to-back lug landing for up to eight lugs. See "Battery Input Illustrations" starting on page 228.



## **Ordering Notes**

 Order one (1) kit P/N 562364 per List 23 and List 24 distribution cabinet, as required.

## Battery Busbar Extension Kit (P/N 554541)

#### **Features**

Provides busbar extension plates and mounting hardware for extending battery busbars through the top of a List 21 (1-Row) and List 22 (2-Row) distribution cabinet. Each busbar extension plate provides three pairs of clearance holes for 3/8" hardware on 1" centers. Allows back-to-back lug landing for up to six lugs per polarity. See "Battery Input Illustrations" on page 228.





#### **Ordering Notes**

1) Order one (1) kit P/N 554541 per List 21 and List 22 distribution cabinet, as required.

## Battery Landing Busbar Kit (P/N 553584), For System Mounted in a Relay Rack Only

## **Features**

Provides a Battery Landing Busbar Kit that attaches to the distribution cabinet's battery busbars and hangs off the back of the cabinet. Six (6) battery landing positions are provided (per polarity) (1/4-20 x 0.875" studs on 0.625" centers). See "Battery Input Illustrations" on page 228.




Not for use with systems mounted in an enclosure.

For use with List 21.

CANNOT be used with List 2 or List 3.

#### **Ordering Notes**

1) Order one (1) kit P/N 553584 per bay, as required.



## Battery Landing Busbar Kit (P/N 555478), For System Mounted in a Relay Rack Only

#### **Features**

♦ Provides a Battery Landing Busbar Kit that attaches to the distribution cabinet's battery busbars and hangs off the back of the cabinet. Four (4) battery landing positions are provided (per polarity) for connection of up to eight (8) battery leads (back-to-back) (per polarity) (1/4-20 x 0.875" studs on 0.625" centers). See "Battery Input Illustrations" on page 228.

#### **Restrictions**


Not for use with systems mounted in an enclosure.

For use with Lists 22, 23, and 24.

CANNOT be used with List 2, List 3, List 7 or List 8.

## **Ordering Notes**

1) Order one (1) kit P/N 555478 per bay, as required.



## **Distribution Devices**

#### Bullet Nose Type Circuit Breakers and Bullet Nose Type Fuseholders e/w TPS/TLS Fuses

#### **Features**

- ♦ Each circuit breaker (as listed in Table 23 and Table 24) plugs into one, two, or three mounting position(s) on a distribution panel containing bullet nose type distribution positions.
- ♦ A single fuseholder provides for installation of a 3 A to 100 A Bussmann TPS type or Littelfuse TLS type fuse (as listed in Table 25). This fuseholder plugs into a single mounting position on a distribution panel containing bullet nose type distribution positions. This fuseholder provides a GMT-A alarm type fuse, which operates open to provide an alarm indication if the associated distribution fuse opens.

#### Restrictions

For use in Lists AL, AN, DE, DF, DG, DH, DJ, DK, FE, FF, FG, FH, FJ FK, and Lists 600, 601, 900, 901, 930, 931. Load should not exceed 80% of device rating.

Install distribution devices from left to right, starting with the highest capacity and working to the lowest capacity. See the distribution panel list descriptions for additional restrictions.

#### **Ordering Notes**


- 1) Order circuit breakers as required per Table 23 or Table 24.
- 2) Order fuses as required per Table 25. For each fuse ordered, also order one (1) P/N 117201 bullet nose type fuseholder.
- 3) See Table 52 for recommended load distribution wire sizes and lugs.
- 4) When ordering 125 A through 300 A circuit breakers; associated crimp lugs may be ordered from Table 21.

All Lists Except Lists 600, 601, 900, 901, 930, 931: When ordering 125 A through 200 A circuit breakers; lug adapter busbar kits P/N 520989, P/N 522786, or P/N 534449 may be ordered per circuit breaker (see "Lug Adapters" on page 128).


All Lists Except Lists 600, 601, 900, 901, 930, 931: When ordering 225 A through 300 A circuit breakers; lug adapter busbar kit P/N 514714 or P/N 514717 may be ordered per circuit breaker (see "Lug Adapters" on page 128).

Lists 600, 601, 900, 901, 930, 931: When ordering 2-pole devices, busbar lug adapter kit P/N 559804 may be ordered per device (see "Lug Adapters (Lists 600, 601, 900, 901, 930, 931)" on page 130).


Lists 600, 601, 900, 901, 930, 931: When ordering 3-pole devices, busbar adapter kit P/N 559805 may be ordered per device (see "Lug Adapters" on page 130).




**Bullet Nose Fuseholder** 



Toggle Handle Bullet Nose Circuit Breaker



Rocker Handle Bullet Nose Circuit Breaker



			Number of	Number of	Part N	lumber
Ampere Rating	Number of Poles	Mounting Positions Required	Electrical Trip <sup>1</sup> (White Handle)	Electrical/ Mechanical Trip <sup>2</sup> (Black Handle)		
1	1	1	102272	101596		
3	1	1	102273	101597		
5	1	1	102274	101598		
10	1	1	102275	101599		
15	1	1	102276	101600		
20	1	1	102277	101601		
25	1	1	102278	101602		
30	1	1	102279	101603		
35	1	1	102280	101604		
40	1	1	102281	101605		
45	1	1	121998	121997		
50	1	1	102282	101606		
60	1	1	102283	101607		
70	1	1	102284	101608		
75	1	1	102285	101609		
80	1	1	121996	121995		
90	1	1	138887	138888		
100	1	2	102286	101610		
125	2	3	516991	516838		
150	2	3	516993	516839		
175	2	3	144883	144884		
200	2	3	121831	121832		
225	3	4	144885	144886		
250	3	4	121835	121836		
300	3	4	149075	149076		

## Circuit Breaker Alarm Operation:

- <sup>1</sup> Provides an alarm during an electrical trip condition only.
- Provides an alarm during an electrical or manual trip condition.

**Note:** Electrical Trip only circuit breakers are not typically used for battery disconnect circuit breakers.

Table 23
Toggle Handle Bullet Nose Type Circuit Breakers

		Number of	Part N	lumber
Ampere Rating	Number of Poles	Mounting Positions Required	Electrical Trip <sup>1</sup> (White Handle)	Electrical/ Mechanical Trip <sup>2</sup> (Black Handle)
1	1	1	142856	142878
3	1	1	142857	142879
5	1	1	142858	142880
10	1	1	142859	142881
15	1	1	142861	142882
20	1	1	142862	142883
25	1	1	142863	142884
30	1	1	142864	142885
35	1	1	142865	142886
40	1	1	142866	142887
45	1	1	142867	142888
50	1	1	142868	142889
60	1	1	142869	142890
70	1	1	142870	142891
75	1	1	142871	142892
80	1	1	142872	142901
100	1	2	142873	142902
125	2	3	142874	142903
150	2	3	142875	142904
200	2	3	142876	142905
250	3	4	142877	142906

- Circuit Breaker Alarm Operation:

  1 Provides an alarm during an electrical trip condition only.
  - <sup>2</sup> Provides an alarm during an electrical or manual trip condition.

Note: Electrical Trip only circuit breakers are not typically used for battery disconnect circuit breakers.

> Table 24 Rocker Handle Bullet Nose Circuit Breakers

Ampere Rating	Part Number	Bussmann P/N	Littelfuse P/N
3	248230900	TPS-3	TLS003
5	248231000	TPS-5	TLS005
6	248231200	TPS-6	TLS006
10	248231500	TPS-10	TLS010
15	248231800	TPS-15	TLS015
20	248232100	TPS-20	TLS020
25	248232400	TPS-25	TLS025
30	248232700	TPS-30	TLS030
40	248233300	TPS-40	TLS040
50	248233900	TPS-50	TLS050
60	248234200	TPS-60	TLS060
70	248234500	TPS-70	TLS070
80	118413		TLS080
90	118414		TLS090
100	118415		TLS100
Bullet Nose Type Fuseholder		P/N 117201 (Includes Fuseholder, 18/100 GMT-X Safety Fuse Cover)	A GMT-A Alarm Fuse, and

Table 25
Bullet Nose Type Fuseholders and TPS/TLS Fuses

## Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block, P/N 549017, (6) GMT Fuse Positions

## **Features**

- Provides six (6) load distribution fuse positions (1/4 A to 15 A GMT alarm-type fuses).
- ♦ Single voltage distribution (-48 V, -58 V, or +24 V).
- Mounts in two (2) distribution positions of a "bullet nose" distribution panel.
- Screw clamp type load and load return terminals provided.
- Includes six (6) dummy fuses equipped with safety fuse covers.

## **Restrictions**

For Lists AL, AN, DE, DF, DG, DH, DJ, DK, FE, FF, FG, FH, and FK, can be installed only in the 1-2, 3-4, 5-6, 7-8, 15-16, 17-18, 19-20, 21-22, 23-24, and 25-26 positions of the distribution panel.

For Lists 600, 601, 900, 901 Row 1 (bottom) distribution panel, can be installed only in the 1-2 through 13-14 positions.


For Lists 600, 601, 900, 901 Row 2 (top) distribution panel, can be installed in all positions.

Occupies two (2) bullet device mounting positions.

Terminal block wire size capacity is 26 AWG to 14 AWG.

35 A maximum capacity per block.

Maximum GMT fuse size is 15 A.



#### **Ordering Notes**

- 1) Order optional Bullet Nose Type 6-Position GMT Fuse Block Kit (P/N 549017) as required. Provides one alarm fuse distribution assembly, ground return link, and hardware.
- 2) Order fuses as required per Table 26.

## Optional +27 VDC Bullet Nose 6-Position GMT Fuse Board Kit, P/N 10062803

#### **Features**

- Provides six (6) load distribution fuse positions (1/4 A to 15 A GMT alarm-type fuses).
- ♦ Single voltage distribution (+27 VDC).
- Mounts in two (2) distribution positions of any "bullet nose" distribution panel.
- ♦ Screw clamp type load and load return terminals provided.
- Includes six (6) dummy fuses equipped with safety fuse covers.

#### **Restrictions**

Only to be connected and used with the +27 VDC Vertiv™ eSure™ Bullet Converter.

Occupies two (2) bullet device mounting positions directly adjacent to the +27 VDC converter(s).

Terminal block wire size capacity is 26 AWG to 14 AWG.

The GMT fuses have an interrupting rating of 450 A @ 60 VDC. It is recommended to install fuses with the highest ampacity starting in the farthest position from the +27 VDC Vertiv™ eSure™ Bullet Converter.


#### At 40 °C Ambient:

- Maximum total current is 27.8 A.
- Maximum fuse size is 15 A.
- When used for power distribution, load should not exceed 80% of device rating, except 10 A and 15 A fuses for which load should not exceed 70% of device rating.
- GMT fuses greater than 10 A SHALL have an empty mounting position between it and any other fuse.

#### At 65 °C Ambient:

- Maximum total current is 22 A.
- Maximum fuse size is 15 A.
- When used for power distribution, load should not exceed 80% of device rating, except 10 A fuses for which load should not exceed 70% of device rating and 15 A fuses for which load should not exceed 50% of device rating.
- GMT fuses greater than 5 A SHALL have an empty mounting position between it and any other fuse.


- 1) Order optional +27 VDC Bullet Nose 6-Position GMT Fuse Board Kit (P/N 10062803) as required (see restrictions above). Provides one alarm fuse distribution assembly, return links, and hardware.
- 2) Order a 60016097 two-pole, 545346DCP three-pole, 10078650 four-pole or 10078651 five-pole paralleling busbar to parallel with the +27 VDC Vertiv™ eSure™ Bullet Converter, depending on the number of converters ordered. The input bullet terminal on the +27 VDC Bullet Nose 6-Position GMT Fuse Board is located in the top-right pole adjacent to the converter module pole when mounted to the left of the converter/s. When mounting the GMT board on the right-hand side of the converter/s, order a paralleling busbar with an additional set of holes. For example, for two converter modules and a GMT Fuse Board, a three-position paralleling busbar would be used for mounting the GMT Fuse board to the left of the converters and a four-position paralleling busbar for right-side mounting.
- 3) Order fuses as required per Table 26.
- 4) Mounting and installation information can be found in UM10062803 and IM565939.



#### Optional 6-Position 30A GMT Fuse Board Kit, P/N 60160806

#### **Features**

- Provides six (6) load distribution fuse positions (1/4 A to 15 A GMT alarm type fuses).
- ♦ Single voltage distribution (-48 V only)
- ♦ Mounts below the lower bullet distribution panel.
- Screw clamp type load and load return terminals provided.
- Includes six (6) dummy fuses equipped with safety fuse covers



## **Restrictions**

For use only with List 930 and List 931.

Terminal block wire size capacity is 26 AWG to 14 AWG.

Maximum capacity is 35 A per block.

Maximum GMT fuse size is 15 A.

#### **Ordering Notes**

- 1) Order optional 6-Position 30 A GMT Fuse Board Kit (P/N 60160806) as required (see restrictions above). Provides one (1) alarm fuse distribution assembly, ground return link, and hardware.
- 2) Order fuses as required per Table 26.
- 3) Mounting and installation information can be found in IM582127000900.

## Optional Bullet Nose Type 6-Position GMT Distribution Fuse Block, P/N 60191012, (6) GMT Fuse Positions

## **Features**

- ◆ Provides six (6) load distribution fuse positions (1/4 A to 15 A GMT alarm-type fuses).
- Single voltage distribution (-48 V or -58 V).
- Mounts in two (2) distribution positions of a "bullet nose" distribution panel.
- Screw clamp type load and load return terminals provided.
- Includes six (6) dummy fuses equipped with safety fuse covers.

## **Restrictions**

For use only with List 930 and List 931.

For Row 1 (bottom) distribution panel, can be installed only in the 6-7 through 23-24 positions.


For Row 2 (top) distribution panel, can be installed in all positions.

Terminal block wire size capacity is 26 AWG to 14 AWG.

35 A maximum capacity per block.

Maximum GMT fuse size is 15 A.

- 1) Order optional Bullet Nose Type 6-Position GMT Fuse Block Kit (P/N 60191012) as required. Provides one alarm fuse distribution assembly, ground return link, and hardware.
- 2) Order fuses as required per Table 26.



## **GMT Type Load Distribution Fuses**

## **Features**

• For use with optional 549017, 10062803, 60160806, and 60191012 GMT fuse assemblies.

#### Restrictions

When used for power distribution, load should not exceed 80% of device rating, except 10 and 15 amp fuses, for which load should not exceed 70% of device rating.

## **Ordering Notes**

1) Order fuses as required per Table 26.

Ampere Rating	Part Number	Fuse Color
18/100 (GMT-A)	248610301	
1/4	248610200	VIOLET
1/2	248610300	RED
3/4	248610500	BROWN
1-1/3	248610700	WHITE
2	248610800	ORANGE
3	248610900	BLUE
5	248611000	GREEN
7-1/2	248611300	BLACK-WHITE
10	248611200	RED-WHITE
15	248611500	RED-BLUE
Replacement Safety Fuse Cover (GMT-Y)	102774	
Replacement Dummy Fuse	248872600	

Table 26 GMT Fuses


## **GJ/218 Type Circuit Breakers**

## **Restrictions**

For use in Lists AC, AD, AM, AP, BC, and BD. Load should not exceed 80% of device rating. Refer to Table 27 for required distribution row mounting positions.

## **Ordering Notes**

- 1) Order circuit breakers as required per Table 27.
- Order a jumper kit as required for each circuit breaker per Table 27.
- See Table 53 for recommended load distribution wire sizes and lugs.



GJ/218 Circuit Breakers

Ampere Rating	No. of Positions	P/N <u>Electrical/</u> <u>Mechanical Trip¹</u> without Internal Shunt	P/N Electrical Trip <sup>2</sup> without Internal Shunt	Breaker Mounting Kit (without Shunt)	P/N Electrical/ Mechanical Trip¹ with Internal Shunt (25 mV @ full rated load)³	P/N Electrical Trip <sup>2</sup> with Internal Shunt (25 mV @ full rated load) <sup>3</sup>	Breaker Mounting Kit (with Shunt)
100	1	256621700	256621300	503787	123580	516184	513731
125	1	256621600	256621400	503787	123631	516187	513731
150	1	256621800	256622400	503787	123632	516185	513731
175	1	256621900	256622500	503787	123633	516186	513731
200	1	256622200	256622600	503787	123634	516188	513731
225	1	256622900	256622700	503787	123635	516189	513731
250	1	256623500	256623400	503787	123636	516190	513731
300	2	256625300	103572	513961	550250	550253	554092
400	2	256626200	256626300	513961	550251	550254	554092
600	3	256628200	103571	513957	550252	550255	554093
800	4	121657	121658	554091		550249	554094

<sup>1,2</sup> Circuit Breaker Alarm Operation:

Note: Electrical Trip only circuit breakers are not typically used for battery disconnect circuit breakers.

Table 27 GJ/218 Circuit Breakers

<sup>1</sup> Provides an alarm during an electrical or manual trip condition.

<sup>2</sup> Provides an alarm during an electrical trip condition only.

Extended shunt leads are 22 AWG stranded wire, approximately 7-10 ft. long from exit point at bottom of distribution cabinet. Each shunt lead is equipped with a 49.9 ohm current limiting resistor. Shunt leads are factory wired to SM-DU+ (if ordered).

## **TPH Type Fuses**

## **Restrictions**


For use in Lists AF, AH, BF, and BH.

Load should not exceed 80% of device rating.

## **Ordering Notes**

- 1) Order fuses as required per Table 28.
- 2) See Table 53 for recommended load distribution wire sizes and lugs.

Ampere Rating	Part Number
70	119437
80	119438
100	119440
150	119581
200	119582
225	119583
250	119584
300	119585
400	119586
500	119587
600	119588



TPH Fuse

Table 28 TPH Fuses

## User Replaceable Alarm, Reference, and Control Fuses

## **Ordering Notes**

1) Order replacement fuses as required per Table 29.

Assembly	Desig.	Function	Size (Amperes)	Туре	Part No.
Distribution Panel with TPH Fuse Block(s)	FA	Fuse Alarm	1/4	Bussmann GMT	248610200
				Safety Fuse Cover (GMT-X)	248898700
TPS/TLS Fuseholders (P/N 117201)	FA	Fuse Alarm	18/100	Bussmann GMT-A	248610301
				Safety Fuse Cover (GMT-X)	248898700

Table 29
User Replaceable Alarm, Reference, and Control Fuses

# **User Replaceable Components**

## **Ordering Notes**

1) Refer to the following table. Refer to the separate rectifier and converter descriptions in this section for their part numbers.

Item	Part Number		
NCU Controller	All Lists Except Lists 600, 601, 900, 901, 930, 931:  1M830DNA (order with appropriate software configuration.)		
	Lists 600, 601, 900, 901, 930, 931: 1M830BNA (order with appropriate software configuration.)		
IB4 Second Ethernet Port Board	558076		
SM-DU	SMDU		
	556166 (all Lists except List 100, 101, 102, 203, 600, 601, 900, 901, 500, 501, 502, 503, 930, 931)		
System Interface Board	562662 (List 100, 101, 102, 203, 500, 501, 502, 503)		
	555484 (List 600, 601, 900, 901)		
	430171G1 (List 930, List 931)		
IB2 Interface Board	MA4C5U31		
EIB Extended Interface Board	MA455U41		
30-Position Fuse Alarm Board	430191G1 (List 930 and List 931 only)		
Temp Probe Sensor	552822		
Tomp Broke Cobles	552823 and		
Temp Probe Cables	556154		
SM-DU+ with Shunt Interface Board	548078		
LVD Driver Circuit Card	563696 (Main Bay) and 563718 (Supplemental Bay)		
LVD Driver Lite Circuit Card	547873 (Main Bay) and 547874 (Supplemental Bay)		
Manual Battery Disconnect Circuit Card	540973		
Disconnect Contactor, 600 A	545468DCP (List LL, List CA)		
Disconnect Contactor, 1200 A	537496 (List CB, List 100, List 101, List 102, List 103, List 203, List 500, List 501, List 502, List 503, List 600, List 900, List 930)		
Disconnect Contactor, 2000 A	549026 (List CC)		
For equipment provided with <b>two</b> SP	D assemblies per output voltage	circuit	
List 100, 101, 102, and 203 only: SPD (Surge Protection Device) Replacement Plug-in Module (Replacement module for SPD P/N 10034885. Each SPD P/N 10034885 has two P/N 10035033 replacement modules. Both modules should be replaced at the same time.)	10035033		
List 100, 101, 102, and 203 only: SPD (Surge Protection Device) Replacement Assembly (includes SPD mounting base with two installed P/N 10035033 SPD plug-in modules.)	10034885		

Table 30 (cont'd on next page) User Replaceable Components

Item	Part Number					
For equipment provided with <u>one</u> SPD assembly per output voltage circuit						
List 100, 101, 102, and 203 only: SPD (Surge Protection Device) Replacement Plug-in Module (Replacement module for SPD P/N 10060979. Each SPD P/N 10060979 (Phoenix Contact Version) has four P/N 10035033 (Phoenix Contact only) replacement modules. All four modules should be the same.	10035033 (Phoenix Contact only)					
List 100, 101, 102, and 203 only: SPD (Surge Protection Device) Replacement Assembly (includes SPD mounting base with four installed P/N 10035033 SPD plug-in modules.)	10060979 (Phoenix Contact version)					
List 100, 101, 102, and 203 only: SPD (Surge Protection Device) Replacement Plug-in Module (Replacement module for SPD P/N 10060979. Each SPD P/N 10060979 (Bourns Version) has two P/N 10071911 replacement modules. Both modules should be replaced at the same time.)	10071911 (Bourns only)					
List 100, 101, 102, and 203 only: SPD (Surge Protection Device) Replacement Assembly (includes SPD mounting base with two installed P/N 10071911 SPD plug-in modules.)	10060979 (Bourns version)					

Table 30 (cont'd from previous page) User Replaceable Components


## Replacement Bay-to-Bay Interconnect Cable

#### **Ordering Notes**

For a replacement cable, order P/N 514640
 (25' Cat5 communications cable terminated in RJ-45 connectors).

## Special Application Rectifier Bus Landing Point Kit P/N 563686

Special application rectifier bus landing point kit P/N 563686 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. Kit P/N 563686 includes two (2) P/N 563574 Bus Landing Point Assemblies. When installed, the kit provides rectifier bus landing points for 500 kcmil cables.



# **DC Generator Input Circuit Breaker Kit**

#### P/N 564219

Kit P/N 564219 is available for use with List 100, 101, 102, 203, 500, 501, 502, and 503. This kit provides the components to install a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies DC generator input power to the system. This kit includes an EIB card for monitoring the shunt included with this kit. For field installation, refer to IM564219. For wiring a DC generator to the circuit breaker, refer to Figure 1.




Figure 1
Wiring DC Generator Input Circuit Breaker Kit P/N 564219

#### P/N 60141027

Kit P/N 60141027 is available for use with List 600, 601, 900, 901, 930 and 931. This kit provides the components to accept a 400 A circuit breaker to feed the rectifier output bus of the power system through a shunt. A customer connects an external DC generator output to this circuit breaker which then supplies DC generator input power to the system. For field installation, refer to IM60141027. For wiring a DC generator to the circuit breaker, refer to Figure 2.

Also order as required a 400 A DC generator input circuit breaker P/N 150860.

This kit includes an EIB card for monitoring the shunt included with the kit.

Landing points for two 4/0 AWG cables (per polarity) terminated in two-hole lugs (3/8" bolt clearance hole, 1" centers).

Load should not exceed 75% of the 400 A DC generator input breaker rating (300 A).

Maximum lug width is 1.25".





Figure 2
Wiring DC Generator Input Circuit Breaker Kit P/N 60141027

# DC Generator Input Landing Kit P/N 10067484

Kit P/N 10067484 is available for use with List 600, 601, 900, and 901. This kit provides DC generator input landing points on the rectifier output bus of the power system. This allows for connection of an external DC generator input provided through an external 600 A DC generator output breaker. This kit includes an EIB card for monitoring an external shunt. For field installation, refer to IM10067484. For wiring a DC generator to the landing points, refer to Figure 3.



Rear

Rear AC cover removed in illustration for clarity only.

Apply electrical anti-oxidation compound to busbar mating surfaces.

3/8-16 Nut (Torque to 300 in-lbs.) 3/8" Lock Washer 3/8" Flat Washer

DC Generator Input (-48 VDC)

DC Generator Input (Return)

Landing points for two cables (per polarity) terminated in two-hole lugs (3/8" bolt clearance hole, 1" centers).

Maximum lug width is 1.25".

Figure 3
Wiring DC Generator Input Landing Kit P/N 10067484

# DC Generator Input Landing Kit P/N 60177224

Kit P/N 60177224 is available for use with Lists 930 and 931. This kit provides DC generator input landing points on the rectifier output bus of the power system. This allows for connection of an external DC generator input provided through an external 600 A DC generator output breaker. This kit includes an EIB card for monitoring an external shunt. For field installation, refer to IM10067484. For wiring a DC generator to the landing points, refer to Figure 4.

or C) DC Generator Input (Return)

Rear AC cover removed in illustration for clarity only.

Apply electrical anti-oxidation compound to busbar mating surfaces.

3/8-16 Nut (Torque to 300 in-lbs.) 3/8" Lock Washer 3/8" Flat Washer

DC Generator Input (-48 VDC)

Landing points for two cables (per polarity) terminated in two-hole lugs (3/8" bolt clearance hole, 1" centers).

Maximum lug width is 1.25".

Figure 4
Wiring DC Generator Input Landing Kit P/N 60177224

# RECOMMENDED WIRE SIZES, BRANCH CIRCUIT PROTECTION, CRIMP LUGS, AND WIRING ILLUSTRATIONS

# Relay Rack and Equipment Enclosure Frame Grounding Requirements

For relay rack and equipment enclosure frame grounding requirements, refer to the current edition of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC), applicable local codes, and your specific site requirements.

A customer's grounding network lead can be attached to the top of each relay rack or equipment enclosure. Provision is made for installing a lead with a two-hole lug that has 1/4" bolt clearance holes on 5/8" centers. Refer to Table 19 for lug selection.

## List 600, 601, 900, 901 Power System Shelf Frame Grounding Requirements

For List 600, 601, 900, 901 power system shelf frame grounding requirements, refer to the current edition of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC), applicable local codes, and your specific site requirements.

The frame grounding connection to the power system shelf is made by using grounding washers with the mounting hardware used to secure the power system shelf to the relay rack or equipment cabinet. Refer to the system installation manual for a procedure. Ensure that the relay rack or equipment cabinet is properly grounded.

Two sets of frame grounding studs are also provided on the rear of the power system shelf. These provide for the installation of a lead with a two-hole lug that has 1/4-inch bolt clearance holes on 5/8-inch centers. Connect a frame grounding lead to one set of studs as required. Refer to Figure 5 for location and recommended torque for this connection.

Recommended frame ground wire size is 6 AWG.





Figure 5 List 600, 601, 900, 901 Power System Shelf Frame Ground Connection

# SPD (Surge Protection Device) (if equipped) Earth Ground Connection

A landing point is provided on the top of the distribution cabinet for an SPD (Surge Protection Device) (if installed) earth ground lead. If installed, the SPD (Surge Protection Device) Assemblies are located on the underneath side of the distribution cabinet top cover panel. A busbar accessed from the top of the distribution cabinet is provided for the SPD earth ground connection. The busbar has two (2) 1/4 20 x 1/2" long threaded studs on 5/8" centers. A 2-hole, 5/8" centers, 1/4" hardware, 2 AWG flex wire crimp lug is provided with the power system. An opening in the top cover permits the compression lug to be routed either to the left of to the right. Refer to Figure 6.



SPD (Surge Protection Device) Earth Ground Connection (if equipped)

# Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System System Application Guide

# Field Installed Module Mounting Assembly Shelf Frame Grounding Connection

# Spec. No. 588705300 and 588705400

Located on the rear of the module mounting assembly are terminals for a ground connection (M4 hardware included). See Figure 7, Figure 8, Figure 9, Figure 10.

For module mounting assembly grounding requirements, refer to the current edition of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC), applicable local codes, and your specific site requirements.

# **Rectifier AC Input Connections**

AC Input Branch Circuit Protection and Wire Size Selection for AC Input Termination Assembly List 40, 41, 42 when used with 588705300 Module Mounting Assemblies with Rectifiers

Refer to the following tables for recommended wire sizes and branch circuit protection.

AC Input to List 40 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, Single Phase, 50 Hz / 60 Hz) Provides "1 AC Feed per 1 Rectifier" Single Phase Input Terminations (System with Spec. No. 58870530001 Rectifier Module Assemblies) 40 °C Ambient **Temperature** Input Overcurrent Input Voltage Current (7) Protection (1) Conduit Wire (2) (3) (4) Size (5) (6) 208 VAC 10 A 15 A 14 AWG 3/4" 240 VAC 8.8 A 15 A 14 AWG 3/4"

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>3</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> THHN 90°C Wire.
- <sup>5</sup> System with Four (4) Spec. No. 588705300 Rectifier Module Assemblies: Conduit sized for twelve (12) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Five (5) Spec. No. 588705300 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for twelve (12) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>7</sup> Input current based on R48-2000E3 rectifier module.

Table 31

Recommended AC Input Branch Circuit Protection and Wire Size when Using List 40 "1 AC Feed per 1 Rectifier – Single Phase" AC Input Termination Assembly, System with Spec. No. 58870530001 Rectifier Module Assemblies

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

AC Input to List 41 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, Single Phase, 50 Hz / 60 Hz)

Provides "1 AC Feed per 2 Rectifiers" Single Phase Input Terminations (System with Spec. No. 58870530001 Rectifier Module Assemblies)

Input Voltage	Input	Overcurrent	40 °C Ambient Temperature		
input voitage	Current (8)	Protection (1)	Wire (3) (4) (5)	Conduit Size <sup>(6) (7)</sup>	
208 VAC	20 A	25 A <sup>(2)</sup>	10 AWG	3/4"	
240 VAC	17.5 A	25 A <sup>(2)</sup>	10 AWG	3/4"	

- <sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.
- <sup>2</sup> Maximum over current protection device is 30 A.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> THHN 90°C Wire.
- <sup>6</sup> System with Four (4) Spec. No. 588705300 Rectifier Module Assemblies: Conduit sized for four (4) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for four (4) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Five (5) Spec. No. 588705300 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for six (6) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>8</sup> Input current based on R48-2000E3 rectifier module.

#### Table 32

Recommended AC Input Branch Circuit Protection and Wire Size when Using List 41 "1 AC Feed per 2 Rectifiers – Single Phase" AC Input Termination Assembly, System with Spec. No. 58870530001 Rectifier Module Assemblies

# AC Input to List 42 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, Three Phase, 50 Hz / 60 Hz) Provides "1 AC Feed per 3 Rectifiers" 3 Phase Input Terminations (System with Spec. No. 58870530001 Rectifier Module Assemblies)

Innut Valtage	Input Overcurrent		40 °C Ambient Temperature		
Input Voltage	Current <sup>(8)</sup>	Protection (1)	Wire (3) (4) (5)	Conduit Size	
208 VAC	17.5 A	25 A <sup>(2)</sup>	10 AWG	1/2" <sup>(6)</sup> 3/4" <sup>(7)</sup>	
240 VAC	15 A	20 A <sup>(2)</sup>	12 AWG	1/2" (6) (7)	

- <sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.
- <sup>2</sup> Maximum over current protection device is 30 A.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> THHN 90°C Wire.
- <sup>6</sup> System with Four (4) Spec. No. 588705300 Rectifier Module Assemblies: Conduit sized for three (3) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for three (3) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Five (5) Spec. No. 588705300 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for six (6) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>8</sup> Input current based on R48-2000E3 rectifier module.
- <sup>9</sup> The three-phase input is internally distributed within the system to provide a single-phase line to line connection to each rectifier position, evenly distributed across the three phases.

# Table 33

Recommended AC Input Branch Circuit Protection and Wire Size when Using List 42 "1 AC Feed per 3 Rectifiers – Three Phase" AC Input Termination Assembly, System with Spec. No. 58870530001 Rectifier Module Assemblies

# AC Input Branch Circuit Protection and Wire Size Selection for AC Input Termination Assembly List 40, 41, 42, 43 when used with 588705400 Module Mounting Assemblies with Rectifiers

Refer to the following tables for recommended wire sizes and branch circuit protection.

AC Input to List 40 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz) Provides "1 AC Feed per 1 Rectifier" Single Phase Input Terminations (System with Spec. No. 58870540001 Rectifier Module Assembly)

Innut Valtage	Input	Overcurrent	40 °C Ambient Temperature		
Input Voltage	Current (5)	Protection (1)	Wire (3) (4) (6)	Conduit Size <sup>)</sup>	
208 VAC	17.9 A	25 A <sup>(2)</sup>	10 AWG	3/4" <sup>(7)</sup>	
240 VAC	15.5 A	20 A	10 AWG	1" <sup>(8) (9)</sup>	
277 VAC	13.5 A	20 A	10 AWG 1" <sup>(8) (9)</sup>		

- <sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.
- <sup>2</sup> Maximum over current protection device is 30 A @ 40 °C.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3500E3 rectifier module.
- <sup>6</sup> THHN 90°C Wire.
- System with Five (5) Spec. No. 588705400 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for eight (8) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for four (4) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Five (5) Spec. No. 588705400 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for twelve (12) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes. Five (5) factory wired rectifier shelves is the maximum number of shelves available in the relay rack version of the equipment. The sixth rectifier shelf must be an expansion shelf.
- System with Six (6) Spec. No. 588705400 Rectifier Module Assemblies: Conduit sized for twelve (12) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes. Six (6) factory wired and installed rectifier shelves are only available with the enclosure version of the equipment and must be used with the five (5) 3/4 inch conduit opening plate option.

#### Table 34

Recommended AC Input Branch Circuit Protection and Wire Size when Using List 40 "1 AC Feed per 1 Rectifier – Single Phase" AC Input Termination Assembly, System with Spec. No. 58870540001 Rectifier Module Assemblies

AC Input to List 41 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz) Provides "1 AC Feed per 2 Rectifiers" Single Phase Input Terminations (System with Spec. No. 58870540001 Rectifier Module Assemblies)

Innut Valtage	Input Overcurrent		40 °C Ambient Temperature		
Input Voltage	Current (5)	Protection (1)	Wire (3) (4) (6)	Conduit Size	
208 VAC	35.8 A	45 A	8 AWG	3/4" <sup>(7)</sup> 1" <sup>(8)</sup>	
240 VAC	31.0 A	40 A <sup>(2)</sup>	8 AWG	3/4" <sup>(7)</sup> 1" <sup>(8)</sup>	
277 VAC	27.0 A	35 A <sup>(2)</sup>	8 AWG	3/4" <sup>(7)</sup> 1" <sup>(8)</sup>	

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3500E3 rectifier module.
- <sup>6</sup> THHN 90°C Wire.
- System with Five (5) Spec. No. 588705400 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for four (4) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for four (4) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Six (6) Spec. No. 588705400 Rectifier Module Assemblies: Conduit sized for six (6) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.

#### Table 35

Recommended AC Input Branch Circuit Protection and Wire Size when Using List 41 "1 AC Feed per 2 Rectifiers – Single Phase" AC Input Termination Assembly, System with Spec. No. 58870540001 Rectifier Module Assemblies

<sup>&</sup>lt;sup>2</sup> Maximum over current protection device is 45 A @ 40 °C.

AC Input to List 42 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, Three Phase, 50 Hz / 60 Hz)

Provides "1 AC Feed per 3 Rectifiers" 3 Phase Input Terminations (9)
(System with Spec. No. 58870540001 Rectifier Module Assemblies)

Innut Valtage	Input	Overcurrent	40 °C Ambient Temperature		
Input Voltage	Current (5)	Protection (1)	Wire (3) (4) (6)	Conduit Size <sup>(7) (8)</sup>	
208 VAC	31 A	40 A <sup>(2)</sup>	8 AWG	1"	
240 VAC	27 A	35 A <sup>(2)</sup>	8 AWG	1"	

- <sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.
- <sup>2</sup> Maximum over current protection device is 45 A @ 40 °C.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3500E3 rectifier module.
- <sup>6</sup> THHN 90°C Wire.
- System with Five (5) Spec. No. 588705400 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for six (6) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Six (6) Spec. No. 588705400 Rectifier Module Assemblies: Conduit sized for six (6) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- The three-phase input is internally distributed within the system to provide a single-phase line to line connection to each rectifier position, evenly distributed across the three phases.

#### Table 36

Recommended AC Input Branch Circuit Protection and Wire Size when Using List 42 "1 AC Feed per 3 Rectifiers – Three Phase" AC Input Termination Assembly, System with Spec. No. 58870540001 Rectifier Module Assemblies


AC Input to List 43 AC Input Termination Assembly (Nominal 277/480 VAC, Three Phase, 50 Hz / 60 Hz) Provides "1 AC Feed per 3 Rectifiers" 3 Phase Input Terminations (8) (System with Spec. No. 58870540001 Rectifier Module Assemblies) 40 °C Ambient **Temperature** Input Overcurrent **Input Voltage** Current (4) Protection (1) Conduit Wire (2) (3) (5) Size (6) (7) 277/480 VAC 13.5 A 20 A **12 AWG** 3/4"

- 1 The AC input branch circuit protective device should be of the time-delay or high inrush type.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>3</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Input current based on R48-3500E3 rectifier module.
- <sup>5</sup> THHN 90°C Wire.
- System with Five (5) Spec. No. 588705400 Rectifier Module Assemblies / Assembly #6 is an Expansion Assembly: Conduit sized for six (6) current carrying conductors, two (2) neutrals, and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- System with Six (6) Spec. No. 588705400 Rectifier Module Assemblies: Conduit sized for six (6) current carrying conductors, two (2) neutrals, and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>8</sup> The three-phase input is internally distributed within the system to provide a single-phase line to neutral connection to each rectifier position, evenly distributed across the three phases. If there is an input phase imbalance, the neutral may be carrying current up to the highest value of the line currents.

# Table 37


Recommended AC Input Branch Circuit Protection and Wire Size when Using List 43 "1 AC Feed per 3 Rectifiers – Three Phase" AC Input Termination Assembly, System with Spec. No. 58870540001 Rectifier Module Assemblies AC Input Connections to AC Input Termination Assembly List 40 Illustration when Used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 1 Rectifier, Single Phase)

## **Installed in a Relay Rack**




AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Five (5) Shelves Installed

## **Installed in a Relay Rack**



AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Four (4) Shelves Installed

# **Installed in a Relay Rack**



AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Three (3) Shelves Installed

NOTE:


## **Installed in a Relay Rack**

AC INPUT CONNECTIONS, 1 FEED PER 2 RECTIFIERS, SINGLE PHASE (582127000 LIST 41). with Three (3) Shelves Installed

- 1	Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #1
	Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #2
	Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #3

Rectifier Module (PCU) Mounting Slots

FRAME GROUND



CONNECTION Four 10-32 X 3/4" Studs and Hardware. Recommended torque: 23 in-lbs.

**GND** 

**GND** 

Wire Size Capacity: 6-14 AWG.

0

Connect Line 1 to Terminal L1.

Connect Line 2 to Terminal L2/N.


Line to Neutral Connect Line to Terminal L1. Connect Neutral to Terminal L2/N.


**GND** 

RECTIFIER (PCU) AC INPUT FEEDS Recommended Torque: 18 in-lbs. 1 FEED PER 2 RECTIFIERS (PCU)
208 VAC. 240 VAC. 277 VAC. 50 Hz / 60Hz. SINGLE PHASE SHELVES 1 AND 2 PCU 1 PCU 2 <u> 1</u>1 L2/N L2/N L2/N SHELF 1/2 0 0 PCU 1 L1 L2/N PCU 2 L1 L2/N PCU 3 L1 L2/N (

Line to Line:

RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60Hz, SINGLE PHASE





RECTIFIER (PCU) AC INPUT FEEDS


B in-lbs. 1 FEED PER 2 RECTIFIERS (PCU)
208 VAC, 240 VAC, 277 VAC, 50 Hz / 60Hz, SINGLE PHASE

Ō

GND

AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with Two (2) Shelves Installed

## **Installed in a Relay Rack**



 $\circ$ 


0

0

0

AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705300 (Nominal 208 VAC, 240 VAC) or 588705400 (Nominal 208 VAC, 240 VAC, 277 VAC) Module Mounting Assemblies with Rectifiers (1 Feed per 2 Rectifiers, Single Phase) - with One (1) Shelf Installed

# **Installed in a Relay Rack**



Line to Line:

Recommended torque:

23 in-lbs.

**GND** 


Connect Line 1 to Terminal L1.
Connect Line 2 to Terminal L2/N.


**GND** 

Line to Neutral
Connect Line to Terminal L1.
Connect Neutral to Terminal L2/N.

**GND** 

Wire Size Capacity: 6-14 AWG. Recommended Torque: 18 in-lbs.






Recommended torque:

23 in-lbs.

AC Input Connections to AC Input Termination Assembly List 42 Illustration when used with 588705300 or 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC) (1 Feed per 3 Rectifiers, Three Phase)


#### **Installed in a Relay Rack**



Note: For fewer power shelves than shown, only the connections for the installed shelves are present. Note: The three-phase input is internally distributed within the system to provide a single-phase line to line connection to each rectifier position, evenly distributed across the three phases.

# AC Input Connections to AC Input Termination Assembly List 43 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 277/480 VAC) (1 Feed per 3 Rectifiers, Three Phase)

## **Installed in a Relay Rack**



Note: For fewer power shelves than shown, only the connections for the installed shelves are present. Note: The three-phase input is internally distributed within the system to provide a single-phase line to neutral connection to each rectifier position, evenly distributed across the three phases.

AC Input Connections to AC Input Termination Assembly List 40 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 1 Rectifier, Single Phase)

#### Installed in an Enclosure


AC INPUT CONNECTIONS, 1 FEED PER 1 RECTIFIER, SINGLE PHASE (582127000 LIST 40)

Shelf #1	Rect. (PCU) 6	Rect. (PCU) 5	Rect. (PCU) 4	Rect. (PCU) 3	Rect. (PCU) 2	Rect. (PCU) 1
Shelf #2	Rect. (PCU) 6	Rect. (PCU) 5	Rect. (PCU) 4	Rect. (PCU) 3	Rect. (PCU) 2	Rect. (PCU)
Shelf #3	Rect. (PCU) 6	Rect. (PCU) 5	Rect. (PCU) 4	Rect. (PCU) 3	Rect. (PCU) 2	Rect. (PCU)
Shelf #4	Rect. (PCU) 6	Rect. (PCU) 5	Rect. (PCU) 4	Rect. (PCU) 3	Rect. (PCU) 2	Rect. (PCU) 1
Shelf #5	Rect. (PCU) 6	Rect. (PCU) 5	Rect. (PCU) 4	Rect. (PCU) 3	Rect. (PCU) 2	Rect. (PCU) 1
Shelf #6	Rect. (PCU) 6	Rect. (PCU) 5	Rect. (PCU) 4	Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)


Rectifier Module (PCU) Mounting Slots


FRAME GROUND
CONNECTION
Four 10-32 X 3/4"
Studs and Hardware.
Recommended torque:
23 in-lbs.


RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 1 RECTIFIER (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE











Note: Customer wiring to top terminals of terminal blocks. For fewer power shelves than shown, only the connections for the installed shelves are present.

Line to Line:
Connect Line 1 to Terminal L1.
Connect Line 2 to Terminal L2/N.


Line to Neutral


Connect Line to Terminal L1.

Connect Neutral to Terminal L2/N.

SHELF 3

000000000





PCU #6 PCU #5 PCU #4 PCU #6 PCU #5 PCU #4

.1 L2/N L1 L2/N L1 L2/N L1 L2/N L1 L2/N L1 L2/N

SHELF 4


AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Six (6) Shelves Installed

## **Installed in an Enclosure**


AC INPUT CONNECTIONS, 1 FEED PER 2 RECTIFIERS, SINGLE PHASE (582127000 LIST 41), with Six (6) Shelves Installed


Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #1
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #2
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #3
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #4
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #5
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #6

Rectifier Module (PCU) Mounting Slots



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE





Note: Customer wiring to top terminals of terminal blocks.


For fewer power shelves than shown, only the connections for the installed shelves are present.

Line to Line:
Connect Line 1 to Terminal L1.
Connect Line 2 to Terminal L2/N.

SHELVES 5 AND 6

<u>Line to Neutral</u>
Connect Line to Terminal L1.
Connect Neutral to Terminal L2/N.

L1 L2/N L1 L2/N L1 L2/N



AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Five (5) **Shelves Installed** 

NOTE:

OF THE SHELF.

WIRING TO A FIELD INSTALLED

SHELF IS DONE AT THE REAR

(4-Row Cabinet Shown, Others Similar)


## **Installed in an Enclosure**

AC INPUT CONNECTIONS. 1 FEED PER 2 RECTIFIERS. SINGLE PHASE (582127000 LIST 41), with Five (5) Shelves Installed

Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #1
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #2
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #3
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #4
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #5


Rectifier Module (PCU) Mounting Slots

SHELVES 3 AND 4



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE

SHELVES 1 AND 2






Note: Customer wiring to top terminals of terminal blocks.

Line to Line: Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N.

SHFLF 5

AC Input Connector Cover Wire Size Capacity: 4 AWG to 14 AWG. Recommended Torque: 10-14 AWG 20 in-lbs. 8 AWG 25 in-lbs. 4 AWG 35 in-lbs. FRAME GROUND Inside View **CONNECTION** Right Side Four 10-32 X 3/4" Studs and Hardware. Recommended torque: 23 in-lbs. RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU)

208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE



For fewer power shelves than shown, only the connections for the installed shelves are present.

Line to Neutral

Connect Line to Terminal L1. Connect Neutral to Terminal L2/N. AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Four (4) Shelves Installed

NOTE:

## **Installed in an Enclosure**

AC INPUT CONNECTIONS, 1 FEED PER 2 RECTIFIERS, SINGLE PHASE (582127000 LIST 41),

with Four (4) Shelves Installed

Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #1
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #2
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #3
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #4

Rectifier Module (PCU) Mounting Slots

FRAME GROUND


**CONNECTION** 

Four 10-32 X 3/4"


Studs and Hardware.

Recommended torque:

23 in-lbs.



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE




RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE

Studs and Hardware.

Recommended torque:

23 in-lbs.



Note: Customer wiring to top terminals of terminal blocks.

For fewer power shelves than shown, only the connections for the installed shelves are present.

<u>Line to Line:</u>
Connect Line 1 to Terminal L1.
Connect Line 2 to Terminal L2/N.

Line to Neutral
Connect Line to Terminal L1.
Connect Neutral to Terminal L2/N.

AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Three (3) Shelves Installed

## **Installed in an Enclosure**


AC INPUT CONNECTIONS, 1 FEED PER 2 RECTIFIERS, SINGLE PHASE (582127000 LIST 41),

with Three (3) Shelves Installed


Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #1
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #2
Rect. (PCU)	Rect. (PCU) 2	Rect. (PCU)	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #3

Rectifier Module (PCU) Mounting Slots

Wire Size Capacity:
4 AWG to 14 AWG.
Recommended Torque:
10-14 AWG 20 in-lbs.
8 AWG 25 in-lbs.
4 AWG 35 in-lbs.



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE



Note: Customer wiring to top terminals of terminal blocks.


For fewer power shelves than shown, only the connections for the installed shelves are present.


Inside View

Left Side


<u>Line to Line:</u>
Connect Line 1 to Terminal L1.
Connect Line 2 to Terminal L2/N.

Line to Neutral
Connect Line to Terminal L1.
Connect Neutral to Terminal L2/N.





RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE



AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with Two (2) **Shelves Installed** 

NOTE:

OF THE SHELF.

WIRING TO A FIELD INSTALLED

Others Similar)

AC Input Connector Cover

SHELF IS DONE AT THE REAR

(4-Row Cabinet Shown,

## Installed in an Enclosure


AC INPUT CONNECTIONS. 1 FEED PER 2 RECTIFIERS, SINGLE PHASE (582127000 LIST 41),

with Two (2) Shelves Installed

Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 4	Rect. (PCU) 6	Shelf #1
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 4	Rect. (PCU) 6	Shelf #2


Rectifier Module (PCU) Mounting Slots

Wire Size Capacity: 4 AWG to 14 AWG. Recommended Torque: 10-14 AWG 20 in-lbs. 8 AWG 25 in-lbs. 4 AWG 35 in-lbs.



Inside View Left Side


RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU)



208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE

FRAME GROUND Inside View **CONNECTION** Right Side Four 10-32 X 3/4" Studs and Hardware. Recommended torque: 23 in-lbs.

RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE



Note: Customer wiring to top terminals of terminal blocks.

For fewer power shelves than shown, only the connections for the installed shelves are present.

Line to Line:

Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N. Line to Neutral

Connect Line to Terminal L1. Connect Neutral to Terminal L2/N. AC Input Connections to AC Input Termination Assembly List 41 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC, 277 VAC) (1 Feed per 2 Rectifiers, Single Phase) - with One (1) Shelf

NOTE:


OF THE SHELF.

WIRING TO A FIELD INSTALLED SHELF IS DONE AT THE REAR

(4-Row Cabinet Shown,


## Installed in an Enclosure

AC INPUT CONNECTIONS. 1 FEED PER 2 RECTIFIERS, SINGLE PHASE (582127000 LIST 41), with One (1) Shelf Installed




Rectifier Module (PCU) Mounting Slots

Wire Size Capacity: 4 AWG to 14 AWG. Recommended Torque: 10-14 AWG 20 in-lbs. 8 AWG 25 in-lbs. 4 AWG 35 in-lbs.



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE




Others Similar) AC Input Connector Cover FRAME GROUND Inside View **CONNECTION** Left Side Right Side Four 10-32 X 3/4" Studs and Hardware.

> RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS (PCU) 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE

Recommended torque:

23 in-lbs.



Note: Customer wiring to top terminals of terminal blocks.

For fewer power shelves than shown, only the connections for the installed shelves are present.

Inside View

Line to Line: Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N.

Line to Neutral Connect Line to Terminal L1. Connect Neutral to Terminal L2/N. AC Input Connections to AC Input Termination Assembly List 42 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 208 VAC, 240 VAC) (1 Feed per 3 Rectifiers, Three Phase)

#### Installed in an Enclosure


AC INPUT CONNECTIONS, 1 FEED PER 3 RECTIFIERS, THREE PHASE (582127000 LIST 42)

Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #1
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #2
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #3
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #4
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #5
Rect. (PCU) 1	Rect. (PCU) 2	Rect. (PCU) 3	Rect. (PCU) 4	Rect. (PCU) 5	Rect. (PCU) 6	Shelf #6


Rectifier Module (PCU) Mounting Slots

NOTE: WIRING TO A FIELD INSTALLED SHELF IS DONE AT THE REAR OF THE SHELF. (4-Row Cabinet Shown. Others Similar) AC Input Connector Cover Wire Size Capacity: 4 AWG to 14 AWG. Recommended Torque: 10-14 AWG 20 in-lbs. 8 AWG 25 in-lbs. 4 AWG 35 in-lbs. Inside View Inside View Left Side Right Side

RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 3 RECTIFIERS (PCU) 208 VAC / 240 VAC, 50 Hz / 60 Hz, THREE PHASE



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 3 RECTIFIERS (PCU) 208 VAC / 240 VAC, 50 Hz / 60 Hz, THREE PHASE



Note: Customer wiring to top terminals of terminal blocks.

For fewer power shelves than shown, only the connections for the installed shelves are present.

Note: The three-phase input is internally distributed within the system to provide a single-phase line to line connection to each rectifier position, evenly distributed across the three phases.


# AC Input Connections to AC Input Termination Assembly List 43 Illustration when used with 588705400 Module Mounting Assemblies with Rectifiers (Nominal 277/480 VAC) (1 Feed per 3 Rectifiers, Three Phase)

#### Installed in an Enclosure


AC INPUT CONNECTIONS, 1 FEED PER 3 RECTIFIERS, THREE PHASE (582127000 LIST 43)


Rect.	Rect.	Rect.	Rect.	Rect.	Rect.	Shelf #1
(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	
1	2	3	4	5	6	
Rect.	Rect.	Rect.	Rect.	Rect.	Rect.	Shelf #2
(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	
1	2	3	4	5	6	
Rect.	Rect.	Rect.	Rect.	Rect.	Rect.	Shelf #3
(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	
1	2	3	4	5	6	
Rect.	Rect.	Rect.	Rect.	Rect.	Rect.	Shelf #4
(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	
1	2	3	4	5	6	
Rect.	Rect.	Rect.	Rect.	Rect.	Rect.	Shelf #5
(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	
1	2	3	4	5	6	
Rect.	Rect.	Rect.	Rect.	Rect.	Rect.	Shelf #6
(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	(PCU)	
1	2	3	4	5	6	

Rectifier Module (PCU) Mounting Slots



RECTIFIER (PCU) AC INPUT FEEDS 1 FEED PER 3 RECTIFIERS (PCU) 277 VAC / 480 VAC, 50 Hz / 60 Hz, THREE PHASE






23 in-lbs.

RECTIFIER (PCU) AC INPUT FEEDS

1 FEED PER 3 RECTIFIERS (PCU)

277 VAC / 480 VAC, 50 Hz / 60 Hz, THREE PHASE

Recommended torque:



Note: Customer wiring to top terminals of terminal blocks.

For fewer power shelves than shown, only the connections for the installed shelves are present.

Note: The three-phase input is internally distributed within the system to provide a single-phase line to neutral connection to each rectifier position, evenly distributed across the three phases.

# AC Input Branch Circuit Protection and Wire Size Selection (List 100, 101, 102, 203, 500, 501, 502, 503) (Nominal 208 VAC, 240 VAC)

Refer to the following table for recommended wire sizes and branch circuit protection.

	AC Input to List 100, 101, 102, 203, 500, 501, 502, 503 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, Single Phase, 50 Hz / 60 Hz)  Provides "1 AC Feed per 2 Rectifiers" Single Phase Input Terminations						
Innut Valtage	Input Current	Overcurrent	40 °C Ambient Temperature				
Input Voltage	(7)	Protection (1)	Wire (3) (4) (5)	Conduit Size <sup>(6)</sup>			
208 VAC	20 A	25 A <sup>(2)</sup>	10 AWG	3/4"			
240 VAC	17.5 A	25 A <sup>(2)</sup>	10 AWG	3/4"			

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> THHN 90°C Wire.
- <sup>6</sup> System with Four (4) Spec. No. 588705300 Rectifier Module Assemblies: Conduit sized for six (6) current carrying conductors and one (1) ground conductor per conduit (based on NEC recommendations), for six (6) PCUs. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>7</sup> Input current based on R48-2000E3 rectifier module.

Table 38

Recommended AC Input Branch Circuit Protection and Wire Size (List 100, 101, 102, 203, 500, 501, 502, 503)

<sup>&</sup>lt;sup>2</sup> Maximum over current protection device is 30 A.

# AC Input Connections to AC Input Termination Assembly in List 100, 101, 102, 203, 500, 501, 502, 503 Illustration (Nominal 208 VAC, 240 VAC)


RECTIFIER AC INPUT FEEDS 1 FEED PER 2 RECTIFIERS 208 VAC / 240 VAC, 50 Hz / 60 Hz, SINGLE PHASE


Line to Line:

Connect Line 1 to Terminal "AC 1". Connect Line 2 to Terminal "AC 2".

Wire Size Capacity: 6-14 AWG. Recommended Torque: 18 in-lbs.

Rect.	Rect.	Rect.	Rect.	Rect. 5	Rect.	Shelf #1
Rect.	Rect.	Rect.	Rect.	Rect. 5	Rect.	Shelf #2
Rect.	Rect.	Rect.	Rect.	Rect. 5	Rect.	Shelf #3
Rect.	Rect.	Rect.	Rect.	Rect. 5	Rect.	Shelf #4





ũ

ũ

# AC Input Branch Circuit Protection and Wire Size Selection (List 600, 601, 900, 901) (Nominal 208 VAC, 240 VAC, 277 VAC)

Refer to the following tables for recommended wire sizes and branch circuit protection.

**Note:** Two-position bridge jumpers are factory-installed. All jumpers are required for dual feed. Remove all jumpers for single feed.

AC Input to List 600, 601, 900, 901 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz)  Provides "1 AC Feed per 1 Rectifier" Single Phase Input Terminations)							
Innut Valtaga	Input Current <sup>(5)</sup>	Overcurrent Protection <sup>(1)</sup>	40°C Ambient Temperature				
Input Voltage			Wire (3) (4) (6)	Conduit Size			
208 VAC	17.9 A	25 A <sup>(2)</sup>	10 AWG	3/4"			
240 VAC	15.5 A	20 A	10 AWG	3/4"			
277 VAC	13.5 A	20 A	10 AWG	3/4"			

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3500E3 rectifier module.
- <sup>6</sup> THHN 90°C Wire.

Table 39

Recommended AC Input Branch Circuit Protection and Wire Size (List 600, 601, 900, 901)

"1 AC Feed per 1 Rectifier – Single Phase"

<sup>&</sup>lt;sup>2</sup> Maximum over current protection device is 30 A @ 40 °C.

AC Input to List 600, 601, 900, 901 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz) Provides "1 AC Feed per 2 Rectifiers" Single Phase Input Terminations							
Innut Valtage	Input Current <sup>(5)</sup>	Overcurrent	40 °C Ambient Temperature				
Input Voltage		Protection (1)	Wire (3) (4) (6)	Conduit Size			
208 VAC	35.8 A	45 A	8 AWG	3/4"			
240 VAC	31.0 A	40 A <sup>(2)</sup>	8 AWG	3/4"			
277 VAC 27.0 A 35 A <sup>(2)</sup> 8 AWG 3/4"							

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3500E3 rectifier module.
- <sup>6</sup> THHN 90°C Wire.

Table 40


Recommended AC Input Branch Circuit Protection and Wire Size (List 600, 601, 900, 901)

"1 AC Feed per 2 Rectifiers – Single Phase"

<sup>&</sup>lt;sup>2</sup> Maximum over current protection device is 45 A @ 40 °C.

Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.

AC Input Connections to AC Input Termination Assembly in List 600, 601, 900, 901 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd on next page)



Wire Size Capacity: 20 AWG to 6 AWG. Recommended Torque: 15 in-lbs.

See Next Page

# AC Input Connections to AC Input Termination Assembly in List 600, 601, 900, 901 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd from previous page)

RECTIFIER AC INPUT FEEDS
208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE
(1 FEED PER 1 RECTIFIER)


Top Row R17 R16 R15 R11 R10 R9 R5 R4 R3 L1


Bottom Row R17 R16 R15 R11 R10 R9 R5 R4 R3 L2/N Line to Line: Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N.

The 2-position bridge jumpers are factory-installed. Remove all jumpers for single feed.

Top Row R2 R1 R8 R7 R6 R14 R13 R12 L1

Bottom Row R2 R1 R8 R7 R6 R14 R13 R12 L2/N





# RECTIFIER AC INPUT FEEDS 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE (1 FEED PER 2 RECTIFIERS)


Top Row R17/R16 R15/R11 R10/R9 R5/R4 R3 L1


Bottom Row R17/R16 R15/R11 R10/R9 R5/R4 R3 L2/N Line to Line: Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N.

The 2-position bridge jumpers are factory-installed. All jumpers are required for dual feed.

Top Row R2/R1 R8/R7 R6/R14 R13/R12 L1

Bottom Row R2/R1 R8/R7 R6/R14 R13/R12 L2/N





# AC Input Branch Circuit Protection and Wire Size Selection (List 930, 931) (Nominal 208 VAC, 240 VAC, 277 VAC)

Refer to the following tables for recommended wire sizes and branch circuit protection.

**Note:** Two-position bridge jumpers are factory-installed. All jumpers are required for dual feed. Remove all jumpers for single feed.

AC Input to List 930, 931, 990 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz Single Feed)  Provides "1 AC Feed per 1 Rectifier" Single Phase Input Terminations)						
Innut Valtara	Input	•	40 °C A Tempe			
Input Voltage	Current (5)		Wire (3) (4) (6)	Conduit Size		
208 VAC	18.3 A	25 A <sup>(2)</sup>	10 AWG	3/4"		
240 VAC	15.8 A	20 A	10 AWG	3/4"		
277 VAC	13.7 A	20 A	10 AWG	3/4"		

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3600E4 rectifier module.
- <sup>6</sup> THHN 90°C Wire.

Table 41

Recommended AC Input Branch Circuit Protection and Wire Size (List 930, 931)
"1 AC Feed per 1 Rectifier – Single Phase"

<sup>&</sup>lt;sup>2</sup> Maximum over current protection device is 30 A @ 40 °C.

AC Input to List 930, 931 AC Input Termination Assembly (Nominal 208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz Dual Feed) Provides "1 AC Feed per 2 Rectifiers" Single Phase Input Terminations						
Innut Valtage	Input Overcurrent			ambient erature		
Input Voltage	Current (5)	Protection (1)	·	Conduit Size		
208 VAC	36.6 A	45 A	8 AWG	3/4"		
240 VAC	31.7 A	40 A <sup>(2)</sup>	8 AWG	3/4"		
277 VAC	27.5 A	35 A <sup>(2)</sup>	8 AWG	3/4"		

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>5</sup> Input current based on R48-3600E4 rectifier module.
- <sup>6</sup> THHN 90°C Wire.


Table 42

Recommended AC Input Branch Circuit Protection and Wire Size (List 930, 931)

"1 AC Feed per 2 Rectifiers – Single Phase"

<sup>&</sup>lt;sup>2</sup> Maximum over current protection device is 45 A @ 40 °C.

# AC Input Connections to AC Input Termination Assembly in List 930, 931 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd on next page)



Wire Size Capacity: 20 AWG to 6 AWG. Recommended Torque: 15 in-lbs.

See Next Page

# AC Input Connections to AC Input Termination Assembly in List 930, 931 Illustration (Nominal 208 VAC, 240 VAC, 277 VAC) (cont'd from previous page)

#### RECTIFIER AC INPUT FEEDS 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE (1 FEED PER 1 RECTIFIER)


Top Row R17 R16 R15 R11 R10 R9 R5 R4 R3


Bottom Row R17 R16 R15 R11 R10 R9 R5 R4 R3 L2/N Line to Line: Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N.

The 2-position bridge jumpers are factory-installed. Remove all jumpers for single feed.

Top Row
R2 R1 R8 R7 R6 R14 R13 R12
L1

Bottom Row R2 R1 R8 R7 R6 R14 R13 R12 L2/N





#### RECTIFIER AC INPUT FEEDS 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, SINGLE PHASE (1 FEED PER 2 RECTIFIERS)


Top Row R17/R16 R15/R11 R10/R9 R5/R4 R3 L1


Bottom Row R17/R16 R15/R11 R10/R9 R5/R4 R3 L2/N Line to Line: Connect Line 1 to Terminal L1. Connect Line 2 to Terminal L2/N.

The 2-position bridge jumpers are factory-installed. All jumpers are required for dual feed.

Top Row R2/R1 R8/R7 R6/R14 R13/R12 L1

Bottom Row R2/R1 R8/R7 R6/R14 R13/R12 L2/N





## **AC Input Connections to Field Installed Module Mounting Assemblies**

#### Spec. No. 588705300 List 03 (120 VAC / 208 VAC / 240 VAC Input, Single Phase)

The module mounting assembly is equipped with plug-in AC input connectors located on the rear of the assembly. Mating connectors and wire harnesses are available (see "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 and "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120). Refer to Figure 7 for module mounting assembly rectifier AC input terminal location.

Refer to Table 43 for recommended AC input branch circuit protection when using the supplied rectifier AC input cable assemblies.

Refer to Table 44 for recommended AC input branch circuit protection when using the supplied rectifier AC input line cords.

# Recommended Rectifier AC Input Branch Circuit Protection (Nominal 120 VAC / 208 VAC / 240 VAC, Single Phase, 50 Hz / 60 Hz)

#### **Supplied Input Cable Assemblies**

(see "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119)

(One AC Input Branch Circuit per Two Rectifier Modules)

Input Voltage	Input Current (2)	Overcurrent Protection (1)
120 VAC	18 A	30 A
208 VAC	20 A	25 A
240 VAC	17.5 A	25 A

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

#### Table 43

Recommended Rectifier AC Input Branch Circuit Protection (Nominal 120 VAC / 208 VAC / 240 VAC, Single Phase, 50 Hz / 60 Hz) Supplied Input Cable Assemblies

#### Recommended Rectifier AC Input Branch Circuit Protection (Nominal 120 VAC / 208 VAC / 240 VAC, Single Phase, 50 Hz / 60 Hz)

Supplied AC Input Line Cords (see "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120)

(One AC Input Branch Circuit per Two Rectifier Modules)

Input Voltage	Input Current (2)	Overcurrent Protection (1)
120 VAC	18 A	
208 VAC	20 A	Size per AC Line Cord Plug Rating
240 VAC	17.5 A	Cord Flag Rating


<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

#### Table 44


Recommended Rectifier AC Input Branch Circuit Protection (Nominal 120 VAC / 208 VAC / 240 VAC, Single Phase, 50 Hz / 60 Hz) Supplied AC Input Line Cords


<sup>&</sup>lt;sup>2</sup> Input current based on R48-2000E3 rectifier module.

<sup>&</sup>lt;sup>2</sup> Input current based on R48-2000E3 rectifier module.



Rectifier AC input connections are made using the supplied AC input cable assemblies or line cords connected here.





Input Connections, 588705300 List 03

#### Spec. No. 588705400 List 02 (208 VAC, 240 VAC, 277 VAC Single Phase, 50 Hz / 60 Hz)

The module mounting assembly is equipped with plug-in AC input connectors located on the rear of the assembly. Mating connectors and wire harnesses are available (see "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119 and "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120). Refer to Figure 8 for module mounting assembly rectifier AC input terminal location.

Refer to Table 45 for recommended AC input branch circuit protection when using the supplied rectifier AC input cable assemblies.

Refer to Table 46 for recommended AC input branch circuit protection when using the supplied rectifier AC input line cords.

## Recommended Rectifier AC Input Branch Circuit Protection (208 VAC, 240 VAC, 277 VAC Single Phase, 50 Hz / 60 Hz)

#### **Supplied Input Cable Assemblies**

(see "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Cable Assemblies" on page 119)

(Connection Points for Six Single Phase AC Input Feeds are Provided per Shelf,
One AC Input Branch Circuit per One Rectifier Module)

Input Voltage	Input Current (2)	Overcurrent Protection <sup>(1)</sup>
208 VAC	17.9 A	25 A
240 VAC	15.5 A	25 A
277 VAC	13.5 A	20 A

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

#### Table 45

Recommended Rectifier AC Input Branch Circuit Protection (208 VAC, 240 VAC, 277 VAC, Single Phase, 50 Hz / 60 Hz) Supplied Input Cable Assemblies

# Recommended Rectifier AC Input Branch Circuit Protection (208 VAC, 240 VAC, Single Phase, 50 Hz / 60 Hz)

#### **Supplied AC Input Line Cords**

(see "588705300 and 588705400 Module Mounting Assembly Rectifier AC Input Line Cords" on page 120)

(Connection Points for Six Single Phase AC Input Feeds are Provided per Shelf, One AC Input Branch Circuit per One Rectifier Module)

Input Voltage	Input Current (2)	Overcurrent Protection <sup>(1)</sup>
208 VAC	17.9 A	Size per AC Line
240 VAC	15.5 A	Cord Plug Rating


<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.


Table 46


Recommended Rectifier AC Input Branch Circuit Protection (208 VAC, 240 VAC, Single Phase, 50 Hz / 60 Hz) Supplied AC Input Line Cords

<sup>&</sup>lt;sup>2</sup> Input current based on R48-3500E3 rectifier module.

<sup>&</sup>lt;sup>2</sup> Input current based on R48-3500E3 rectifier module.







Rectifier AC Input (208 VAC, 240 VAC, 277 VAC, 30 A)

Line to Line:

Connect Line 1 to Terminal 1.

Connect Line 2 to Terminal 2.

Line to Neutral

Connect Line to Terminal 1.

Connect Neutral to Terminal 2.

Figure 8 Input Connections, 588705400 List 02

#### Spec. No. 588705400 List 03 (208 VAC, 240 VAC Input, Three Phase, 50 Hz / 60 Hz)

The module mounting assembly is equipped with plug-in AC input connectors located on the rear of the assembly. Mating connectors and AC input line cords are available (P/N 562046). Refer to Figure 9 for module mounting assembly rectifier AC input terminal location.


Refer to Table 47 for recommended AC input branch circuit protection when using the supplied rectifier AC input line cords.

# Recommended Rectifier AC Input Branch Circuit Protection (208 VAC, 240 VAC, Three Phase, 50 Hz / 60 Hz) Supplied AC Input Line Cords (P/N 562046) (Connection Points for Two 3-Phase AC Input Feeds are Provided per Shelf) Input Voltage Input Current (2) Overcurrent Protection (1) 208 VAC 31 A Size per AC Line Cord Plug Rating

Table 47
Recommended Rectifier AC Input Branch Circuit Protection
(208 VAC, 240 VAC, Three Phase, 50 Hz / 60 Hz)
Supplied AC Input Line Cords

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

<sup>&</sup>lt;sup>2</sup> Input current based on R48-3500e3 rectifier module.



#### Spec. No. 588705400 List 04 (277/480 VAC Three Phase Input, 50 Hz / 60 Hz)

The module mounting assembly is equipped with plug-in AC input connectors located on the rear of the assembly. Mating connectors and AC input line cords are available (P/N 562045). Refer to Figure 10 for module mounting assembly rectifier AC input terminal location.

Refer to Table 48 for recommended AC input branch circuit protection when using the supplied rectifier AC input line cords.

Recommended Rectifier AC Input Branch Circuit Protection (277/480 VAC, Three Phase, 50 Hz / 60 Hz)						
Su	Supplied AC Input Line Cords (P/N 562045)					
(Connection Points for Two 3-Phase AC Input Feeds are Provided per shelf)						
Input Voltage Input Current (2) Overcurrent Protection (1)						
277 VAC	13.5 A	Size per AC Line Cord Plug Rating				

<sup>&</sup>lt;sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

Table 48
Recommended Rectifier AC Input Branch Circuit Protection
(277/480 VAC, Three Phase, 50 Hz / 60 Hz)
Supplied AC Input Line Cords

<sup>&</sup>lt;sup>2</sup> Input current based on R48-3500E3 rectifier module.




Figure 10 Input Connections, 588705400 List 04

#### Optional Inverter System AC Input Connections (List 50, 51, 52, 53)

#### **Inverter System AC Input Connections**

<u>Inverter System AC Input Branch Circuit Protection and Wire Size Selection (Nominal 120 VAC, Single Phase, 50 Hz / 60 Hz)</u>

Refer to the following table for recommended wire sizes and branch circuit protection. Refer to Figure 11 for an illustration.

#### Spec. No. 582127000 Lists 50, 51, 52, and 53 Inverter System Recommended AC Input Branch Circuit Protection and Wire Size

Provides Input Terminations for "One AC Feed per Inverter System" (Nominal 120 VAC, Single Phase, 50 Hz / 60 Hz)


	•		•	•			
1:-4	Overcurrent Protection	Protection (1)	Conductor	500			
List Number	Input Voltage	Input Current	OCPD Minimum	OCPD Maximum	Wire Size <sup>(2) (3) (4)</sup>	EGC Wire Size	Conduit Size (in)
	40 °C and 65 °C Ambient Temperature (5)						
List 50 List 51 120 VAC 54 A 70 A 90 A 4 AWG 8 AWG 3/							3/4"
List 52 List 53	120 VAC	108 A	150 A	150 A	1/0 AWG	6 AWG	1-1/4"

<sup>1</sup> The AC input branch circuit protective device should be of the time-delay or high inrush type.

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>3</sup> Equipment grounding conductors must be provided with the AC input conductors supplied to the module mounting assembly. Frame ground terminals must be connected to earth ground, not power system neutral. Equipment grounding conductor size based on recommendations of the NEC Table 250-122 for copper wire. If aluminum or copper clad aluminum grounding conductor is used, refer to Table 250-122 for increased conductor size. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> THHN 90°C Wire.
- <sup>5</sup> Table values are based on full-power operation of inverter modules at 40 °C ambient temperature. For systems designed to operate in a 65 °C ambient environment, wire the system using the OCPD and field-wiring sizes as recommended for 40 °C ambient temperature due to the linear power derating of the inverter module between 45 °C and 65 °C. Refer to Section 1.2.1 (AC Input Ratings) and Figure 1.1 (Power Derating Based on Temperature) of the Inverter Module User Manual (UMI1201000).

If NEC calculations for field-wiring at 65 °C indicate that a larger wire gauge should be used vs. the 40 °C wire gauge, then the calculated 65 °C gauge should be used. However, the power derating of the inverter modules should outpace any increase in gauge due to NEC wire derating.

Table 49
Spec. No. 582127000 Lists 50, 51, 52, and 53
Optional Inverter System Recommended AC Input Branch Circuit Protection and Wire Size



Wire Size Capacity: 14 AWG to 2/0 AWG.

Recommended Torque: 35 lbf.in (3.95 N.m) 12 AWG

35 lbf.in (3.95 N.m) 14 AWG

582137100 List 52 40 lbf.in (4.52 N.m) 8 AWG

582137100 List 53 120 lbf.in (13.56 N.m) 6 AWG to 2/0 AWG




Figure 11
Optional Inverter System AC Input Connections (List 50, 51, 52, 53)

#### Optional Inverter System AC Output Connections (List 50, 51, 52, 53)

**Inverter System AC Output Connections (List 50, 52)** 

### Inverter System AC Output Branch Circuit Protection and Wire Size Selection When Equipped with List 50, 52

Refer to Table 50 and Table 51 for recommended wire sizes and branch circuit protection. Refer to Figure 12 for an illustration. Each 120 VAC output is protected by a 70 A circuit breaker located on the front of the unit.

# Spec. No. List 50 Inverter System Recommended AC Output Branch Circuit Protection and Wire Size

1RU AC Termination Panel with One (1) 70 A Overcurrent Protection Device (Nominal 120 VAC, Single Phase, 50 Hz / 60 Hz)

Output	Output Output		40 °C Ambient 65 °C Ar Temperature Temper			
Voltage Current		Protection	Wire (3) (4)	Conduit Size (in) <sup>(5)</sup>	Wire (3) (4)	Conduit Size (in) <sup>(5)</sup>
120 VAC	50 A Note 1	70 A	6 AWG	3/4	4 AWG	1 Note 2

Output current determined as 50 A max (50 A X 120 VAC = 6kVA rating) for the AC distribution panel.

- <sup>2</sup> The equipment grounding conductor can be 8 AWG minimum. If the installation uses two (2) 4 AWG cables and an 8 AWG ground cable, then 3/4-inch conduit is permissible. If the equipment grounding conductor is equivalent in size to the 4 AWG current carrying cables, then a 1-inch conduit is required and cannot be accommodated on the 1RU AC distribution panel.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> THHN 90°C Wire.
- <sup>5</sup> Two current and one ground wire per conduit (one AC output conduit).

Table 50

Inverter System Recommended AC Output Branch Circuit Protection and Wire Size (List 50)

# Spec. No. List 52 Inverter System Recommended AC Output Branch Circuit Protection and Wire Size

2RU AC Termination Panel with Two (2) 70 A Overcurrent Protection Devices (Nominal 120 VAC, Single Phase, 50 Hz / 60 Hz)

Output	Output	Overcurrent	40 °C Ambient Temperature  Wire (3) (4)  Conduit Size (in) (5)		65 °C Ambient Temperature	
Voltage	Current	Protection			Wire (3) (4)	Conduit Size (in) <sup>(5)</sup>
120 VAC	56 A Note 1	70 A	4 AWG	1 Note 2	4 AWG	1 Note 2

- 1 Output current determined as 80% of the 70 A breaker that is being used in the AC distribution panel.
- <sup>2</sup> The equipment grounding conductor can be 8 AWG minimum. If the installation uses two (2) 4 AWG cables and an 8 AWG ground cable, then 3/4-inch conduit is permissible. If the equipment grounding conductor is equivalent in size to the 4 AWG current carrying cables, then a 1-inch conduit is required.
- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- <sup>4</sup> THHN 90°C Wire.
- <sup>5</sup> Two current and one ground wire per conduit (two AC output conduits).

Table 51
Inverter System Recommended AC Output Branch Circuit Protection and Wire Size (List 52)

## Inverter System AC Output Connections Illustration (List 50, 52)





Figure 12
Inverter System AC Output Connections (List 50, 52)

#### **Inverter System AC Output Connections (List 51, 53)**

The 1RU and 2RU AC distribution panels with 15A NEMA / IEC connectors are automatically field wired via the line cords that connect to the NEMA / IEC outlets. Refer to Figure 13 for an illustration of the NEMA panel.






Figure 13
Inverter System AC Output Connections (List 51, 53)

# External Alarm, Reference, Monitoring (All Lists except List 100, 101, 102, 203, 500, 501, 502, 503, 600, 601, 900, 901, 930, 931)


#### External Alarm, Reference, Monitoring, and Control Wire Sizes

Recommended wire size is 22 AWG for loop lengths up to 200 ft. and 18 AWG to 20 AWG for loop lengths over 200 ft.

#### External Alarm, Reference, Monitoring, and Control Illustrations

See Table 30 for replacement part numbers.

## Circuit Card Location (Main Bay) Optional Second IB2 or EIB (Main Bay Only) Optional IB4 (Main Bay Only) (underside of cover) (Second Ethernet Port Board) Optional EIB (Main Bay Only) 4-Row Cabinet Shown, (Extended Interface Board) Others Similar (located on inside side panel) (Front Door Removed in Illustration for Clarity) IB2 (Main Bay Only) (Interface Board) (located on inside side panel) Optional SM-DU+ and Shunt Interface Board Controller Optional LVD Optional LVD Driver Circuit Card Inhibit Switch (factory installed OR if option specified) **Optional Manual Battery** Disconnect Circuit Card (Main Bay Only) System Interface Optional LVD Driver Circuit Card Lite Circuit Card



#### (Main Bay Only)

\* When an NCU configuration is furnished that enables NCU capability to receive status information sent from Fiamm SoNick [Sodium Nickel] batteries. Connect leads from the Fiamm SoNick batteries to the RS-485 terminals. Refer to the battery manufacturer documentation and the NCU controller manual UM1M830BNA for details.

#### TB2 (Main Bay Only)


RS485 Connection\* TB2 1A: RS485+ TB2 2A: RS485-

RS232 Connection TB2 1B: CGND TB2 2B: TXD232 TB2 3B:RXD232

TB2 3A: Internally used by system.


#### TB2

Wire Size Capacity: 16-26 AWG. Recommended Torque: 2.0 in-lbs.




J1. J2. J3. J4 Distribution Panels FA Inputs

J8 (Main Bay Only) Selects to power Controller from "Battery Power" or not.



J10 (Main Bay Only) Battery Monitoring External / Internal (see TB1-4 and TB1-5 for external monitoring points)



CAN2 (top) CAN1 (bottom)


TB1-2: External Battery FA

TB1-3: External System FA

TB1-4: External Battery Monitoring (-) TB1-5: External Battery Monitoring (+) TP1 (+) and TP2 (-) Bay Voltage Monitoring


TP3 (+) and TP4 (-) Bay Load **Shunt Monitoring** 

TB1-2, TB1-3, TB1-4, TB1-5 Main Bay Only. Wire Size Capacity: 22-12 AWG. Recommended Torque: 3.0 in-lbs. FA Signals: System voltage applied to the terminal turns in an alarm.




NOTE:

See next page for Bay to Bay Communication Cable Connections.



NOTE: Use standard CAT5 communications cables.

 Diagrams above are for typical configurations. CAN1 is used for all SM\_CAN connections and for RECT\_CAN connections up through and including the bay with the 72nd rectifier slot maximum (for 1R483500E3 or 1R484000E) or the 60th rectifier slot maximum (for 1R483500E).
 CAN2 of the Main Bay should be connected to RECT\_CAN IN in the supplementary bay that has the 73rd rectifier slot (for 1R483500E3 or 1R484000E) or the 61st rectifier slot (for 1R483500E).




#### Schematic Diagram of EIB Board **EIB Board** $\bigcirc$ 0000000000000000 DO4 NO Θ-9 DO3 NO 2 DO4\_COM ള က DO3 COM Θ-DO4 NC $\alpha$ Θ-DO3\_NC RELAY OUTPUTS DO2 NO 9 DO1 NO 2 DO2 COM 4 8 DO1\_COM က DO2 NC DO1\_NC DO5 NO 9 2 DO5 COM 4 Θ-7 DCV8 က Θ-DO5\_NC Θ- $\alpha$ DCV7 DCV6 9 VOLTAGE INPUTS DCV5 2 DCV4 9 က DCV3 12C TEMP2 TEMP1 DCV2 $^{\circ}$ DCV1 SH3+ 9 SH3-2 SHUNT SH2+ 4 5 က SH2-Θ-SH1+ Θ-Θ-SH1-<u>J5-J9</u> MA455U41 EIB Wire Size Capacity: 16-26 AWG. ಬದಬ 444 Recommended Torque: 2.2 in-lbs. EIB TEMP PROBE 2 EIB TEMP PROBE 1

## Schematic Diagram of SM-DU+ and Shunt Interface Board

#### SMDU+ SHUNT INTERFACE TB2 0 J2 0 SHUNT25+ SHUNT25-25A 0 25B ° 24A ° SHUNT24+ → 4 ≻ 24B o SHUNT24- $\rightarrow$ 5 $\succ$ 23A o SHUNT23+ $\rightarrow$ 6 $\succ$ 7 $\succ$ 23B 0 SHUNT23-SHUNT22+ 22A o >8≻ SHUNT22-22B o 21A ° SHUNT21+ →10≻ 21B o SHUNT21-→11≻ →12× 20A 🜼 SHUNT20+ 20B o SHUNT20-<del>-></del>13≻ SHUNT19+ 19A o →14≻ 19B ° SHUNT19-<del>→</del>15≻ 18A o SHUNT18+ <del>→</del>16≻ 18B ° SHUNT18-→17≻ SHUNT17+ SHUNT17-17A o <del>-></del>18≻ 17B o <del>></del>19≻ 16A o SHUNT16+ →20≻ SHUNT16-16B 0 →21≻ 15A ° SHUNT15+ <del>></del>22≻ 15B ° SHUNT15-→23> SHUNT14+ SHUNT14-→24> →25> <del>→</del>26> TB1 SHUNT INPUTS 13A o SHUNT13+ J1 SHUNT13-SHUNT12+ $\overrightarrow{\rightarrow}$ 2 $\overleftarrow{\rightarrow}$ 3 $\overleftarrow{\rightarrow}$ 12B ° 11A ° SHUNT12-SHUNT11+ 11B o SHUNT11- $\begin{array}{c} \rightarrow 5 \\ \rightarrow 6 \\ \rightarrow 7 \\ \rightarrow \end{array}$ SHUNT10+ SHUNT10-10A o 10B ° 9A 0 SHUNT9+ →8 ≻ 9B 0 SHUNT9-. . . . . . . . . . . . . . . . . . . 0 SHUNT8+ →10≻ SHUNT8-SHUNT7+ /A 0 7B 0 6A 0 8B ° <del>→</del>11≻ →12≻ SHUNT7-<del>→</del>13≻ SHUNT6+ →14≻ 6B ° SHUNT6-→15≻ 0 SHUNT5+ SHUNT5-SHUNT4+ 0 5B →17≻ 4A **→18**≻ 4B 0 SHUNT4-<del>></del>19≻ 3A o SHUNT3+ ÷20≻ 0 SHUNT3-<del>></del>21≻ SHUNT2+ 2A 0 →22≻ SHUNT2-2B ° 1A ° →23> SHUNT1+ →24> 1B ° SHUNT1-<del>></del>25>

#### Shunt Interface Board



SM-DU+ and Shunt
Interface Board

©


- กษาสุดปลาย ปี กา H ร

→26>

ØØØØØØØØØØØØØØØØØØØØØØØØØØØØ

TB1 - TB2 Wire Size Capacity: 16-26 AWG. Recommended Torque: 2.2 in-lbs.

# Optional LVD Driver Circuit Card




#### Momentary UP / Middle / Down


Momentary UP Position: Closes all LVD Contactors (inhibit mode). Middle Position: OFF (Controller DOES NOT control LVD's) (inhibit mode). DOWN Position: ON (Controller controls LVD's).

#### Notes:

- 1. Connects up to (4) LVLD and (1) LVBD contactors.
- 2. Switch and indicator located on circuit card installed in Main Bay only.



## Optional LVD Driver Lite Circuit Card




<u>J1</u>
To LVLD contactor, uses controller LVD1 control setting (Level 1).

J3
To LVLD contactor, uses controller LVD2 control setting (Level 2).

J2
To LVBD contactor, uses controller LVD2 control setting (Level 2).
Can only be used if it is contained in a List 21 (1-row) cabinet.


#### Momentary UP / Middle / Down

Momentary UP Position: Closes all LVD Contactors (inhibit mode).
Middle Position: OFF (Controller DOES NOT control LVD's) (inhibit mode).
DOWN Position: ON (Controller controls LVD's).




Active Indicator

#### Optional Manual Battery Disconnect Circuit Card (Main Bay Only)



# CAN Interface Board ( Supplementary Bay Only )




## External Alarm, Reference, Monitoring (List 100, 101, 102, 203, 500, 501, 502, 503)


#### External Alarm, Reference, Monitoring, and Control Wire Sizes

Recommended wire size is 22 AWG for loop lengths up to 200 ft. and 18 AWG to 20 AWG for loop lengths over 200 ft.

#### External Alarm, Reference, Monitoring, and Control Illustrations




## System Interface Board



CAN termination plug P/N 548398 must be installed if an external device is not connected to the system.

## System Interface Board



#### TB1

Wire Size Capacity: 14AWG to 30AWG
Recommended Torque: 0.28Nm or 2.48 in-lb


FA Signals: System voltage applied to the terminal turns in an alarm.

TB1-1: Bat Tray FA TB1-2: Bat Rack FA

J6 (System Temp 2)

J5 (System Temp 1)

**NCU CAN Port** 




\* The relay assigned to "Critical Summary" alarm (relay 1 on first IB2 by default) will operate in the "Fail Safe Mode". "Fail Safe Mode" means Relay 1 is de-energized during an alarm condition, opening the contacts between the C and NO terminals, and closing the contacts between the C and NC terminals.

The remaining seven (7) relays energize during an alarm condition, closing the contacts between the C and NO terminals, and opening the contacts between the C and NC terminals.

Refer to the configuration drawing (C-drawing) supplied with your system for your system's specific relay labeling.

Not all I/O points are available for customer connection (some are used for factory system connections).





## External Alarm, Reference, Monitoring (List 600, 601, 900, 901)

#### External Alarm, Reference, Monitoring, and Control Wire Sizes

Recommended wire size is 22 AWG for loop lengths up to 200 ft. and 18 AWG to 20 AWG for loop lengths over 200 ft.


#### External Alarm, Reference, Monitoring, and Control Illustrations





## J4 on System Interface Board

Selects to power controller from "Battery Power" or not if a battery LVD contactor is furnished.



#### J3 on System Interface Board


Wire Size Capacity: 16 AWG to 30 AWG.

Wire Strip Length: 0.32 inch. Recommended Torque: 2.3 in-lbs.

## RS485 Connection

J3-1: RS485+ J3-2: RS485-

#### System Interface Board P/N 555484



The relay assigned to "Critical Summary" alarm (relay 1 by default) will operate in the "Fail Safe Mode". "Fail Safe Mode" means Relay 1 is de-energized during an alarm condition, opening the contacts between the C and NO terminals, and closing the contacts between the C and NC terminals. The remaining seven (7) relays energize during an alarm condition, closing the contacts between the C and NO terminals, and opening the contacts between the C and NC terminals.


Not all I/O points may be available for customer connection (some may be used for factory system connections). The digital inputs and relay outputs may be preprogrammed for specific functions. Refer to the configuration drawing (C-drawing) supplied with your system for your system's specific configuration.

#### •

Wire Size Capacity: 16 AWG to 26 AWG.


Wire Strip Length: 0.20 inch. Recommended Torque: 2.2 in-lbs.


#### IB2 Assembly (with shield)



Switch settings must be in this position to interface with the controller.

#### IB2 (Controller Interface Board)





The five (5) relays energize during an alarm condition, closing the contacts between the C and NO terminals, and opening the contacts between the C and NC terminals.


Not all I/O points may be available for customer connection (some may be used for factory system connections). The relay outputs may be preprogrammed for specific functions. Refer to the configuration drawing (C-drawing) supplied with your system for your system's specific configuration.

#### <u>J5-J9:</u>

Wire Size Capacity: 16 AWG to 26 AWG.


Wire Strip Length: 0.20 inch. Recommended Torque: 2.2 in-lbs.

#### EIB Assembly (with shield)




## EIB (Controller Extended Interface Board)

Switch settings must be in this position to interface with the controller.



## Schematic Diagram of EIB (Controller Extended Interface Board)





## External Alarm, Reference, Monitoring (List 930, 931)

## External Alarm, Reference, Monitoring, and Control Wire Sizes


Recommended wire size is 22 AWG for loop lengths up to 200 ft. and 18 AWG to 20 AWG for loop lengths over 200 ft.

## External Alarm, Reference, Monitoring, and Control Illustrations






System Interface Board P/N 430171G1



<u>S1:</u> Manual Battery Disconnect (MBD) switch and DS1 illuminates to indicate you're in the MBD mode, which means your Battery LVD is open and your Batteries are disconnected from the system.

TB1-1/A/1B: RS485 Southbound Output TB1-2A/2B: RS485 Northbound Output TB1-3A/3B: -48V Fused Output that can be used to power external devices

TB2-1A: External -48V Fuse Alarm Input TB2-2A: External -58V Fuse Alarm Input TB2-3A: GMT Fuse Alarm Input TB2-1B/2B/3B: RS232 Output



TB2 on System Interface Board
Wire Size Capacity: 16 AWG to 26 AWG
Recommended Torque: 2.0 in-lbs.


The relay assigned to "Critical Summary" alarm (relay 1 by default) will operate in the "Fail Safe Mode". "Fail Safe Mode" means Relay 1 is de-energized during an alarm condition, opening the contacts between the C and NO terminals, and closing the contacts between the C and NC terminals. The remaining seven (7) relays energize during an alarm condition, closing the contacts between the C and NO terminals, and opening the contacts between the C and NC terminals.

Not all I/O points may be available for customer connection (some may be used for factory system connections). The digital inputs and relay outputs may be preprogrammed for specific functions. Refer to the configuration drawing (C-drawing) supplied with your system for your system's specific configuration.

Wire Size Capacity: 16 AWG to 26 AWG.


Wire Strip Length: 0.20 inch. Recommended Torque: 2.2 in-lbs.


#### IB2 Assembly (with shield)



Switch settings must be in this position to interface with the controller.

#### IB2 (Controller Interface Board)





**RELAY OUTPUTS** 

The five (5) relays energize during an alarm condition, closing the contacts between the C and NO terminals, and opening the contacts between the C and NC terminals.


Not all I/O points may be available for customer connection (some may be used for factory system connections). The relay outputs may be preprogrammed for specific functions. Refer to the configuration drawing (C-drawing) supplied with your system for your system's specific configuration.

#### <u>J5-J9:</u>

Wire Size Capacity: 16 AWG to 26 AWG.


Wire Strip Length: 0.20 inch. Recommended Torque: 2.2 in-lbs.

#### EIB Assembly (with shield)




## EIB (Controller Extended Interface Board)

Switch settings must be in this position to interface with the controller.



## Schematic Diagram of EIB (Controller Extended Interface Board)



#### **Load Distribution**

#### **Load Distribution Wire Sizes and Lugs Selection**

The rating of the distribution device determines the load lead wire size requirement. The distribution panel ordered determines the lug hole size and spacing requirements. For wire size and lug selection; refer to the following.

When Distribution Panels using Bullet Nose Type Devices (TPS/TLS Fuses and/or Bullet Nose Type Circuit
Breakers) are Provided: Lug-terminated load leads are connected to the individual load busbars and load return busbar
(if equipped) located on the distribution panel. If the distribution panel is not equipped with a load return busbar, load
return connections are made to a separate return busbar.

The distribution panel's individual load busbars and load return busbar (if equipped) provide 1/4-20 studs for installation of customer-provided two-hole lugs that have 1/4-inch bolt clearance holes on 5/8-inch centers. Customer must provide (or order) lug mounting hardware. The distribution panel's individual load busbars and return busbar (if equipped) are designed to accommodate the lugs listed in Table 19 and Table 21. Use Table 52 to select recommended load distribution wire sizes and lugs for various loop lengths per fuse/circuit breaker ampere rating. Maximum size of wire to be connected to a single fuseholder/circuit breaker position is 2 AWG. For wiring up to 350 kcmil, see Table 21 for special application crimp lug / strap combinations. Refer also to "Lug Adapters" on page 128 or "Lug Adapters (Lists 600, 601, 900, 901, 930, 931)" on page 130. Use Table 20 and Table 53 when using the lug adapters with 3/8-inch bolt clearance holes on 1-inch centers.

The separate return busbar (if furnished) provides 3/8-16 captive nuts for installation of customer-provided two-hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide (or order) lug mounting bolts and hardware. The separate return busbar (if furnished) are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended load distribution wire sizes and lugs for various loop lengths per fuse/circuit breaker ampere rating.

When Distribution Panels using GJ/218 Circuit Breakers or TPH Fuses are Provided: Lug-terminated load leads are
connected to the individual load busbars and load return busbar (if equipped) located on the distribution panel. If the
distribution panel is not equipped with a load return busbar, load return connections are made to a separate return
busbar.

The distribution panel's individual load busbars and load return busbar (if equipped) provide 3/8-16 captive nuts or studs for installation of customer-provided two-hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide (or order) lug mounting bolts (if required) and hardware. The distribution panel's individual load busbars and return busbar (if equipped) are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended load distribution wire sizes and lugs for various loop lengths per fuse/circuit breaker ampere rating.


The separate return busbar (if furnished) provides 3/8-16 captive nuts for installation of customer-provided two-hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide (or order) lug mounting bolts and hardware. The separate return busbar (if furnished) are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended load distribution wire sizes and lugs for various loop lengths per fuse/circuit breaker ampere rating.


#### **Load Distribution (Distribution Panels) Illustrations**

All Lists Except Lists 600, 601, 900, 901): Refer to the illustrations located under the distribution list number descriptions starting on page 67.

Lists 600, 601, 900, 901): Refer to Figure 14.


Lists 930, 931): Refer to Figure 15.






Note: 100 A circuit breakers can be used without a space provided the continuous current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker SHALL HAVE an empty mounting position between it and any other overcurrent protective device.

Figure 14 582127000 Lists 600, 601, 900, 901 Load Connections






CAUTION: A 100 A circuit breaker or fuse SHALL HAVE an empty mounting position between it and any other overcurrent protective device. 100 A circuit breakers can be used without a space provided the continuous current in each 100 A device does not exceed 64 A. A 175 A or greater circuit breaker SHALL HAVE an empty mounting position between it and any other overcurrent protective device.


The five right-most positions in each panel are reserved for -48 VDC. The five left-most positions in each panel are reserved for -58 VDC. The remaining positions can be selected for either -48 VDC or -58 VDC in groups of five positions.

Figure 15 582127000 Lists 930, 931 Load Connections

## Load Distribution Wiring (Optional Bullet Nose 6-Position 35 A GMT Fuse Block) Illustration



## Load Distribution Wiring (Optional Bullet Nose 6-Position 30 A GMT Fuse Block) Illustration (List 930, 931 Only)



## **Battery Input**

#### **Battery Input Wire Sizes and Lugs Selection**

- When Distribution Panels Providing Battery Disconnect Fuse/Circuit Breaker Positions are Provided: The rating of
  the disconnect device determines the input battery lead wire size requirement. The distribution panel ordered
  determines the lug hole size and spacing requirements. For wire size and lug selection; refer to the following.
  - a) When Distribution Panels Using Bullet Nose Type Devices (TPS/TLS Fuses and/or Bullet Nose Type Circuit Breakers) are Provided: Lug-terminated input battery leads are connected to the individual battery busbars and battery return busbar (if equipped) located on the distribution panel. If the distribution panel is not equipped with a battery return busbar, battery return connections are made to a separate return busbar.

The distribution panel's individual battery busbars and battery return busbar (if equipped) provide 1/4-20 studs for installation of customer-provided two-hole lugs that have 1/4-inch bolt clearance holes on 5/8-inch centers. Customer must provide (or order) lug mounting hardware. The distribution panel's individual battery busbars and return busbar (if equipped) are designed to accommodate the lugs listed in Table 19 and Table 21. Use Table 52 to select recommended battery wire sizes and lugs for various loop lengths per battery disconnect fuse/circuit breaker ampere rating. Maximum size of wire to be connected to a single fuseholder/circuit breaker position is 2 AWG. For wiring up to 350 kcmil, see Table 21 for special application crimp lug / strap combinations. Refer also to "Lug Adapters" on page 128. Use Table 20 and Table 53 when using the lug adapters with 3/8-inch bolt clearance holes on 1-inch centers.

The separate return busbar (if furnished) provides 3/8-16 captive nuts for installation of customer-provided two-hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide (or order) lug mounting bolts and hardware. The separate return busbar (if furnished) are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended load distribution wire sizes and lugs for various loop lengths per fuse/circuit breaker ampere rating.

b) When Distribution Panels Using GJ/218 Circuit Breakers or TPH Fuses are Provided: Lug-terminated battery leads are connected to the individual battery busbars and battery return busbar (if equipped) located on the distribution panel. If the distribution panel is not equipped with a battery return busbar, battery return connections are made to a separate return busbar.

The distribution panel's individual battery busbars and battery return busbar (if equipped) provide 3/8-16 captive nuts or studs for installation of customer-provided two-hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide (or order) lug mounting bolts (if required) and hardware. The distribution panel's individual battery busbars and battery return busbar are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended battery wire sizes and lugs for various loop lengths per battery disconnect fuse/circuit breaker ampere rating.


The separate return busbar (if furnished) provides 3/8-16 captive nuts for installation of customer-provided two-hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide (or order) lug mounting bolts and hardware. The separate return busbar (if furnished) are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended load distribution wire sizes and lugs for various loop lengths per fuse/circuit breaker ampere rating.

• When Distribution Panels with Battery Disconnect Fuse/Circuit Breaker Positions are NOT Provided: Lugterminated input battery leads are connected to the battery busbar and battery return busbar. These busbars provide 3/8-16 captive nuts for installation of customer-provided two hole lugs that have 3/8-inch bolt clearance holes on 1-inch centers. Customer must provide lug mounting bolts and hardware. Battery wire size and lug requirements are determined by site requirements. For wire size and lug selection; refer to the following.


The battery busbars are designed to accommodate the lugs listed in Table 20. Use Table 53 to select recommended battery wire sizes and lugs for various loop lengths per required battery branch circuit ampere rating.

#### **Battery Input Illustrations**


- a) Connections to Battery Disconnect Circuit Breakers
   Refer to the illustrations located under "Battery Disconnect Distribution Panels" starting on page 84.
- b) Connections to Lists 21 through 24 Distribution Cabinets




3-Row and 4-Row Cabinets




## c) Connections to List 100, 101, 102, 203, 500, 501, 502, 503 Distribution Cabinet





## d) Connections to List 600, 601, 900, 901 Distribution Cabinet



BATTERY AND BATTERY RETURN CONNECTIONS

3/8-16 Studs on 1" Centers

(Customer must supply or order hardware)

Maximum Lug Width: 1.88 inches.

Busbar Hardware:

3/8" Hex Nut

3/8" Lock Washer


3/8" Flat Washer

Recommended Torque to 300 in-lbs.

Note: Central Office Ground should be tied to any point on the battery return busbar.

## e) Connections to Interbay Busbars (P/O List 2 and List 3) (for system mounted in a relay rack only)


The current rating of the inter-bay bus bars is 2000 amps maximum. Rectifier placement load and battery connections should be such that this maximum current is not exceeded.



(CAN ONLY BE USED FOR BATTERY CONNECTIONS IF THE SYSTEM DOES NOT CONTAIN A BATTERY SHUNT OR BATTERY DISCONNECT CONTACTOR) 3/8-16 Captive Nuts on 1" Centers

Notes:


1. All dimensions are in inches.



Rear

## f) Connections to Optional Battery Busbar Extension Kit P/N 562364 Installed in a List 23 and List 24 Distribution Cabinet


Note: See Battery Busbar Extension Kit (P/N 562364) under ACCESSORY DESCRIPTIONS for description.



List 24 Distribution Cabinet (List 23 similar)


## g) Connections to Optional Battery Busbar Extension Kit P/N 554541 Installed in a Lists 21 through 22 Distribution Cabinets

Note: See Battery Busbar Extension Kit (P/N 554541) under ACCESSORY DESCRIPTIONS for description.




h) Connections to Optional Battery Landing Busbar Kit P/N 553584 Installed in List 21 Distribution Cabinet (for systems mounted in a relay rack only)

Note: See Battery Busbar Extension Kit (P/N 553584) under ACCESSORY DESCRIPTIONS for description.



## i) Connections to Optional Battery Landing Busbar Kit P/N 555478 Installed in Lists 22 through 24 Distribution Cabinets (for systems mounted in a relay rack only)

Note: See Battery Busbar Extension Kit (P/N 555478) under ACCESSORY DESCRIPTIONS for description.



Up to Eight (8) Battery Leads (per polarity). [Four (4) battery landing positions, two (2) battery cable lugs back-to-back each position.]

# Wire Size and Lug Selection Tables for Load and Battery Connections to TPS/TLS Fuses and Bullet Nose Type Circuit Breakers

Fuse/ Circuit Breaker Amperage	Recm 90°C Wire Size <sup>(1)</sup>								
	14 AWG	12 AWG	10 AWG	8 AWG	6 AWG	4 AWG	2 AWG	1/0 AWG	
	Loop Length (feet) (2)								
1, 3, 5, 6, 10 A	37 <sup>(3, 4)</sup>	58 <sup>(3, 4)</sup>	93 (3, 4)						
15 A	24 (3, 4)	39 <sup>(3, 4)</sup>	62 <sup>(3, 4)</sup>						
20 A		29 (3, 4)	46 <sup>(3, 4)</sup>	74 <sup>(3, 4)</sup>					
25 A			37 <sup>(3, 4)</sup>	59 <sup>(3, 4)</sup>	94 (3, 4)				
30 A			31 (3, 4)	49 (3, 4)	78 <sup>(3, 4)</sup>				
35 A				42 <sup>(3, 4)</sup>	67 <sup>(3, 4)</sup>	107 <sup>(3, 4)</sup>			
40 A				37 <sup>(3, 4)</sup>	59 <sup>(3, 4)</sup>	94 (3,4)			
45 A				33 (3, 4)	52 <sup>(3, 4)</sup>	83 <sup>(3, 4)</sup>			
50 A				29 <sup>(3, 4)</sup>	47 <sup>(3, 4)</sup>	75 <sup>(3, 4)</sup>			
60 A					39 <sup>(3, 4)</sup>	62 <sup>(3, 4)</sup>	99 (3, 4)		
70 A					33 <sup>(3)</sup>	53 <sup>(3, 4)</sup>	85 <sup>(3, 4)</sup>	135 <sup>(4)</sup>	
75 A					31 <sup>(3)</sup>	50 <sup>(3, 4)</sup>	79 <sup>(3, 4)</sup>	126 <sup>(4)</sup>	
80 A						47 <sup>(3, 4)</sup>	74 <sup>(3, 4)</sup>	118 <sup>(3, 4)</sup>	
Recommended Crimp Lug (5)									
Lug	245342300	245342300	245342300	245390200	245346700	245346800	245346900	245393500 <sup>(6)</sup>	

Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.

- 3 Wire Size / Loop Length Combination Calculated using 30 °C Ambient Operating Temperature.
- Wire Size / Loop Length Combination Calculated using 40 °C Ambient Operating Temperature.
- <sup>5</sup> Two-hole lug, 1/4" bolt clearance hole, 5/8" centers. Lugs should be crimped per lug manufacturer's specifications.
- <sup>6</sup> Special application crimp lug / strap combination.

Table 52 (cont'd on next page)
Recommended Wire Sizes and Lugs for Load and Battery Connections to Various TPS/TLS Fuses and Bullet Nose Type Circuit Breakers

Recommended wire sizes are sufficient to restrict voltage drop to 1.0 volt or less at listed branch current for the loop lengths shown. Loop length is the sum of the lengths of the positive and negative leads.

Fuse/ Circuit Breaker Amperage	Recm 90°C Wire Size (1)									
	4 AWG	2 AWG	1/0 AWG	2/0 AWG	3/0 AWG	4/0 AWG	250 kcmil	350 kcmil		
	Loop Length (feet) <sup>(2)</sup>									
90 A	41 <sup>(3)</sup>	66 <sup>(3, 4)</sup>	105 <sup>(3, 4)</sup>	133 <sup>(4)</sup>						
100 A		59 <sup>(3, 4)</sup>	95 (3, 4)	119 <sup>(3, 4)</sup>						
125 A		47 <sup>(3)</sup>	76 <sup>(3, 4)</sup>	95 <sup>(3, 4)</sup>	120 <sup>(4)</sup>					
150 A			63 <sup>(3, 4)</sup>	79 <sup>(3, 4)</sup>	100 <sup>(3, 4)</sup>					
200 A					75 <sup>(3, 4)</sup>	95 (3, 4)	112 <sup>(3, 4)</sup>			
250 A						76 <sup>(3, 4, 7)</sup>	90 (3, 4, 7)	126 <sup>(3, 4, 7)</sup>		
300 A								105 (3, 4, 7)		
Recommended Crimp Lug										
Lug (5)	245346800	245346900	245393500 <sup>(6)</sup>	245393600 <sup>(6)</sup>	245393700 <sup>(6)</sup>	245393800 <sup>(6)</sup>	514872 <sup>(6)</sup>	514873 <sup>(6)</sup>		
Lug <sup>(8, 9)</sup>		245348200	245347100	245347200	245347300	245347400	245347500	245347700		

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- Recommended wire sizes are sufficient to restrict voltage drop to 1.0 volt or less at listed branch current for the loop lengths shown. Loop length is the sum of the lengths of the positive and negative leads.
- <sup>3</sup> Wire Size / Loop Length Combination Calculated using 30 °C Ambient Operating Temperature.
- Wire Size / Loop Length Combination Calculated using 40 °C Ambient Operating Temperature.
- Two-hole lug, 1/4" bolt clearance hole, 5/8" centers. Lugs should be crimped per lug manufacturer's specifications.
- <sup>6</sup> Special application crimp lug / strap combination.
- MUST USE P/N 514717 Lug Adapter Busbar for lugs having 1/4" bolt clearance hole, 5/8" centers.
- <sup>8</sup> Two-hole lug, 3/8" bolt clearance hole, 1" centers. Lugs should be crimped per lug manufacturer's specifications.
- MUST USE P/N 522786 or 534449 Lug Adapter Busbar for 125 A to 200 A circuit breakers or P/N 514714 Lug Adapter Busbar Kit for 225 A to 300 A circuit breakers.

Table 52 (cont'd from previous page)
Recommended Wire Sizes and Lugs for Load and Battery Connections
to Various TPS/TLS Fuses and Bullet Nose Type Circuit Breakers

# Wire Size and Lug Selection Tables for Load and Battery Connections to TPH Fuses and GJ/218 Type Circuit Breakers or Battery Branch Circuits

Fuse/ Circuit Breaker Amperage	Recm 90°C Wire Size (1)								
	6 AWG	4 AWG	2 AWG	1/0 AWG	2/0 AWG	3/0 AWG	4/0 AWG	250 kcmil	
	Loop Length (feet) <sup>(2)</sup>								
70 A	33 <sup>(3)</sup>	53 <sup>(3, 4)</sup>	85 <sup>(3, 4)</sup>	135 <sup>(4)</sup>					
80 A		47 <sup>(3, 4)</sup>	74 <sup>(3, 4)</sup>	118 <sup>(3, 4)</sup>					
100 A			59 (3, 4)	95 (3, 4)	119 <sup>(3, 4)</sup>				
125 A			47 <sup>(3)</sup>	76 <sup>(3, 4)</sup>	95 (3, 4)	120 <sup>(4)</sup>			
150 A				63 <sup>(3, 4)</sup>	79 <sup>(3, 4)</sup>	100 <sup>(3, 4)</sup>			
175 A					68 <sup>(3, 4)</sup>	86 <sup>(3, 4)</sup>	108 <sup>(3, 4)</sup>		
200 A						75 <sup>(3, 4)</sup>	95 (3, 4)	112 <sup>(3, 4)</sup>	
Recommended Crimp Lug (5)									
Lug	245349900	245350000	245348200	245347100	245347200	245347300	245347400	245347500	

Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.

- Wire Size / Loop Length Combination Calculated using 30 °C Ambient Operating Temperature.
- Wire Size / Loop Length Combination Calculated using 40 °C Ambient Operating Temperature.
- <sup>5</sup> Two-hole lug, 3/8" bolt clearance hole, 1" centers. Lugs should be crimped per lug manufacturer's specifications.

Table 53 (cont'd on next page)
Recommended Wire Sizes and Lugs for Load and Battery Connections
to Various TPH Fuses and GJ/218-Circuit Breakers or Battery Branch Circuits

Recommended wire sizes are sufficient to restrict voltage drop to 1.0 volt or less at listed branch current for the loop lengths shown. Loop length is the sum of the lengths of the positive and negative leads.

Fuse/ Circuit Breaker Amperage	Recm 90°C Wire Size (1)									
	2/0 AWG	3/0 AWG	4/0 AWG	250 kcmil	300 kcmil	350 kcmil	400 kcmil	500 kcmil		
	Loop Length (feet) <sup>(2)</sup>									
225 A		67 <sup>(3)</sup>	84 <sup>(3, 4)</sup>	100 (3, 4)	120 <sup>(4)</sup>					
250 A			76 <sup>(3)</sup>	90 (3,4)	108 <sup>(3, 4)</sup>	126 <sup>(4)</sup>				
300 A	159 <sup>(4)</sup> (2) Wires				90 <sup>(3)</sup>	105 <sup>(3, 4)</sup>	120 <sup>(3, 4)</sup>			
400 A		75 <sup>(3, 4)</sup> (2) Wires	95 <sup>(3, 4)</sup> (2) Wires	112 <sup>(3, 4)</sup> (2) Wires						
500 A			76 <sup>(3)</sup> (2) Wires	90 <sup>(3, 4)</sup> (2) Wires	108 <sup>(3, 4)</sup> (2) Wires	126 <sup>(4)</sup> (2) Wires				
600 A					90 <sup>(3)</sup> (2) Wires	105 <sup>(3, 4)</sup> (2) Wires 157 <sup>(4)</sup> (3) Wires	120 <sup>(3, 4)</sup> (2) Wires			
800 A				84 <sup>(3)</sup> (3) Wires	101 <sup>(3, 4)</sup> (3) Wires	118 <sup>(3, 4)</sup> (3) Wires	135 <sup>(3, 4)</sup> (3) Wires			
Recommended Crimp Lug (5)										
Lug	245347200 (per cable)	245347300 (per cable)	245347400 (per cable)	245347500 (per cable)	245347600 (per cable) See also Note 6.	245347700 (per cable) See also Note 6.	245347800 (per cable) See also Note 6.	245347900 (per cable)		

- Wire sizes based on recommendations of the American National Standards Institute (ANSI) approved National Fire Protection Association's (NFPA) National Electrical Code (NEC). Table 310.15 (B) (16) for copper wire at 90 °C conductor temperature. For operation in countries where the NEC is not recognized, follow applicable codes.
- Recommended wire sizes are sufficient to restrict voltage drop to 1.0 volt or less at listed branch current for the loop lengths shown. Loop length is the sum of the lengths of the positive and negative leads.
- <sup>3</sup> Wire Size / Loop Length Combination Calculated using 30 °C Ambient Operating Temperature.
- Wire Size / Loop Length Combination Calculated using 40 °C Ambient Operating Temperature.
- <sup>5</sup> Two-hole lug, 3/8" bolt clearance hole, 1" centers. Lugs should be crimped per lug manufacturer's specifications.
- For a 600 A GJ/218 circuit breaker installed in a List AM or List AP distribution panel, P/N 562888 3-pole lug adapter may be ordered. P/N 562888 includes one (1) busbar that mounts on the three lug landing positions of a 600 A circuit breaker installed in a List AM or List AP distribution panel and one (1) busbar that mounts on the three landings of the associated ground return bar. These busbars provide two (2) landings for standard two-hole lugs having 3/8" bolt clearance holes on 1" centers.

Table 53 (cont'd from previous page)
Recommended Wire Sizes and Lugs for Load and Battery Connections
to Various TPH Fuses and GJ/218-Circuit Breakers or Battery Branch Circuits

#### **SPECIFICATIONS**

- SYSTEM
  - 1.1 Output Ratings
    - 1.1.1 See "General Specifications" starting on page 4.
  - 1.2 Input Ratings
    - 1.2.1 See "General Specifications" starting on page 4.
  - 1.3 Environmental Ratings
    - 1.3.1 Operating Ambient Temperature Range:
    - 1.3.2 Environment:
      - (A) Relay Rack Mounted Option and Enclosure P/N 563524 or 564881 Mounted Option: -40 °C to +40 °C (-40 °F to +104 °F).
      - (B) Rack Mounted in an OSP Enclosure Option (582127000 List 600, 601, 900, 901): -40 °C to +65 °C (-40 °F to +149 °F).
    - 1.3.3 Storage Ambient Temperature Range: -40 °C to +85 °C (-40 °F to +185 °F).
    - 1.3.4 Humidity: This Power System is capable of operating in an ambient relative humidity range of 0% to 95%, non-condensing.
    - 1.3.5 Altitude: Capable of operating in an altitude range of -200 feet to 10,000 feet. The maximum operating ambient temperature should be de-rated by 3 °C per 1000 feet above 5000 feet.
    - 1.3.6 Mounting: Refer to "Overall Dimensions" on page 245 for mounting dimensions.
      - This product is intended only for installation in a restricted access location on or above a non-combustible surface.
      - This product must be located in a controlled environment with access to crafts persons only.
      - This product is intended for installation in network telecommunication facilities (CO, vault, hut, or other environmentally controlled electronic equipment enclosure).
      - This product is intended to be connected to the common bonding network in a network telecommunication facility (CO, vault, hut, or other environmentally controlled electronic equipment enclosure).
      - The DC return connection to this system can remain isolated from system frame and chassis (DC-I).
      - This system is suitable for installation as part of the Common Bonding Network (CBN).
      - Rectifier, converter, and mounting assembly ventilating openings must not be blocked and temperature of air
        entering rectifiers and converters must not exceed the rated operating ambient temperature range.
      - Clearance requirements are:
        - a) Recommended minimum aisle space clearance for the front of each bay is 2'6".
        - b) Recommended minimum aisle space clearance for the rear of each bay is 2'0" for any of the following conditions:
          - Multiple bay arrangements that incorporate rear inter-bay busbars (List 2, List 3, List 7 and List 8 bays).
          - 2) Addition of a module mounting assembly in the field.
          - 3) Making AC input connections to a field installed module mounting assembly.
          - 4) Adding battery tray(s) in the field.
        - c) For all other conditions, required minimum spacing from the rear of the bay to a wall or other solid surface is that which is specified for proper converter and/or module mounting assembly ventilation.

588705000 Module Mounting Assembly: The distance from the rear of a module mounting assembly to a wall or other solid structure must not be less than two (2) inches. This will assure proper airflow through the rectifier modules.

588705300 and 588705400 Module Mounting Assembly: The distance from the rear of the module mounting assembly to a wall or other solid structure must not be less than four (4) inches. This will assure proper airflow through the rectifier and converter modules.

**Note:** Minimum spacing specified for ventilation may not permit replacement of certain components such as busbars or module mounting assemblies.

## Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System

## System Application Guide

- 1.4 Compliance Information
  - 1.4.1 Safety Compliance: This power board is UL Listed ("c UL") as a DC Power Distribution Center for Communications Equipment. This unit meets the requirements of CSA 22.2, No. 225 and is tested and Certified by UL ("c UL") as a Custom Built Power Distribution Center for Communications Equipment.
  - 1.4.2 NEBS Compliance: Compliance verified by a Nationally Recognized Testing Laboratory (NRTL) per GR-1089-CORE and GR-63-CORE. Contact Vertiv for NEBS compliance reports.

Rectifier Modules: In order to remain compliant during a fan failure condition, the backup battery connection must be utilized to provide sufficient power to the loads for up to eight (8) hours when the system is operated at greater than 50% output power. If no backup battery connection is used, the system must operate with a redundant module installed.

Converter Modules: In order to remain compliant during a fan failure condition, the system must operate with a redundant module installed.

- 1.5 IB2 and EIB (Controller Interface Board) Ratings
  - 1.5.1 Digital Input Ratings
    - (A) Maximum Voltage Rating: 60 VDC.
    - (B) Active High: > 19 VDC.
    - (C) Active Low: < 1 VDC.
  - 1.5.2 Relay Ratings
    - (A) Steady State: 0.5 A @ 60 VDC; 1.0 A @ 30 VDC.
    - (B) Peak: 3 A @ 30 VDC.
- 588705300 MODULE MOUNTING ASSEMBLY
  - 2.1 Input and Output Ratings
    - 2.1.1 588705300 List 01

Input Rating: 208 VAC, 240 VAC, 10 A / 8.7 A, 50 Hz / 60 Hz, single-phase.

Output Rating: -48 VDC, 250 A (12000 W) maximum @ 45 °C.

+24 VDC, 187 A (4500 W) maximum @ 45 °C or -58 VDC, 85.7 A (4800 W) maximum @ 45 °C

-48 VDC, 225 A (12000 W) maximum @ 65 °C.

+24 VDC, 150 A (3600 W) maximum @ 65 °C or -58 VDC, 68.5 A (3480 W) maximum @ 65 °C

-48 VDC, 168 A (9000 W) maximum @ 70 °C.

+24 VDC, 125 A (3000 W) maximum @ 70 °C or -58 VDC, 57 A (3198 W) maximum @ 70 °C

Input Rating: 120 VAC, 9 A, 50 Hz / 60 Hz, single-phase.

Output Rating: -48 VDC, 125 A (6000 W) maximum @ 45 °C.

+24 VDC, 187 A (4500 W) maximum @ 45 °C or -58 VDC, 85.7 A (4800 W) maximum @ 45 °C

-48 VDC, 112 A (5400 W) maximum @ 65 °C.

+24 VDC, 150 A (3600 W) maximum @ 65 °C or -58 VDC, 68.5 A (3480 W) maximum @ 65 °C

-48 VDC, 84.4 A (4050 W) maximum @ 70 °C.

+24 VDC, 125 A (3000 W) maximum @ 70 °C or -58 VDC, 57 A (3198 W) maximum @ 70 °C

#### 2.1.2 588705300 List 03

Input Rating: 208 VAC, 240 VAC, 20 A / 17.5 A, 50 Hz / 60 Hz, single-phase.

Output Rating: -48 VDC, 250 A (12000 W) maximum @ 45 °C.

+24 VDC, 187 A (4500 W) maximum @ 45 °C or -58 VDC, 85.7 A (4800 W) maximum @ 45 °C

-48 VDC, 225 A (12000 W) maximum @ 65 °C.

+24 VDC, 150 A (3600 W) maximum @ 65 °C or -58 VDC, 68.5 A (3480 W) maximum @ 65 °C

-48 VDC, 168 A (9000 W) maximum @ 70 °C.

+24 VDC, 125 A (3000 W) maximum @ 70 °C or -58 VDC, 57 A (3198 W) maximum @ 70 °C

Input Rating: 120 VAC, 18 A, 50 Hz / 60 Hz, single-phase.

Output Rating: -48 VDC, 125 A (6000 W) maximum @ 45 °C.

+24 VDC, 187 A (4500 W) maximum @ 45 °C or -58 VDC, 85.7 A (4800 W) maximum @ 45 °C

-48 VDC, 112 A (5400 W) maximum @ 65 °C.

+24 VDC, 150 A (3600 W) maximum @ 65 °C or -58 VDC, 68.5 A (3480 W) maximum @ 65 °C

-48 VDC, 84.4 A (4050 W) maximum @ 70 °C.

+24 VDC, 125 A (3000 W) maximum @ 70 °C or -58 VDC, 57 A (3198 W) maximum @ 70 °C

#### 2.2 Environmental Ratings

- 2.2.1 Operating Ambient Temperature Range (208 VAC, 240 VAC Input):
  - (A) -40 °C to +45 °C (-40 °F to +113 °F). 588705300 List 01, 03: 250 A / -48 VDC and 187 A / +24 VDC or 82.8 A / -58 VDC, maximum.
  - (B) -40 °C to +65 °C (-40 °F to +149 °F). 588705300 List 01, 03: 225 A / -48 VDC and 150 A / +24 VDC or 66.2 A / -58 VDC, maximum.
  - (C) -40 °C to +70 °C (-40 °F to +158 °F). 588705300 List 01, 03: 168 A / -48 VDC and 125 A / +24 VDC or 55.1 A / -58 VDC, maximum.
- 2.2.2 Operating Ambient Temperature Range (120 VAC):
  - (A) -40 °C to +45 °C (-40 °F to +113 °F). 588705300 List 01, 03: 125 A / -48 VDC and 187 A / +24 VDC or 82.8 A / -58 VDC, maximum.
  - (B) -40 °C to +65 °C (-40 °F to +149 °F). 588705300 List 01, 03: 112 A / -48 VDC and 150 A / +24 VDC or 66.2 A / -58 VDC, maximum.
  - (C) -40 °C to +70 °C (-40 °F to +158 °F). 588705300 List 01, 03: 84.4 A / -48 VDC and 125 A / +24 VDC or 55.1 A / -58 VDC, maximum.
- 2.2.3 Storage Ambient Temperature Range: -40 °C to +70 °C (-40 °F to +158 °F).
- 2.2.4 Humidity: Capable of operating in an ambient relative humidity range of 0% to 95%, non-condensing.
- 2.2.5 Altitude: Capable of operating in an altitude range of -200 feet to 10,000 feet. The maximum operating ambient temperature should be de-rated by 3 °C per 1000 feet above 6562 feet.
- 2.2.6 Audible Noise:
  - (A) For One Rectifier Module: Less than 50 dB(A) at <25 °C, measured at 60cm (2') distance.
  - (B) For Twelve Rectifier Modules: Less than 55 dB with 12 rectifiers mounted in system at ≤25 °C, measured at 1 m (3') distance in front of system and at same horizontal line of the middle of system.
- 2.2.7 Ventilation Requirements:
  - (A) Ventilation: A module mounting assembly must be mounted so ventilating openings are not blocked and temperature of the air entering the assembly does not exceed the Operating Ambient Temperature Range stated above. Refer also to "Mounting" below.
  - (B) Stacking Considerations: This system is designed for front to back ventilation to facilitate stacking of module mounting assemblies, one above the other, in a relay rack. There is no spacing requirement between stacked module mounting assemblies of a single system.
- 2.2.8 Mounting: The module mounting assembly is designed for mounting in a 23 inch wide relay rack with 1 inch or 1-3/4 inch multiple drilling. Mounting angles are positioned for a fixed 9-inch front projection mounting. Refer to "Overall Dimensions" starting on page 245 for dimensional illustrations.
  - This product is intended only for installation in a restricted access location on or above a non-combustible surface.
  - This product must be located in a controlled environment with access to crafts persons only.
  - This product is intended for installation in network telecommunication facilities (CO, vault, hut, or other environmentally controlled electronic equipment enclosure).
  - This product is intended to be connected to the common bonding network in a network telecommunication facility (CO, vault, hut, or other environmentally controlled electronic equipment enclosure).
  - The DC return connection to this system can remain isolated from system frame and chassis (DC-I).
  - This system is suitable for installation as part of the Common Bonding Network (CBN).
  - Rectifier, converter, and module mounting assembly ventilating openings must not be blocked and temperature of air entering rectifiers and converters must not exceed the rated operating ambient temperature range.
  - Clearance Requirements: The distance from the rear of the module mounting assembly to a wall or other solid structure must not be less than four (4) inches. This will assure proper airflow through the rectifier and converter modules.

**Note:** Minimum rear spacing specified for ventilation may not permit installation and maintenance of the system. Refer to "System Specifications" on starting on page 240 for increased clearance requirements.

## Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System

## System Application Guide

- 2.3 Compliance Information
  - 2.3.1 Safety Compliance: This unit meets the requirements of UL 60950-1, Standard for Information Technology Equipment, and is UL Recognized as a power supply for use in Telephone, Electronic Data Processing or Information Processing Equipment. This unit meets the requirements of CAN/CSA 22.2, No. 60950-00 and is tested and Certified by UL ("c UR") as a Component Type Power Supply.
  - 2.3.2 GR-3108 Class 2 Compliant
- 588705400 MODULE MOUNTING ASSEMBLY
  - 3.1 Output Ratings
    - 3.1.1 -48 VDC, 437 A, 21000 W (maximum).
  - 3.2 Input Ratings
    - 3.2.1 588705400 List 01, 02: 208 VAC, 240 VAC, 277 VAC, 50 Hz / 60 Hz, 1-Phase, 17.9 A / 15.5 A / 13.5 A.
    - 3.2.2 588705400 List 03: 208 VAC, 240 VAC, 50 Hz / 60 Hz, 3-Phase, 31 A / 27 A.
    - 3.2.3 588705400 List 04: 277/480 VAC, 50 Hz / 60 Hz, 3-Phase, 13.5 A.
  - 3.3 Environmental Ratings
    - 3.3.1 Operating Ambient Temperature Range: -40 °C to +40 °C (-40 °F to +104 °F).
    - 3.3.2 Storage Ambient Temperature Range: -40 °C to +85 °C (-40 °F to +185 °F).
    - 3.3.3 Humidity: Capable of operating in an ambient relative humidity range of 0 % to 95 %, non-condensing.
    - 3.3.4 Altitude: Capable of operating in an altitude range of -200 feet to 10,000 feet. The maximum operating ambient temperature should be de-rated by 3 °C per 1000 feet above 5000 feet.
    - 3.3.5 Ventilation Requirements:
      - (A) Ventilation: A module mounting assembly must be mounted so ventilating openings are not blocked and temperature of the air entering the shelf does not exceed the Operating Ambient Temperature Range stated above. Refer also to "Mounting" below.
      - (B) Stacking Considerations: This system is designed for front to back ventilation to facilitate stacking of module mounting shelves, one above the other, in a relay rack. There is no spacing requirement between stacked module mounting shelves of a single system.
    - 3.3.6 Mounting: The module mounting assembly is designed for mounting in a 23 inch wide relay rack with 1-3/4 inch multiple drilling. Mounting angles are positioned for a fixed 9-inch front projection mounting. Refer to "Overall Dimensions" starting on page 245 for dimensional illustrations.
      - This product is intended only for installation in a restricted access location on or above a non-combustible surface.
      - This product must be located in a controlled environment with access to crafts persons only.
      - This product is intended for installation in network telecommunication facilities (CO, vault, hut, or other environmentally controlled electronic equipment enclosure).
      - This product is intended to be connected to the common bonding network in a network telecommunication facility (CO, vault, hut, or other environmentally controlled electronic equipment enclosure).
      - The DC return connection to this system can remain isolated from system frame and chassis (DC-I).
      - This system is suitable for installation as part of the Common Bonding Network (CBN).
      - Rectifier and module mounting assembly ventilating openings must not be blocked and temperature of air entering rectifiers must not exceed the rated operating ambient temperature range.
      - Clearance Requirements: The distance from the rear of the module mounting assembly to a wall or other solid structure must not be less than four (4) inches. This will assure proper airflow through the rectifier modules.
        - **Note:** Minimum rear spacing specified for ventilation may not permit installation and maintenance of the system. Refer to "System Specifications" on starting on page 240 for increased clearance requirements.
  - 3.4 Compliance Information
    - 3.4.1 Safety Compliance: This unit meets the requirements of UL 60950-1, Standard for Information Technology Equipment, and is UL Recognized as a power supply for use in Telephone, Electronic Data Processing or Information Processing Equipment. This unit meets the requirements of CAN/CSA 22.2, No. 60950-00 and is tested and Certified by UL ("c UR") as a Component Type Power Supply.

## Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System

## System Application Guide

#### 4. OPTIONAL INVERTER SYSTEM

- 4.1 AC Input and DC Input Ratings
  - 4.1.1 Operating Voltage Range: 42 VDC to 58 VDC, 96 VAC to 140 VAC.
  - 4.1.2 Frequency Range: 50 Hz (47 Hz to 53 Hz) or 60 Hz (57 Hz to 63 Hz).
  - 4.1.3 Stopping Voltages: Refer to 4.1.1.
  - 4.1.4 Restart Voltages: After low voltage shutdown 48 VDC / 101 VAC; After high voltage shutdown 57 VDC / 135 VAC.
  - 4.1.5 Nominal Input Current (per inverter @ 100% load): 23 A @ -48 VDC, 8.8 A @ 120 VAC.
  - 4.1.6 Maximum Input Current (per inverter @ 100% load): 26.4 A @ -42 VDC, 11 A @ 96 VAC.
- 4.2 AC Output Ratings
  - 4.2.1 Nominal Output Voltage: 120 VAC.
  - 4.2.2 Output Voltage Tolerance: Fixed 120 VAC.
  - 4.2.3 Output Frequency: 50 Hz or 60 Hz.
  - 4.2.4 Total Harmonic Distortion (linear load): < 3% @ 100% linear load for inverter.
  - 4.2.5 Nominal Output Power: 1000 W / 1000 VA per inverter.
  - 4.2.6 Overload: 110% to 125% @ 42 VDC to 48 VDC (15s), 125% @ 96 VAC to 140 VAC (15s). Maximum input current: 3 x In (nominal current) for 120ms.
  - 4.2.7 Power Factor: >0.99.
- 5. RECTIFIER

Refer to the Rectifier Instructions (UM1R483500E, UM1R483500E3, or UM1R482000E3).

6. -48 VDC TO +24 VDC CONVERTER

Refer to the Converter Instructions (UM1C48241500).

7. -48 VDC TO -58 VDC CONVERTER

Refer to the Converter Instructions (UM1C48582000P3).

8. INVERTER

Refer to the Inverter Instructions (UM1I1201000).

9. CONTROLLER

Refer to the ACU+ Controller Instructions (UM1M820BNA) or NCU Controller Instructions (UM1M830BNA).

For controller factory settings, refer to the Controller Configuration Drawing (C-drawing).

## **MECHANICAL SPECIFICATIONS**


## **Overall Dimensions**

## **Relay Racks**


Refer to Table 17 for relay rack dimensions.

## Enclosure, P/N 563524

- 1. All dimensions are in inches.
- 2. Finish: Textured Dark Gray




Top View





## **List 21 (One-Row Distribution Cabinet)**


## Notes:

- 1. All dimensions are in inches, unless otherwise specified.
- 2. Finish: Textured Dark Gray or Textured White











### **List 22 (Two-Row Distribution Cabinet)**

- 1. All dimensions are in inches, unless otherwise specified.
- 2. Finish: Textured Dark Gray or Textured White






## **List 23 (Three-Row Distribution Cabinet)**

#### Notes:


- 1. All dimensions are in inches, unless otherwise specified.
- 2. Finish: Textured Dark Gray or Textured White







## List 24 (Four-Row Distribution Cabinet)

- 1. All dimensions are in inches, unless otherwise specified.
- Finish: Textured Dark Gray or Textured White







## 58212700050



## 58212700051




## 58212700052




## 582127000100, 582127000500


- 2. Finish: Textured Gray
- 3. Relay Rack Dimensions: 84"H x 25.8"W x 18"D
- 4. Relay Rack Available Rack Space: 26RU





## 582127000101, 582127000501

- 1. All dimensions are in inches.
- 2. Finish: Textured Gray
- 3. Relay Rack Dimensions: 60"H x 25.8"W x 18"D
- Relay Rack Available
   Rack Space: 4RU
   (1RU = 1.75") (accepts #12 hardware)










## 582127000102, 582127000502


#### Notes:

- 1. All dimensions are in inches.
- 2. Finish: Textured Gray
- 3. Relay Rack Dimensions: 72"H x 25.8"W x 18"D
- 4. Relay Rack Available

Rack Space: 3RU

(1RU = 1.75") (accepts #12 hardware)








Front View


Right Side View


- 2. Finish: Textured Gray
- 3. Relay Rack Dimensions: 84"H x 25.8"W x 18"D
- 4. Relay Rack Available


















- 1. All dimensions are in inches.
- 2. Finish: Textured Gray




Rear View










Front View Right Side View




Rear View

- 1. All dimensions are in inches.
- 2. Finish: Textured Gray.

Optional Battery Disconnect Circuit Breaker


## List 93 (Battery Tray)

- 1. All dimensions are in inches, unless otherwise specified.
- 2. Finish: Textured Dark Gray
- 3. Maximum trays available per rack is four (4).





## List 95 (Battery Tray)

- 1. All dimensions are in inches, unless otherwise specified.
- 2. Finish: Textured Dark Gray or White.
- 3. Maximum trays available per rack is four (4).




## 588705300 Module Mounting Assembly (List 01)





Left Side View





Rear View

#### Notes:

- 1. All dimensions are in inches, unless otherwise specified.
- 2. Weight in LBS.


Module Mounting Assembly


Net: 11.0 Rectifier Module Net: 2.5 Converter Module Net: 2.3

Module Mounting Assembly and Module Bodies:

Bright Zinc Plating Module Face Plates: **Textured Gray** 

#### 588705300 Module Mounting Assembly (List 03)





Notes:

Rear View

- All dimensions are in inches, unless otherwise specified.
- 2. Weight in LBS.

Module Mounting Assembly


Net: 11.7 Rectifier Module Net: 2.5 Converter Module Net: 2.3

3. Finish:

Module Mounting Assembly and Module Bodies:

Bright Zinc Plating Module Face Plates: Textured Gray

## 588705300 Module Mounting Assembly (List 61)







Rear View

Notes:

1. All dimensions are in inches.

## 588705400 Module Mounting Assembly (List 01, 11, 15)







## Notes:

- Rear View
- 1. All dimensions are in inches, unless otherwise specified.
- 2. Weight in LBS.

Module Mounting Assembly

Net: 11.0 Rectifier Module

Net: 3.7


3. Finish:


Module Mounting Assembly and Module Bodies:

Bright Zinc Plating
Module Face Plates:

Textured Dark Gray

## 588705400 Module Mounting Assembly (List 02, 03, 04, 12, 13, 14)







#### Rear View

#### Notes:

- All dimensions are in inches, unless otherwise specified.
- 2. Weight in LBS.

Module Mounting Assembly

Net: 13.5 Rectifier Module Net: 3.7

3. Finish:

Module Mounting Assembly and Module Bodies:

Bright Zinc Plating Module Face Plates:

Textured Dark Gray

# Weights

List Number or Part Number	Net Weight (lbs), each	Description
Common Equipme	nt	
58212700001	2	Common Equipment, Main Bay
58212700002	30	Common Equipment, 1st Supplemental Bay, Adjacent
58212700003	24	Common Equipment, 2nd through 5th Supplemental Bays, Adjacent
58212700005	1.5	Common Equipment, 1st through 5th Supplemental Bays, Remote
58212700007	59	Common Equipment, 1st Supplemental Bay, Enclosure Mounted
58212700008	47	Common Equipment, 2nd through 5th Supplemental Bays, Enclosure Mounted
Optional Inverter S	Systems	, , , , , , , , , , , , , , , , , , ,
58212700050	22	Inverter System
58212700051	23	Inverter System
58212700052	33	Inverter System
58212700053	34	Inverter System
111201000	2.5	Inverter Module
Configured Syster	ns	
582127000100	485	Power and Distribution Bay (Fully Configured)
582127000101	463	Power and Distribution Bay (Fully Configured with One Battery Tray)
582127000102	519	Power and Distribution Bay (Fully Configured with Two Battery Trays)
582127000203	588	Power and Distribution Bay (Fully Configured with Three Battery Trays)
582127000600 582127000601	135	Power and Distribution Bay (Fully Configured)
582127000900 582127000901	148	Power and Distribution Bay (Fully Configured)
582127000930	189	Power and Distribution Bay (Fully Configured)
582127000931	184	Power and Distribution Bay (Fully Configured)
582127000500	485	Power and Distribution Bay (Fully Configured)
582127000501	463	Power and Distribution Bay (Fully Configured with One Battery Tray)
582127000502	519	Power and Distribution Bay (Fully Configured with Two Battery Trays)
582127000503	588	Power and Distribution Bay (Fully Configured with Three Battery Trays)
Distribution Cabin	ets	
58212700021	55	Distribution Cabinet, 1 Row
58212700022	76	Distribution Cabinet, 2 Rows
58212700023	98	Distribution Cabinet, 3 Rows
58212700024	126	Distribution Cabinet, 4 Rows
Module Mounting	Assembly 58870	5300
58870530001	11	Module Mounting Assembly
58870530003	11.7	Module Mounting Assembly
58870530061	9.9	Module Mounting Assembly
1R482000E3	2.5	Rectifier Module
1C48241500	2.3	Converter Module
1C48582000P3	2.3	Converter Module
1C48583750P4	2.7	Converter Module

List Number or Part Number	Net Weight (lbs), each	Description			
Module Mounting Assembly 588705400					
58870540001	11	Module Mounting Assembly			
58870540002	13.5	Module Mounting Assembly			
58870540003	13.5	Module Mounting Assembly			
58870540004	13.5	Module Mounting Assembly			
58870540011	11.3	Module Mounting Assembly			
58870540012	13.8	Module Mounting Assembly			
58870540013	13.8	Module Mounting Assembly			
58870540014	13.8	Module Mounting Assembly			
58870540015	11.3	Module Mounting Assembly			
1R483500E3	3.7	Rectifier Module			
1R483600E4	3.9	Rectifier Module			
Controller					
1M830DNA	1.0	NCU			
1M820DNA	1.0	ACU+			
Rectifier					
1R483500E	7	Rectifier Module			
1R484000E	5.4	Rectifier Module			
Battery Accessori	es				
58212700090	1.5	Battery Shunt, 800 A			
58212700091	3.5	Battery Shunt, 2000 A			
58212700092	3.2	Battery Shunt, 2500 A			
58212700093	32	Integrated, Pre-cabled Battery Tray			
58212700095	35.7	Optional Battery Tray, Pre-Cabled, For System Mounted in a Relay Rack Only, 22.5" Deep			
559813 559814	1	Battery Disconnect Breaker Kit, 1-pole			
559815 559816	1.5	Battery Disconnect Breaker Kit, 2-pole			
Distribution Panel	s, Primary Volta	ge			
582127000AC	6	Distribution Panel			
582127000AD	5	Distribution Panel			
582127000AF	16	Distribution Panel			
582127000AH	22	Distribution Panel			
582127000AL	12.6	Distribution Panel			
582127000AM	17	Distribution Panel			
582127000AN	9.6	Distribution Panel			
582127000AP	8	Distribution Panel			
Distribution Panel	s, Dual Voltage				
582127000DE	14	Distribution Panel			
582127000DF	14	Distribution Panel			
582127000DG	14	Distribution Panel			

List Number or Part Number	Net Weight (lbs), each	Description				
582127000DH	14	Distribution Panel				
582127000DH 582127000DJ	14	Distribution Panel				
582127000DK	14	Distribution Panel				
582127000FE	14	Distribution Panel				
582127000FF	14	Distribution Panel				
582127000FG	14	Distribution Panel				
582127000FH	14	Distribution Panel				
582127000FJ	14	Distribution Panel				
582127000FK	14	Distribution Panel				
Distribution Panel	Distribution Panels, Battery Disconnect					
582127000BC	10	Distribution Panel				
582127000BD	8	Distribution Panel				
582127000BF	20	Distribution Panel				
582127000BH	25	Distribution Panel				
Battery Disconnect Contactors						
582127000CA	7	600 Amp Battery Disconnect Contactor				
582127000CB	6	1200 Amp Battery Disconnect Contactor				
582127000CC	6	2000 Amp Battery Disconnect Contactor				
Bulk Output Panel						
582127000EA	11	Bulk Output Panel				
Ground Bar	1					
582127000GA	11	Ground Bar				
Low Voltage Disco	onnect					
582127000LL	2.5	Low Voltage Load Disconnect Option				
Manual Battery Di		Zow ronago zoda piocomiost option				
582127000MB	1	Manual Battery Disconnect Option				
	I	Marida Battery Disconnect Option				
Distribution Eleme	1	I.W. 0.5. W. 0.175				
549017	1.5	Kit, 6-Position GMT Fuse Module, 35 A				
60160806	3.2	Kit, 6-Position GMT Fuse Module, 30 A, With RTN Cable				
60147273	1.0	+27 VDC Vertiv™ eSure™ Bullet Converter				
10062803	1.0	Kit, +27 VDC Bullet Nose 6-Position GMT Fuse Board				
256623500	0.6	Circuit Breaker, 250 A, GJ/218, One-pole, Without Shunt				
256626200	1.2	Circuit Breaker, 400 A, GJ/218, Two-pole, Without Shunt				
256628200	2	Circuit Breaker, 600 A, GJ/218, Three-pole, Without Shunt				
550249	3	Circuit Breaker, 800 A, GJ/218, Four-pole, With Shunt				
Relay Racks						
562360	46	Relay Rack				
559817	51	Relay Rack				
559818	103	Relay Rack				
559820	113	Relay Rack				
562353	243	Relay Rack				

# Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System System Application Guide

List Number or Part Number	Net Weight (lbs), each	Description		
10009902	243	Relay Rack		
562355	246	Relay Rack		
559821	81	Relay Rack		
559822	123	Relay Rack		
564169	187	Relay Rack		
564127	208	Relay Rack		
Enclosures				
563524	221	Enclosure, Seismic, 84"H x 28"W x 28"D, No Side Panels, Dark Gray Color		
563666	22	Enclosure Side Panel, Dark Gray Color, Qty. 1		
564881	221	Enclosure, Seismic, 84"H x 28"W x 28"D, No Side Panels, White Color		
564889	22	Enclosure Side Panel, Qty. 1, White Color		

## Vertiv<sup>™</sup> NetSure<sup>™</sup> 7100 DC Power System System Application Guide

#### **RELATED DOCUMENTATION**

System Quick Start Guide:QS582127000System Installation Instructions:IM582127000System User Instructions:UM582127000

ACU+ Controller Instructions: UM1M820BNA or UM1M820DNA400

NCU Controller Instructions:UM1M830BNARectifier Instructions:UM1R483500E3Rectifier Instructions:UM1R483500ERectifier Instructions:UM1R482000E3Converter Instructions:UM1C48241500Converter Instructions:UM1C48582000P3Inverter Instructions:UM11201000

**NCU Controller 2nd Ethernet Port** 

Add-On Kit Instructions: IM559252

**NCU Controller 2nd Ethernet Port** 

Retrofit Kit Instructions: IM559251

System Installation Instructions (List 100, 101, 102, IM582127000100

203, 500, 501, 502, 503):

System User Instructions (List 100, 101, 102, 203, UM582127000100

500, 501, 502, 503):

System Installation Instructions (List 600, 601, 900, 901, IM582127000900

930, 931):

**System User Instructions (List 600, 601, 900, 901, 930, 931):** UM582127000900

Main Schematic Diagrams: SD582127000 (System)

SD588705300 (Module Mounting Assembly) SD588705400 (Module Mounting Assembly)

Main Wiring Diagrams: T582127000 (System)

#### **BATTERY MANUFACTURER INFORMATION**

Some equipment described in this System Application Guide is designed to accommodate batteries from various manufacturers. The following are referenced in this document.

C&D: C&D Technologies, Inc., Powercom Div., 1400 Union Meeting Road, Blue Bell, PA 19422-0858

Deka®: East Penn Mfg. Co., Inc., Lyon Station, PA 19536-0147

**Douglas**: Douglas Battery Mfg. Co., 500 Battery Dr., Winston-Salem, NC 27117-2159 **Fiamm:** FIAMM T.I, 23880 Industrial Park Drive, Farmington Hills, Detroit, MI 48335

Marathon™: GNB Industrial Power, a Division of Exide Technologies, Princeton, NJ 08543. Northstar: NorthStar Battery Co. LLC, 4000 Continental Way, Springfield, MO 65803

PowerSafe Enersys™: EnerSys Inc., Reading, PA, 196212-4145

#### Vertiv.com | Vertiv Headquarters, 505 N Cleveland Ave, Westerville, OH 43082, USA

© 2025 Vertiv Group Corp. All rights reserved. Vertiv™ and the Vertiv logo are trademarks or registered trademarks of Vertiv Group Corp. All other names and logos referred to are trade names, trademarks or registered trademarks of their respective owners. While every precaution has been taken to ensure accuracy and completeness here, Vertiv Group Corp. assumes no responsibility, and disclaims all liability, for damages resulting from use of this information or for any errors or omissions.

