



Manufacturer's Name: <u>Vertiv Tech Co., Ltd.</u>

Manufacturer's Address: 1-4F, 6-10F, Block B2, Nanshan I Park,

No.1001 Xueyuan Road, Nanshan District,

Shenzhen, Guangdong, China

Zip Code 518055

For the following equipment

Product: Uninterruptible Power System (UPS)

Type Designation:

UPS:GXT5-5000HVRT5UXLN,GXT5-5000IRT5UXLE.

GXT5-5000IRT5UXLN,GXT5-6000IRT5UXLN.

GXT5-6000IRT5UXLE.

External Battery Cabinet: GXT5-EBC192VRT3U

POD:PD5-CE6HDWRMBS, PD5-CE6HDWRMBSU

is herewith confirmed to comply with the requirements set out in Directive 2014/35/EU, Directive 2014/30/EU, and Directive 2011/65/EU. Compliance with 2014/35/EU and 2014/30/EU are evaluated by applying the following standards:

Safety standard: EN 62040-1:2008+A1:2013

EMC standard: EN 62040-2:2006 EN 61000-3-11:2000

EN 61000-3-12:2011

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Signature: _____ Date : <u>2018-11-22</u>

Weiguo Zeng

Position/Title: Senior Director, R&D/Engineering



Annex Information

Product: <u>Uninterruptible Power System (UPS)</u>

Type Designation:

UPS:GXT5-5000HVRT5UXLN,GXT5-5000IRT5UXLE.

GXT5-5000IRT5UXLN,GXT5-6000IRT5UXLN.

GXT5-6000IRT5UXLE.

External Battery Cabinet: GXT5-EBC192VRT3U

POD:PD5-CE6HDWRMBS, PD5-CE6HDWRMBSU

LVD Compliance test report

Issued by: TÜV Rheinland (Shenzhen) Co., Ltd

Report number: 50155039 001

Dated: Nov 02, 2018

EMC Compliance Test report Issued by: <u>Vertiv Tech Co., Ltd.</u>

Report number: GXT5 Small 230 UPS-TCC-3V1D0

Dated: Nov 02, 2018

EMI limit Value: Category C2

Power Port Type: AC